Portland State University

PDXScholar

Dissertations and Theses

Dissertations and Theses

Winter 1-8-2015

Sensible Air to Air Heat Recovery Strategies in a Passive House

Santiago Martin Rodriguez-Anderson
Portland State University

Follow this and additional works at: https://pdxscholar.library.pdx.edu/open_access_etds

Part of the [Energy Systems Commons](#), [Environmental Design Commons](#), and the [Sustainability Commons](#)

Let us know how access to this document benefits you.

Recommended Citation

Rodriguez-Anderson, Santiago Martin, "Sensible Air to Air Heat Recovery Strategies in a Passive House" (2015). *Dissertations and Theses*. Paper 2123.
<https://doi.org/10.15760/etd.2121>

This Thesis is brought to you for free and open access. It has been accepted for inclusion in Dissertations and Theses by an authorized administrator of PDXScholar. Please contact us if we can make this document more accessible: pdxscholar@pdx.edu.

Sensible Air to Air Heat Recovery Strategies in a Passive House

by

Santiago Martin Rodriguez-Anderson

A thesis submitted in partial fulfillment of the
requirements for the degree of

Master of Science
in
Mechanical Engineering

Thesis Committee:
David Sailor, Chair
Huafen Hu
Graig Spolek

Portland State University
2014

©2014 Santiago Martin Rodriguez-Anderson

Abstract

Due to rising energy costs and concerns about global climate change, high performance buildings are more in demand than ever before. With roughly 20% of the total energy consumption in the United States being devoted to residential use, this sector represents a significant opportunity for future savings. There are many guidelines and standards for reducing building energy consumption. One of the most stringent is the Passive House Standard. The standard requires that that air infiltration is less than or equal to 0.6 air changes per hour at a 50 Pascal pressure difference (ACH_{50}), annual heating energy is less than or equal to 15kWh/m^2 , and total annual source energy is less than or equal to 120 kWh/m^2 . For comparison, the typical West coast US residence has an ACH_{50} of 5 and annually uses more than 174 kWh/m^2 of source energy according to the 2009 Residential Energy Consumption Survey. With these challenging requirements, successful implementation of the Passive House Standard requires effective strategies to substantially reduce energy consumption for all end uses.

Heating and cooling loads are low by necessity in a Passive House. As such this makes end uses like water heating a much larger fraction of total energy use than they would be in a typical building. When air to water heat pumps are employed the energy consumption by water heating is lowered significantly. By employing innovative heat recovery strategies the energy consumption for water heating and HVAC can be reduced even further. This

study uses energy modeling and project cost analysis to evaluate three innovative control strategies. Results for a Passive House in Portland Oregon show a savings of about \$70 annually with a payback period of 10 years. The same Passive House in Fairbanks Alaska with a different strategy would save \$150 annually with a payback period of 5 years.

Dedication

I dedicate this thesis to my wife Krista who always encouraged me to think big and always made me laugh when times got tough. I also owe thanks to La Familia Rodriguez and the rest of my friends and family who supported me through the trials and tribulations of higher education.

Acknowledgments

Foremost, I would like to express my gratitude to my advisor and committee chair, David Sailor, for his steadfast support and guidance. I would also like to thank my committee members, Huafen Hu and Graig Spolek, for their support and feedback.

I would like to thank Ella Wong, Randy Hayslip for letting me troubleshoot equipment in their house and spend time observing what it is like living in the house of the future.

Special thanks to Jeff Lauck for helping debug my EnergyPlus Programs, and Natalie Sherwood for listening to my colorful observations on programming.

The Trekhaus project would not have been possible without current and former students and staff of the Green Building Research Laboratory, especially Jeff Lauck, Christophe Parroco, Daeho Kang, Pamela Wallace, Stephanie Jacobsen, and Steve Gross for their assistance with instrument installation, energy modeling, and data analysis.

Contents

Abstract.....	i
Dedication.....	iii
Acknowledgements.....	iv
List of Tables.....	vii
List of Figures.....	viii
1. Introduction	1
1.1 Motivation and background.....	1
1.1.1 Inspiration for This Study.....	3
2. Methods.....	7
2.1 Site Description	7
2.1.1 Location and Climate	7
2.1.2 Construction Details and Occupancy.....	9
2.1.3 Mechanical Equipment Description.....	12
2.2 EnergyPlus Model Description	13
2.2.1 Model Overview.....	13
2.2.2 Key Features of the Simplified Model.....	15
2.2.3 Major Components, Assumptions, and Limitations	21
2.3 Analysis Approach	22
2.3.1 Analysis Overview	22
2.3.2 Heat Recovery Experimentation with Energy Model	22
2.3.3 Cost Analysis	22
3. Results.....	26
3.1 Simulation Data	26
3.1.1 Baseline Case Simulation Results.....	26
3.1.2 End Use Energy Savings for Portland Oregon.....	27
3.1.3 Total Energy Savings for all Simulated Cities	29
3.2 Cost-Benefit Data	31

4.	Discussion	33
4.1	Heat Recovery Performance	33
4.1.1	Analysis of Energy Data.....	33
4.1.2	Analysis of Cost Data.....	36
4.2	Comparison to other studies.....	37
4.3	Potential Drawbacks.....	38
4.4	What could be done differently?	39
5.	Conclusion	41
	References	43
6.	Appendix A - Energy Plus.....	45
7.	Appendix B - Additional Data Figures.....	53
8.	Appendix C - Contents of Supplemental Data Files.....	58

List of Tables

Table 2-1 Summary data of simulation climate data.....9

Table 2-2 Envelope construction summary for simplified Passive House
model 11

Table 2-3 Glazing summary for simplified Passive House model 12

Table 2-4 Electric utility billing rates for chosen simulation cities 24

Table 2-5 Summary of cost analysis metrics..... 24

Table 3-1 Cost-benefit results for Portland Oregon 32

Table 3-2 Cost-Benefit results for Fairbanks Alaska 32

Table 3-3 Cost-Benefit data for Phoenix Arizona 32

List of Figures

Figure 1-1. An overview of energy consumption in the United States in 2010..	1
Figure 1-2 NREL evaluation of COP for the heat pump water heater used in the Trekhaus study.....	15
Figure 1-3 Trekhaus heat recovery ventilator stream temperature.....	6
Figure 1-4 Water heating energy profiles for Trekhaus	6
Figure 2-1 Location of Trekhaus	7
Figure 2-2 Map of all simulation climates.....	8
Figure 2-3 Trekhaus, a passive house duplex home	9
Figure 2-4 Open studio model of a Passive House created in Sketchup ..	10
Figure 2-5 Base line HVAC diagram	17
Figure 2-6 Case A: Heat recovery of HRV exhaust diagram.....	18
Figure 2-7 Case B: Heat recovery of cold HPWH compressor exhaust.....	19
Figure 2-8 Case C: Combined strategies of Case A and Case B.....	20
Figure 3-1 Baseline Case energy consumption for Passive House model in Portland Oregon.....	27
Figure 3-2 Energy savings compared to the Baseline Case for fans in Portland Oregon.....	27
Figure 3-3 Energy savings compared to the Baseline Case for cooling in	

Portland Oregon..... 28

Figure 3-4 Energy savings compared to the Baseline Case for heat recovery in Portland Oregon..... 28

Figure 3-5 Energy savings compared to the Baseline Case for hot water in Portland Oregon..... 29

Figure 3-6 Total Energy savings from Baseline Case in Portland Oregon..30

Figure 3-7 Total energy savings compared to Baseline Case in Fairbanks Alaska30

Figure 3 8 Total energy savings compared to Baseline Case in Phoenix Arizona.....31

1. Introduction

1.1 Motivation and background

The United States accounted for 19% of the world's primary energy consumption. Roughly twenty two percent of that primary energy consumption was used in residential buildings [1]. The combined statistic is that residences in the United States consume 4.2% of global primary energy produced. This means that U.S. homes consume nearly one twentieth of the primary energy produced worldwide.

Figure 1-1. An overview of energy consumption in the United States in 2010. Commercial and residential buildings in the U.S. account for 41% of the country's total source energy consumption. [1].

Rising energy prices and strong indicators of global climate change have begun to shift policy toward high efficiency in as many aspects of American life as possible. The Passive House standard is fast becoming a leading efficiency standard for residential buildings. The Passive House Standard is widely used

throughout Europe and is becoming more common in the United States.

Originally developed in Germany, the Passive house Standard requires not only consideration of total site energy consumption, but also source energy use.

Source energy and site energy consumption differ in that site energy only accounts for end use totals, while source energy accounts for losses in production and transmission. A building that produces electricity on site would have a lower source energy consumption than a similar building that gets its electricity from the grid [2].

The Passive House Standard requires that a building use less than or equal to 120 kWh/m² per year of total source energy, and less than or equal to 15 kWh/m² of heating and cooling energy. In addition the standard requires that infiltration rates be no more than 0.6 air changes per hour at a 50 Pascal [3]. This ends up being roughly 10% of a typical home's energy consumption and 10% of typical infiltration rates [4]. The strict requirements on infiltration necessitate the use of airtight envelopes and heat recovery ventilators to provide sufficient fresh air to building occupants without sacrificing occupant comfort. In addition to high efficiency ventilators, efficient heating and cooling is also necessary to achieve the strict 15 kWh/m² requirement. Typically a heat pump of some kind will achieve this end. A variety of other energy efficient appliances are often used. If energy consumption for heating and cooling is reduced to about a tenth of the allowable energy use intensity, then hot water heating will become the largest end use. Tankless water heaters and heat pump water heaters are

popular choices to help reduce consumption from this end-use.

Heat pumps use a refrigeration cycle to either reject heat from a space or to add heat to it. If a heat pump is rejecting heat from a space, its efficiency is improved as the environment around the condenser gets colder. This is because a greater temperature difference increases the rate of heat rejection with the environment. This is similar to the case where heat is being added to an environment with a heat pump. A greater temperature difference between the heat reservoir and the evaporator increases the rate of heat addition to the environment. These basic principles of heat pumps mean that any time that an environment can be made more favorable for an evaporator or condenser, the heat pump will require less energy to operate. These more favorable conditions could be achieved with strategic recovery of waste heat. These benefits would vary depending on the typical operating environment. To observe the full range of operating possibilities one would need to examine operation across a range of climate conditions.

1.1.1 Inspiration for This Study

Trekhaus is a Passive House that has been a part of a variety of studies by the Green Building Research Lab since it was first occupied by the owners in 2012 [4]. This building is a Passive House duplex located in Portland Oregon. Key

features include walls with an R-value (SI) of 9.82 triple paned argon-filled windows, mini-split heat pump, heat recovery ventilator, and heat pump water heater [5]. Additionally, the Trekhaus includes Phase Change materials in the western unit in an attempt to improve thermal comfort. The Trekhaus occupants and researches noted that the heat pump water heater in their workshop put out cold air exhaust whenever it operated. During the summer, the occupants would leave the workshop door open to cool the house with exhaust air. It became a matter of curiosity among the researchers as to what level of benefit this afforded the occupants. On an intuitive level it made sense to make use of the free cooling.

Further investigation led to the conclusion that measures to raise the operating air temperature of the heat pump water heater were desirable. NREL did a study on a group of five different heat pump water heaters to evaluate a variety of performance metrics [6]. One of those water heaters studied included the water heater used in Trekhaus. One important finding of that study was that the Coefficient of Performance (COP) of the hot water heaters was highly dependent upon the Wet Bulb (WB) temperature of the compressor air intake. The trend was that a higher wet bulb temperature meant a higher COP for the water heater (see **Figure 2-1**). There is a positive correlation with wet bulb temperature and dry bulb temperature. A higher dry bulb temperature means a higher enthalpy of air entering the compressor intake.

Figure 1-2 NREL evaluation of COP for the heat pump water heater used in the Trekhaus study. (From: Laboratory Performance Evaluation of Residential Integrated Heat Pump Water Heaters)[6]

As part of a study of the heat recovery ventilator efficiency in the Trekhaus, a large quantity of data for typical air temperatures at each of the ducts leading into and out of the ventilator was recorded and analyzed. The general observation was that the exhaust air was warmer at night than the outdoor air because of the ventilator operating in economizer mode (see **Figure 1-3**). This continued into the late morning while hot water was being heated (see **Figure 1-4**) [5]. It seemed likely that there could be some energy savings by using that exhaust air to help heat the intake air for the hot water heater. This would

be especially true in the winter months, as the occupants noted that it got colder in the workshop than it did outside.

Figure 1-3 Trekhaus heat recovery ventilator stream temperatures [5]

Figure 1-4 Water heating energy profiles for Trekhaus [5]

2. Methods

This analysis uses collected data on the construction and operation of a house used in a field study in Portland Oregon. This data is incorporated into an energy model which then provides energy consumption data. The energy consumption data is used for cost analysis.

2.1 Site Description

The sites for the simulation study include the original field study location in Portland Oregon as well as two additional locations with different climates.

2.1.1 Location and Climate

The model used in this study is based on the Trekhaus passive house. Trekhaus is a privately-owned three-bedroom duplex in Portland Oregon. The

Figure 2-1 Location of Trekhaus (<https://maps.google.com>)

general location in the United States is shown in **Figure 2-1**. Trekhaus was designed to meet the Passive House standard in ASHRAE Climate Zone 4C, a mixed marine climate with 2346 heating degree days and 235 cooling degree

days (18.3°C base) [7]. The same building model is also evaluated in Pheonix Arizona, and Fairbanks Alaska to provide a cold climate and a hot climate to compare equipment operation conditions. The general locations for the model are shown in **Figure 2-2**. There were no changes to the model for different climate conditions. It should be noted that there would be construction and design differences to be able to meet the passive house standard in different climates. Each of these climates would present different demands on the building. A building in Fairbanks would use substantially more energy for zone heating or water heating than a building in Portland. The same building in Pheonix would have much higher demands for cooling than its twin in Portland.

Figure 2-2 Map of all simulation climates (<https://maps.google.com>)

Table 2-1 Summary data of simulation climate data

<i>Location</i>	<i>Heating Degree Days</i>	<i>Cooling Degree Days</i>	<i>1% Dehumidification HR (grains/kgda)</i>
<i>Portland OR at PDX AP</i>	2346	235	11.0
<i>Phoenix AZ at Sky Harbor AP</i>	523	2532	16.3
<i>Fairbanks AL AP</i>	7516	39	9.8

2.1.2 Construction Details and Occupancy

Trekhaus is a two story duplex from which many model elements were selected. Some items of particular importance are the high window to wall ratio

Figure 2-3 Trekhaus, a passive house duplex home, is divided into two mirror-image apartments with a party wall on the north-south axis. on the southern wall, total floor area, infiltration rates, ventilation rates, and envelope construction. The model in this simulation study is a single floor and a stand-alone structure. The building has a conditioned floor area of 148.6 m², and

an unconditioned work shop with floor area of 9.3 m². Although the workshop is unconditioned, its walls are still built up like the exterior to separate it both from the conditioned zone and the outside conditions. The model has only one floor to more effectively treat the building as a single conditioned zone. Lighting density was determined from the electrical equipment loads that were tallied from Trekhaus surveys and provided they overall equipment load for this model. The envelope for the model is a simplified version of what was used in Trekhaus. The exterior wall construction layers from outside to inside are wood siding, 100mm foil faced polyisocyanurate insulation, 12 mm plywood sheathing, 184 mm blown-in cellulose insulation, and 16 mm gypsum board. From outside to inside, roof construction consists of a single-ply membrane, 178 mm

Figure 2-4 Open studio model of a Passive House created in Sketchup

polyisocyanurate insulation, 19 mm plywood decking, 300 mm blown-in cellulose

insulation, and 16 mm gypsum board. The floor is a 100 mm thick concrete slab insulated with 170 mm of expanded perlite and 100 mm of expanded polystyrene. The data for this construction is summarized in **Table 2-2**.

The windows in the model are all fixed frame with three layers of glazing and a 90% argon/10% air mixture in between the panes. Low-e coatings are also used to affect the Solar Heat Gain Coefficient (SHGC) of the windows. The South facing windows have coatings on surfaces three and five, while all other windows have the coatings on surfaces two and five (counting from inside to outside). The details of the glazing are summarized in **Table 2-4**.

Table 2-2 Envelope construction summary for simplified Passive House model

<i>Construction</i>	<i>Material</i>	<i>Thickness (m)</i>	<i>Thermal Conductivity (W/m K)</i>	<i>R- Value (m² k/W)</i>	<i>Total Assembly R-Value (m² k/W)</i>
<i>Foundation Slab</i>	Expanded Perlite	0.171	0.054	3.156	6.11
	Extruded Polystyrene	0.102	0.035	2.910	
	Concrete	0.102	2.060	0.049	
<i>Exterior Wall</i>	Siding	0.019	0.103	0.185	9.82
	Air Gap	-	-	0.150	
	Polyisocyanurate Insulation	0.102	0.021	4.826	
	Plywood Sheathing	0.013	0.098	0.130	
	Blown-In Cellulose Insulation	0.184	.042	4.431	
	Gypsum Board	0.016	.159	0.100	
<i>Roof</i>	Single-Ply Membrane	-	-	-	15.97
	Polyisocyanurate Insulation	0.178	0.021	8.445	
	Plywood Decking	0.016	0.098	0.165	
	Blown-In Cellulose Insulation	0.302	0.042	7.258	
	Gypsum Board	0.016	0.159	0.100	

Table 2-3 Glazing summary for simplified Passive House model

<i>Façade</i>	<i>Window Type</i>	<i>Low-e Surfaces</i>	<i>Center of Glass</i>			<i>Total Window</i>	
			Visible Transmittance	SHGC	U-factor (W/m ² K)	SHGC	U-factor (W/m ² K)
<i>South</i>	Fixed	3, 5	0.63	0.59	0.88	0.51	0.97
<i>North, East, West</i>	Fixed	2, 5	0.57	0.36	0.71	0.31	0.81

2.1.3 Mechanical Equipment Description

The passive house standard sets high standards for primary energy consumption as a whole, but for HVAC needs in particular. Trekhaus meets its heating and cooling needs with a Mitsubishi Mr. Slim mini-split heat pump, consisting of an SUZ-KA09NA outdoor unit coupled to an SEZ-KD09NA indoor unit. This system has rated heating and cooling capacities of 3.2 kW and 2.4 kW, respectively. The specifications of this heat pump were chosen for the simplified Passive House model. Due to the low infiltration rates in Passive Houses, dedicated mechanical ventilation systems are needed to provide appropriate indoor air quality for occupants. The addition of heat recovery is a common choice because it reduces the demand for heating and cooling by preconditioning air entering a space. Depending on the climate, either a flat plate heat exchanger or a heat wheel are used for heat recovery. A climate without high dehumidification demand is ideal for a flat plate heat exchanger

like the one used in Trekhaus. The full air handling unit including the heat exchanger, supply, and exhaust fans is commonly referred to as a Heat Recovery ventilator (HRV). The simplified Passive House model uses an HRV with specification matching that of the Zehnder ComfoAir™ 350 used in Trekhaus.

Domestic hot water is another major source of energy consumption. Trekhaus meets its hot water needs with an AirGenerate AirTap™ AT150 heat pump water heater (HPWH) with a storage capacity of 189 L. The water heater in Trekhaus is located in the unconditioned workshop. This particular HPWH has the compressor and evaporator fixed to the tank. As it is configured the workshop air serves as both the heat source and heat sink for HPWH refrigerant cycle. The heat pump is nominally rated at 2.75 kW with the primary and backup electric elements nominally rated at 4 kW. This water heater can operate in three modes: heat pump only, electric element only, and hybrid mode.

2.2 EnergyPlus Model Description

The energy models described provide computational data to research without requiring extensive experimental setup.

2.2.1 Model Overview

The energy model used in this study was created using EnergyPlus, a whole building simulation developed by the U.S. Department of Energy [8]. Although EnergyPlus provides excellent flexibility and power in developing a model, creating even a simple building from scratch can be a tedious and error

prone process. To this end NREL has developed a GUI energy modeling tool called Open Studio. Open Studio runs on the EnergyPlus engine and has plugins available for Sketchup. Sketchup and its Open Studio plugin were used to develop the basic floor plan and fenestration placement for the simplified Passive House model. The building geometry was then brought into the Open Studio environment where basic HVAC configurations, schedules, and setpoints were programmed in. This model was then exported to an EnergyPlus Input Design File (IDF). The IDF environment allows for objects to be imported from existing models.

The existing Trekhaus model was first developed by Christophe Parroco (a former staff member of the Green Building Research Laboratory) using the third-party GUI, DesignBuilder™, and then exported to the EnergyPlus Input Data File format. Further development of the HVAC systems, mainly the mini-split heat pump and HRV, was performed by Daeho Kang (a postdoctoral researcher in the Green Building Research Laboratory)[9]. Further validation and research on phase change material used in Trekhaus was done by Jeffery Lauck.

This model study will examine the effectiveness of employing additional sensible heat exchangers to make use of exhaust energy from both the heat pump water heater and the heat recovery ventilator. The particular EnergyPlus object that was added or modified was HeatExchanger:AirToAir:SensibleAndLatent. The simplified model in this study takes some HVAC, efficiency curves, and constructions from the Trekhaus model.

2.2.2 Key Features of the Simplified Model

The Baseline Case of a simple passive house uses a heat recovery ventilator to bring in fresh outdoor air and exhaust stale air. When the enthalpy of the HRV return air is greater than that of the outdoor air, the bypass (economizer) mode is activated. Mechanical heating and cooling are provided solely by the heat pump. The heat pump water heater is in an unconditioned workshop adjacent to the house. The compressor inlet draws from the workshop air. The compressor also exhausts into the workshop. This Base Case is shown in **Figure 2-5**.

One alternate configuration is where the HRV exhaust air is passed to the exhaust side of an additional sensible heat exchanger before being sent outdoors. This air has a higher enthalpy than the outdoor air regardless of season or HRV operating mode because it contains some of the heat generated inside the house. Since the passive house would not be losing heat through infiltration, most of the sensible heat will be exhausted through the HRV. The supply side of the added heat exchanger takes in workshop air and preheats it before feeding into the HPWH compressor intake. The objective of this design is to improve the efficiency of the airside portion of the HPWH refrigeration cycle thereby reducing the HPWH energy consumption. Hereafter this configuration will be called Case A. The details of Case A can be seen in **Figure 2-6**.

Another configuration that is considered (Case B) sends exhaust from the

HPWH compressor through the exhaust side of an added sensible heat exchanger. After passing through the heat exchanger, the outlet mixes with the workshop air. The supply side of the heat exchanger preconditions the room air before feeding to the MSHP intake. The desired effect is to reduce the need for cooling and heat recovery energy for the controlled zone. If the air being supplied to the interior space is preconditioned, then the bypass mode on the HRV can run for longer periods. Passive houses typically require more cooling than heating during shoulder seasons and summer so this can be a significant energy savings. In addition this will keep the workshop warmer and provide some improvement to the HPWH efficiency. Hereafter this configuration will be called as Case B. The details of Case B can be seen in **Figure 2-7**.

It is possible to combine Case A and Case B to try to reap different benefits at different times. In either case, HPWH energy consumption should be reduced. Even with this reduction, it could be beneficial to choose to precondition air entering the controlled zone, or to decouple the controlled zone from the workshop. This combined case would require two sensible heat exchangers and a series of dampers to control the flow path. The flow pathway is just as is described for Case A and Case B. Some additional dampers would be needed to ensure that only one of the cases is selected at a given time. This configuration will be called case C. The details of Case C can be seen in **Figure 2-8**

Figure 2-5 Base line HVAC diagram

Figure 2-7 Case B: Heat recovery of cold HPWH compressor exhaust

Figure 2-8 Case C: Combined strategies of Case A and Case B

2.2.3 Major Components, Assumptions, and Limitations

The approach to implement these heat recovery designs is fairly straightforward. An additional sensible heat exchanger object and connections to the relevant equipment were added. The details of the HRV, HPWH, and add on heat exchangers are shown in Appendix A. The HRV exhaust fan, MSHP fan and the HPWH fan fulfill all the needs for prime movers for the air.

There are controls in the form of setpoints and usage schedules for the Heat Recovery Ventilator, Mini-Split Heat Pump, and Heat Pump Water Heater. Any additional heat recovery is done every hour of every day. In Case C a choice is made each month to switch from one heat recovery mode to the other. Implementing appropriate “smart” differential controls for this type of heat recovery is complex. The purpose of this model is to see if there will be savings even in a simple add-on to a typical HVAC configuration without needing a specialized Direct Digital Control (DDC). This model will not reflect all of possible savings from heat recovery controlled at an hourly level, nor does it account for the possibility of choosing outdoor air as a heat source or sink.

2.3 Analysis Approach

2.3.1 Analysis Overview

The analysis in this study has two general categories: simulated energy consumption for Passive House models and cost analysis to determine the financial feasibility for each case in the chosen climates. This assists in the decision making process of whether or not to employ a heat recovery strategy.

2.3.2 Heat Recovery Experimentation with Energy Model

The energy model has several electrical end uses of interest: fans, heating, cooling, heat recovery, and hot water. These values were determined on a monthly basis for the Base Case, Case A, and Case B. Case C will be determined afterward since it is simply the ideal schedule choice for a given month between A and B based on the simulated energy consumption for Case A or Case B. The energy use for the alternate cases was subtracted from the Base Case. This method calculates the energy savings from employing heat recovery. It is possible to have negative savings if the energy use for a given category was higher than the Base Case. Although it is informative to see the differences in each individual end use from one case to another, it is the sum of the savings that matters for determining the value of a choice.

2.3.3 Cost Analysis

Equipment lifespan, inflation rates, interest rates and initial equipment

costs factor into the present worth of an energy savings choice. Although a simply payback calculation may be sufficient (See **Equation 1**), it is better to use the present worth equations to determine the explicit monetary value of a choice. **Equation 2** is the total present worth of an investment.

$$\text{Payback Period} = \frac{\text{Investment Cost}}{\text{Yearly Savings}} \quad (1)$$

$$P = A \left[\frac{(1+i)^N - 1}{i(1+i)^N} \right] + G \left[\frac{(1+i)^N - iN - 1}{i^2(1+i)^N} \right] - C \quad (2)$$

Here, A is the annual savings, G is the annual Inflation cost, C is the initial investment cost, i is the interest rate, and N is the lifetime of the equipment in years. We use inflation rates and interest rates that reflect the norm in the Western United States [10]. The billing rates used reflect the mean residential price as stated by local utilities. Portland prices have a set rate for consumers using less than 1000 kWh. Phoenix has varying rates throughout the year, so the rates were averaged to a mean annual value. Fairbanks has only a single listed rate for residential consumers. All rates are summarized in **Table 2-3**.

Table 2-4 Electric utility billing rates for chosen simulation cities

<i>Region and Electric Utility Company</i>	<i>Billing Rate (\$/kWh)</i>
<i>Portland OR, PGE [11]</i>	0.10320
<i>Fairbanks Alaska, GVEA [12]</i>	0.19497
<i>Phoenix, SRP [13]</i>	0.10257

Interest rates and inflation are variable not only for every country, but for regions within a country. As such the values selected for analysis can be somewhat arbitrary. For the purposes of this study, the mean predicted energy inflation rate from 2010-2030 in the Western states (includes OR, AZ, and AK) is used. The interest rate is a typical savings account interest rate because the homeowner would pay this cost out of pocket. This does not account for the user taking a mortgage loan to pay for the upgrade. The lifetime of the equipment will be set at 20 years which is a typical replacement rate for mechanical equipment. This data is summarized in table 2-4.

Table 2-5 Summary of cost analysis metrics

<i>Cost analysis metric</i>	<i>Metric Value</i>
<i>Project Life (years)</i>	20
<i>Interest Rate (%) [14]</i>	4
<i>Inflation Rate (%) [15]</i>	2.56

Installation cost varies based on availability of equipment and local labor prices. The mechanical designs presume that an HRV, HPWH, and MSHP will be

installed. If they are installed relatively close to each other in the floor plan the added cost of ducting would be fairly low. The only added equipment would be an added sensible heat exchanger for Cases A and B, and a second heat exchanger with some added damper controls for Case C. The major cost is the sensible heat exchanger. These typically come as part of an HRV with two electric fans which contribute substantially to the cost and are not needed in this scenario. The assumption made for this study is that an off-the-shelf HRV minus the fans could be used, and that the installation would be a part of the initial HVAC installation upon building the house. Alternatively, this could be considered an add-on feature for an HRV already on the market. Altogether with parts and labor, the added cost would come out to about \$700 with a 10% price increase for Fairbanks [16] [17]. This calculation is crude but it gives this study a reasonable starting point. The cost can be adjusted if need be as part of future work.

3. Results

The results of this study are presented in two sections: simulation data and cost analysis data. Case A performed as expected with significant savings over winter months in all climates. Case B had some surprising energy outcomes when examining the Phoenix and Fairbanks houses. They performed as near opposites with Fairbanks seeing the greatest benefit in summer, while Phoenix saw the greatest benefit in the non-summer months.

3.1 Simulation Data

This data was generated from EnergyPlus simulations with the output summary of EndUseEnergyConsumptionElectricityMonthly. This section contains total energy use summaries as well as the HVAC end use energy for Portland. The end use energy data for the Fairbanks and Phoenix houses are in Appendix B

3.1.1 Baseline Case Simulation Results

Figure 3-1 Baseline Case energy consumption for Passive House model in Portland Oregon

The total monthly energy consumption for the Baseline Case in Portland Oregon is summarized in **Figure 3-1**. Annual total consumption of electricity is 7094 kWh.

3.1.2 End Use Energy Savings for Portland Oregon

End use energy savings summaries for fans (**Figure 3-2**), cooling (**Figure 3-3**), heat recovery (**Figure 3-4**) and domestic hot water (**Figure 3-5**). It should be noted that the savings and penalties are slight for all end uses except domestic

Figure 3-2 Energy savings compared to the Baseline Case for fans in Portland Oregon

water heating for Case A, and heat recovery for Case B

Figure 3-3 Energy savings compared to the Baseline Case for cooling in Portland Oregon

Figure 3-4 Energy savings compared to the Baseline Case for heat recovery in Portland Oregon

Figure 3-5 Energy savings compared to the Baseline Case for hot water in Portland Oregon

3.1.3 Total Energy Savings for all Simulated Cities

When the total savings on energy consumption is tallied for Case A and Case B, it is clear from **Figure 3-6** that Case B is the best option for Portland.

Case A performs best overall in Fairbanks although the summer months in

Figure 3-7 show a slight benefit preference for case B. Case A has fairly uniform benefits in Phoenix throughout the year as seen in **Figure 3-8**. Case B for Phoenix demonstrates an overall penalty during summer but a benefit the rest of the year.

Figure 3-6 Total Energy savings from Baseline Case in Portland Oregon

Figure 3-7 Total energy savings compared to Baseline Case in Fairbanks Alaska

Figure 3-8 Total energy savings compared to Baseline Case in Phoenix Arizona

3.2 Cost-Benefit Data

These data were generated by summarizing the annual energy savings for Case A and Case B in each climate. Case C was generated by choosing the highest savings from month to month. A rough equipment cost was calculated with mechanical cost data and an equipment catalog. Case A and B would cost roughly the same to implement while Case C would cost about twice as much because it is effectively the implementation of both Case A and Case B. Both a simple payback and lifecycle Benefit were calculated from **Equations 1** and **2**. The lifecycle benefit accounts for inflation and interest (discount) rates for the homeowner and calculates the present worth of an investment. Case C did not show sufficient benefit in any climate to make it worthwhile from purely an investment standpoint. None of the simulated strategies yielded an investment benefit for Phoenix (**Table 3-3**). Case B showed a net positive investment value for both Portland (**Table 3-1**) and Fairbanks (**Table 3-2**). The investment value

was highest for Case B in Portland and Case A had the highest value in Fairbanks.

Table 3-1 Cost-benefit results for Portland Oregon

	PORTLAND A	PORTLAND B	PORTLAND C
ANNUAL ENERGY SAVINGS (KWH)	340.5	398.5	401.5
ANNUAL SAVINGS (\$)	35.13	68.90	69.42
INVESTMENT COST (\$)	700	700	1400
SIMPLE PAYBACK (YEARS)	19.9	17.0	33.79
LIFECYCLE BENEFIT (\$)	-81.39	24.10	-670.43

Table 3-2 Cost-Benefit results for Fairbanks Alaska

	FAIRBANKS A	FAIRBANKS B	FAIRBANKS C
ANNUAL ENERGY SAVINGS (KWH)	779.4	231.4	805.9
ANNUAL SAVINGS (\$)	151.96	45.11	157.13
INVESTMENT COST (\$)	770	770	1540
SIMPLE PAYBACK (YEARS)	5.07	17.07	9.80
LIFECYCLE BENEFIT (\$)	1905.54	24.32	1226.51

Table 3-3 Cost-Benefit data for Phoenix Arizona

	PHOENIX A	PHOENIX B	PHOENIX C
ANNUAL ENERGY SAVINGS (KWH)	212.8	219.3	297.1
ANNUAL SAVINGS (\$)	21.83	22.49	30.47
INVESTMENT COST (\$)	700	700	1400
SIMPLE PAYBACK (YEARS)	32.1	31.1	45.9
LIFECYCLE BENEFIT (\$)	-315.73	-303.94	-863.44

4. Discussion

The discussion of the results is in four parts: How heat recovery Case A and Case B performed, how these results compare to other studies, what are some of the drawbacks of how this study was performed, how could this study be done differently.

4.1 Heat Recovery Performance

The performance of a heat recovery strategy must be judged by how it created energy savings compared to the Baseline Case, and how these energy savings translated to investment value for the home owner.

4.1.1 Analysis of Energy Data

A summary for the total energy consumption of the Baseline Case model is presented in **Figure 3-1**. The total site energy consumption per square foot is 48 kWh/m² per year, and the total site heating and cooling energy is 12 kWh/m² per year. This energy consumption profile is well within the acceptable limits for a Passive House.

Alternate Cases A and B demonstrated very little change in fan energy consumption. **Figure 3-2** shows the savings in fan energy for Case A and Case B in Portland. The savings for case A and the penalty for case B are very small, on the order of a kWh for the whole year. The savings in Case A is from the reduced demand on the air side of the HPWH compressor thus resulting in less air needing to be moved. The fan penalty in Case B is slight, and comes from the HPWH compressor needing to work harder since its heat source is household air

which typically has a lower enthalpy than the HRV exhaust. In addition the MSHP fan needs to work harder to overcome the pressure drop from the added sensible heat exchanger. Similar results are observed for the simulations for Fairbanks and Phoenix (**Figures 7-1, 7-2**). The benefit in Case A for Phoenix is about 2 times larger than that for Portland. The simulation of Case A for Fairbanks shows a net penalty of roughly 6 kWh because the exhaust temperatures for the HRV were typically lower than the workshop air temperature. The results for Case B were nearly the same across all climates.

Cooling energy was not greatly affected by either alternate case. **Figure 3-3** shows the energy savings for cooling energy compared to the Baseline Case for Cases A and B in Portland. Case A has penalty of 4 kWh per year while case B has a savings of less than a kWh. The results for Phoenix show slightly larger penalty of 7 kWh per year for Case A, and the Fairbanks penalty is 2 kWh per year (**Figures 7-3, 7-4**). Case B is roughly the same for all climates.

There was a substantial change in total heat recovery energy by exchanging heat between cold HPWH exhaust energy with indoor air. **Figure 3-4** shows energy savings for heat recovery compared to the baseline for Cases A and B. Case A has no effect whatsoever on heat recovery energy while case B shows a savings of 409 kWh. This accounts for nearly all of the energy savings for case B. The results are similar for Fairbanks and Phoenix which showed a savings of 252 kWh and 229 kWh respectively (**Figures 7-5, 7-6**). The reason for the savings in Case B is not immediately apparent. It should be noted that the

greatest savings for Phoenix was in the non-summer months while the greatest savings for Fairbanks was during the summer. This indicates that the savings for Case B comes from longer operation hours for the HRV bypass mode which reduces the total HRV energy consumption by reducing the pressure drop for bringing in outdoor air. The bypass activates whenever the outdoor air temperature is cooler than the return air temperature and a building is in cooling mode. This would rarely happen in a Phoenix summer which is too hot at all times from bypass mode, and would most often happen during a Fairbanks summer.

Figure 7-9 shows the power use for the HRV for a hot summer day for Case B and the Baseline. The only time when both cases operate in the same fashion is during the hottest part of the day when bypass mode cannot be active. The specific effects surrounding the heat recovery savings may merit further study.

Energy consumption for domestic hot water was significantly changed by capturing waste heat from household exhaust air. **Figure 3-5** demonstrates substantial savings of 342 kWh per year in Portland by employing case A. Case B shows a small penalty of 10 kWh per year. Fairbanks has a savings of 781 kWh per year for case A, and the Phoenix house saves 219 kWh per year. The positive effect of feeding heat to the HPWH compressor intake is clear. It makes intuitive sense that adding heat to the reservoir that the HPWH draws from would improve its efficiency and therefore its energy consumption. It also makes sense that the greatest improvement by employing case A is for colder climates where the conditions would penalize a standalone HPWH even more than a hot climate.

The penalty for coupling the cold exhaust to the household air is not as obvious. Note that the net energy penalty for water heating under Case B is the same in Phoenix as it is in Portland (**Figure 7-7**), while the penalty is 20 kWh in Fairbanks (**Figure 7-8**). It is likely it is not as useful to the efficiency of the HPWH to have a warmer cold reservoir to dump heat to as opposed to having a warmer hot reservoir. It would merit further study to examine the effects on efficiency of connecting the cold air exhaust of HPWH to different temperature reservoirs.

The overall energy consumption data for each case in each climate shows that there may be some benefit to switching between recovering heat for hot water from house exhaust, or using the HPWH cold air to improve heat recovery in the house (see **Figures 3-6, 3-7, 3-8**). It should be noted that in Portland, improving household heat recovery has the greatest benefit regardless of the month. Phoenix and Fairbanks do best for most of the year under Cases B and A respectively, while seeing a changeover in best monthly benefit during the summer. There is no question that employing a Case C would bring an Energy benefit to the Fairbanks and Phoenix houses, only a long term cost analysis will tell whether or not it is a good investment for the homeowner.

4.1.2 Analysis of Cost Data

Tables 3-1, 3-2 and 3-3 provide summaries of the costs and benefits of employing each heat recovery strategy. The first thing one should note is that none of these strategies would be worthwhile in the Phoenix House. This is

because the Energy savings are too low, and the cost of electric energy in Phoenix is inexpensive at \$0.10/kWh. This ends up making the payback period 10 years greater than the lifetime of the equipment, and the lifetime benefits are negative. The Portland house would payback at 20 years for case A, and 10 for Case B with a lifetime penalty of \$81 and benefit of \$24 respectively. Fairbanks shows the most promise with a payback of 5 years for Case A and a lifetime benefit of \$1906.

Case C is problematic. Although the energy savings for Case C are the highest in the Fairbanks house, the lifetime benefit is less at \$1227 because of the added equipment cost. If energy savings were the only goal then it would be worthwhile. If a design were on the brink of meeting a strict certification like the Passive House standard then it could be employed. From strictly a cost standpoint it makes sense to choose either Case A or Case B depending on the climate, and local energy costs.

4.2 Comparison to other studies

A study at Oakridge National Laboratory by Thomlinson et al showed the energy saving potential from a combined HPWH and indoor heat pump system [18]. Excess hot water was used to heat indoor air. A compression cycle used the cold output from the HPWH to cool the indoor air. Although this system showed a high theoretical efficiency of 19.6 SEER for heating, cooling, and hot water; the

prototype has not yet been developed. This study does indicate that “soft integration” of heat pump water heaters with waste heat producers like refrigerators and dryers is a well-established practice with proven results. This “soft integrated” approach is done by placing the HPWH in the proximity of the waste heat producer. This differs significantly from the approach taken in this study which aimed to directly interface the HPWH with existing heat sources and sinks. In addition this study focused on evaluating a Passive House model instead of a typical residence.

Exhaust air heat recovery in Buildings by Fehrm et al investigates the energy savings for a variety of cases in Sweden that employ an exhaust air heat pump system to reuse waste heat [19]. The overall device designs were similar to the configuration studied by Tomlinson et al in they used a series of vapor compression cycles to transfer the heat. The study shows savings of up to 31% in some cases. It is clearly stated that these systems are made financially viable by a combination of regulations on residential energy use and government subsidies.

4.3 Potential Drawbacks

Although using household exhaust and indoor air streams shows promise in improving overall efficiency for a house; there is a significant barrier of 10%-20% added construction costs for a Passive House. Although the savings in the

energy models for this study were clearly present, those energy savings would not be possible without added investment. The success of the cost analysis is strongly dependent on the price of electricity as well as the initial added cost of installation. Such a heat recovery system is not on the market and this makes the equipment cost challenging to estimate. It would require substantial analysis from an experienced mechanical designer and contractor to determine the actual initial cost of installation. The novelty alone would make this task more expensive than the costs estimated in previous sections.

4.4 What could be done differently?

To get a greater benefit out of Case A or B, a digital control system could be employed. Although this would add significant installation cost, there is potential to increase savings. A “smart” digital control would maximize the benefit on a short term basis and reduce losses by only employing heat recovery when it is needed. The Trekhaus only has a digital control for the MSHP which controls heating and cooling. It would likely see a savings if there were a digital controller for the HRV that changed flow rates based on occupancy and infiltration through open windows and doors. The HRV is instead controlled by the building occupants. The reason that this has not been done is that the savings by having such a control does not outweigh the cost for that particular DDC application.

It may be worthwhile to combine Case A or B with an outdoor air loop to

provide the option of exchanging air with the outside. This would require some additional added controls, but an additional heat source/sink could add some additional efficiency to domestic hot water heating or heat recovery.

In addition, a clear benefit of employing these heat recovery systems only seems to manifest in a mild climate for Case B, or a cold climate for Case A.

There are a fairly large number of certified Passive Houses in Oregon and Illinois so there may be hope for these heat recovery strategies being employed in the US especially if the climate is mostly heating dominated. There is an even greater possibility for this being effective in northern Europe or Scandinavia where Passive houses are common and Energy prices can be up to three times higher for residential consumers [20].

5. Conclusion

This study evaluates the effects of using exhaust heat recovery to improve HPWH efficiency, and cold HPWH exhaust recovery to improve household HVAC efficiency. The end result was that exhaust air heat recovery design improvement paid back in 5 years in Fairbanks Alaska and 12 years in Portland Oregon while it would not pay back in Phoenix Arizona. Using cold air heat recovery paid back in 10 years in Portland, 15 years in Fairbanks, and would not pay back in Phoenix. These results would vary with different cost data.

The Passive House standard requires innovation to achieve its challenging energy consumption goal of 120 kWh/m² per year. As such, finding cost effective improvements beyond the typical energy saving HVAC and appliances is difficult. Even what appears to be a substantial savings of \$60 per year will not mean much to the consumer if they have to make an unsubsidized investment at a net penalty over the life of the installed equipment. In addition, the savings will not be the same for all houses and locations. In this study, it was observed that a Passive House in Fairbanks Alaska would save a substantial amount of money with a heat recovery improvement while the same house in Portland received a mediocre benefit. This was due to a combination of slightly different energy prices and substantially different climates for the same improvement. Ultimately, no one solution will always be the answer.

Some of the results need further examination: such as the specific benefit

to heat recovery when using cold air exhaust, and the associated water heating penalty. It would also be worthwhile to see how an outdoor air loop and a digital controller would affect these heat recovery strategies. Further investigation into sensible waste heat recovery strategies shows great promise for improving efficiency in Passive Houses and other high performance buildings.

References

- [1] U.S. Department of Energy Office of Energy Efficiency and Renewable Energy, United States, "Buildings energy data book," 2011. [Online]. Available: <http://www.btscoredatabook.net>.
- [2] Energy Star, "Energy strategies for buildings&plants," [Online]. Available: <http://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager/understand-metrics/difference>. [Accessed 2014].
- [3] Passive House Institute US, What is a Passive House?, 2011.
- [4] D.J. Sailor, J. Lauck, "Evaluation of Phase Change Materials for Improving thermal comfort in a Super-Insulated Residential Building," *Energy and Buildings*, no. 79, pp. 32-40, 2014.
- [5] D.J. Sailor, J. Lauck, S. Rodriguez, "In Situ Evaluation of vanguard technologies for high performance residential buildings," in *ASME 2013 Summer Heat Transfer Conference*, Minneapolis, 2013.
- [6] B. Sparn, K. Hudson, and D. Christenson, "Laboratory Performance Evaluation of Residential Integrated Heat Pump Water Heaters," NREL, Golden, 2011.
- [7] American Society of Heating, Refrigerating and Air-Conditioning Engineers, 2009 ASHRAE Handbook: Fundamentals, Atlanta, GA: ASHRAE, 2009.
- [8] Earnesto Orlando Laurence Berkly National Laboratories University of Illinois, "Getting Started with Energy Plus," U.S. Department of Energy, 2013.
- [9] J. Lauck, *PCM in Super-Insulated Buildings*, Portland: Portland State University, 2013.
- [10] A. Rushing, J. Kneifel, B. Lippiatt "Energy Price Indices and Discount Factors For Life-Cycle Cost Analysis," in *NIST Handbook 135*, US NIST, 2010.
- [11] Portland General Electric Company, *Schedule 7 Residential Service*, Portland: Portland General Electric Company, 2012.
- [12] Golden Valley Electric Association, "Rates," Golden Valley Electric Association, 02 03 2014. [Online]. Available: <http://www.gvea.com/rates/rates>.
- [13] SRP, "Frequently asked questions about the basic plan," SRP, 2014. [Online]. Available: <http://www.srpnet.com/prices/home/basicfaq.aspx#1>.
- [14] BECU, "Cecking and Savings," 2014 05 2014. [Online]. Available:

<http://www.becu.org/personal/checking-savings.aspx>.

[15] Standard & Poors, "US Inflation Rate By Year," 1 04 2014.

[Online]. Available: <http://www.multpl.com/inflation/table>.

[16] P. R. Waier, "Heating Ventilation and AC," in *RSMMeans Building Construction Cost Data*, 2012, pp. 496-531.

[17] Grainger, "Heat & Energy Recovery Ventilators," [Online]. Available: <http://www.grainger.com/category/heat-energy-recovery-ventilators/central-equipment/hvac-and-refrigeration/ecatalog/N-jq4>.

[18] J.J. Tomlinson, C.K. Rice, E. Baskin, "Integrated Heat Pumps For Combined Space Conditioning and Water Heating," in *8th IEA Heat Pump Conference*, Tokyo, 2005.

[19] Mats Fehrm, Wilhelm Reiners, Matthias Ungemach, "Exhaust air heat recovery in buildings," *International Journal of refrigeration*, no. 25, pp. 439-449, 2002.

[20] European Commission, "Energy Prices and Costs in Europe," Brussels, 2014.

6. Appendix A - EnergyPlus

The following figures are Base Case HVAC equipment objects in EnergyPlus that are the most critical to replicating the energy model for the Baseline Case. These include the packaged terminal heat pump, heat recovery ventilator, heat recovery ventilator controller, Package terminal heat pump heating and cooling coils, fans, heat pump water heater, heat pump water heater coil, heat recovery ventilator sensible heat exchanger, equipment connection list, and node list.

[0002] Thermostat:BoilerOutdoorAirSetpoint [0001] ZoneHVAC:PackagedTerminalHeatPump [0001] ZoneHVAC:EnergyRecoveryVentilator			pump), supplemental heating coil (gas, electric, heat recovery), fixed-position outdoor air mixer.		
Field	Units	Obj1			
Availability Schedule Name		Always On Discrete 1			
Air Inlet Node Name		PTHP Indoor Air Intake			
Air Outlet Node Name		PTHP Conditioned Air Outlet			
Outdoor Air Mixer Object Type		OutdoorAir:Mixer			
Outdoor Air Mixer Name		PTHP OA Mixer			
Supply Air Flow Rate During Cooling Operation	m3/s	0.165			
Supply Air Flow Rate During Heating Operation	m3/s	0.165			
Supply Air Flow Rate When No Cooling or Heating is Needed	m3/s	0.165			
Outdoor Air Flow Rate During Cooling Operation	m3/s	0			
Outdoor Air Flow Rate During Heating Operation	m3/s	0			
Outdoor Air Flow Rate When No Cooling or Heating is Needed	m3/s	0			
Supply Air Fan Object Type		Fan:OnOff			
Supply Air Fan Name		PTHP supply Fan			
Heating Coil Object Type		Coil:Heating:DX:SingleSpeed			
Heating Coil Name		HP Heating Coil			
Heating Convergence Tolerance	dimensionless	0.001			
Minimum Outdoor Dry-Bulb Temperature for Compressor	C	-8			
Cooling Coil Object Type		Coil:Cooling:DX:SingleSpeed			
Cooling Coil Name		HP Cooling Coil			
Cooling Convergence Tolerance	dimensionless	0.001			
Supplemental Heating Coil Object Type		Coil:Heating:Electric			
Supplemental Heating Coil Name		OS:Coil:Heating:Electric 5			
Maximum Supply Air Temperature from Supplemental Heating Coil	C	autosize			
Maximum Outdoor Dry-Bulb Temperature for Supplemental Heating Coil	C	21			
Fan Placement		DrawThrough			
Supply Air Fan Operating Mode Schedule Name					

Figure 6-1 EnergyPlus object ZoneHVAC:PackagedTerminal Heatpump

[0001] ZoneHVAC:EnergyRecoveryVentilator:Controller		Field Description: ID: A1
[0001] AirTerminal:SingleDuct:Uncontrolled		
Field	Units	Obj1
Name		ERV Economizer
Temperature High Limit	C	0
Temperature Low Limit	C	
Enthalpy High Limit	J/kg	
Dewpoint Temperature Limit	C	
Electronic Enthalpy Limit Curve Name		
Exhaust Air Temperature Limit		ExhaustAirTemperatureLimit
Exhaust Air Enthalpy Limit		NoExhaustAirEnthalpyLimit
Time of Day Economizer Flow Control Schedule Name		
High Humidity Control Flag		No
Humidistat Control Zone Name		
High Humidity Outdoor Air Flow Ratio		1
Control High Indoor Humidity Based on Outdoor Humidit		No

Figure 6-5 EnergyPlus object ZoneHVACEnergyRecoveryVentilator

[0004] Fan:OnOff		or other control signals. This fan can also operate continuously like Fan:ConstantVolume.			
[0001] Coil:Cooling:DX:SingleSpeed		Field Description:			
[0001] Coil:Heating:Electric					
Field	Units	Obj1	Obj2	Obj3	Obj4
Name		HRV Supply Fan	HRV Exhaust Fan	HPwHFan West	PTHP supply Fan
Availability Schedule Name		Always On	Always On	Always On	Always On
Fan Total Efficiency		0.75	0.75	0.7	0.7
Pressure Rise	Pa	100	100	100	250
Maximum Flow Rate	m3/s	0.048611111	0.048611111	0.2685	0.165
Motor Efficiency		0.9	0.9	0.9	0.9
Motor In Airstream Fraction				1	1
Air Inlet Node Name		HRV OA Mixed Air Node	HRV Exhaust Fan inlet Node	West Workspace Outlet	OS.ZoneHVAC:PackagedTerminalHeatP
Air Outlet Node Name		HRV Supply Fan Outlet	HRV Exhaust Outlet	HPwHDX:CoilAirInlet	OS.ZoneHVAC:PackagedTerminalHeatP
Fan Power Ratio Function of Speed Ratio Curve Name					
Fan Efficiency Ratio Function of Speed Ratio Curve Name					
End-Use Subcategory		HRV Fan Power	HRV Fan Power	Water Heating	PTHP Cooling

Figure 6-6 EnergyPlus objects Fan:OnOff

Field	Units	Obj1
Name		HP Cooling Coil
Availability Schedule Name		Always On Discrete 1
Gross Rated Total Cooling Capacity	W	2800
Gross Rated Sensible Heat Ratio		0.75
Gross Rated Cooling COP	W/W	3.4
Rated Air Flow Rate	m3/s	0.15
Rated Evaporator Fan Power Per Volume Flow Rate	W/(m3/s)	
Air Inlet Node Name		PTHP OA Mixed Air Node
Air Outlet Node Name		OS:ZoneHVAC:PackagedTerminalHeatP
Total Cooling Capacity Function of Temperature Curve I		HPACCoolCapFT
Total Cooling Capacity Function of Flow Fraction Curve		HPACCoolCapFFF
Energy Input Ratio Function of Temperature Curve Nar		HPACCOOLEIRFT
Energy Input Ratio Function of Flow Fraction Curve Nar		HPACCOOLEIRFFF
Part Load Fraction Correlation Curve Name		HPACCOOLPLFFPLR
Nominal Time for Condensate Removal to Begin	s	
Ratio of Initial Moisture Evaporation Rate and Steady S	dimensionless	
Maximum Cycling Rate	cycles/hr	
Latent Capacity Time Constant	s	
Condenser Air Inlet Node Name		
Condenser Type		EvaporativelyCooled
Evaporative Condenser Effectiveness	dimensionless	

Figure 6-7 EnergyPlus object CoolingCoil:DX:SingleSpeed

Field	Units	Obj1
Name		HP Heating Coil
Availability Schedule Name		Always On Discrete 1
Gross Rated Heating Capacity	W	3192
Gross Rated Heating COP	W/W	2.81
Rated Air Flow Rate	m3/s	0.1652
Rated Supply Fan Power Per Volume Flow Rate	W/(m3/s)	
Air Inlet Node Name		OS:ZoneHVAC:PackagedTerminalHeatP
Air Outlet Node Name		OS:ZoneHVAC:PackagedTerminalHeatP
Heating Capacity Function of Temperature Curve Name		HPACHeatCapFT
Heating Capacity Function of Flow Fraction Curve Name		HPACCoolCapFFF
Energy Input Ratio Function of Temperature Curve Nar		HPACHeatEIRFT
Energy Input Ratio Function of Flow Fraction Curve Nar		HPACCOOLEIRFFF
Part Load Fraction Correlation Curve Name		HPACCOOLPLFFPLR
Defrost Energy Input Ratio Function of Temperature Cu		HPACCoolCapFT
Minimum Outdoor Dry-Bulb Temperature for Compressor	C	-8
Outdoor Dry-Bulb Temperature to Turn On Compressor	C	
Maximum Outdoor Dry-Bulb Temperature for Defrost Op	C	5
Crankcase Heater Capacity	W	
Maximum Outdoor Dry-Bulb Temperature for Crankcase	C	10
Defrost Strategy		ReverseCycle
Defrost Control		Timed

Figure 6-8 HeatingCoil:DX:SingleSpeed

Field	Units	Obj1
Name		HPWHDXCoil
Rated Heating Capacity	W	2750
Rated COP	W/W	3
Rated Sensible Heat Ratio		0.6956
Rated Evaporator Inlet Air Dry-Bulb Temperature	C	29.44
Rated Evaporator Inlet Air Wet-Bulb Temperature	C	22.22
Rated Condenser Inlet Water Temperature	C	55.72
Rated Evaporator Air Flow Rate	m3/s	autocalculate
Rated Condenser Water Flow Rate	m3/s	autocalculate
Evaporator Fan Power Included in Rated COP		Yes
Condenser Pump Power Included in Rated COP		Yes
Condenser Pump Heat Included in Rated Heating Capacity		No
Condenser Water Pump Power	W	150
Fraction of Condenser Pump Heat to Water		0.1
Evaporator Air Inlet Node Name		HPWHDXCoilAirInlet
Evaporator Air Outlet Node Name		West Workspace Inlet
Condenser Water Inlet Node Name		HPWHWaterInletNode West
Condenser Water Outlet Node Name		HPWHWaterOutletNode West
Crankcase Heater Capacity	W	100
Maximum Ambient Temperature for Crankcase Heater	C	5
Evaporator Air Temperature Type for Curve Objects		WetBulbTemperature

Figure 6-9 EnergyPlus Object Coil:WaterHeating:AirToWaterHeatPump

Field	Units	Obj1
Name		HeatPumpWaterHeater West
Availability Schedule Name		Always On
Compressor Setpoint Temperature Schedule Name		HPWHTempSch
Dead Band Temperature Difference	deltaC	2
Condenser Water Inlet Node Name		HPWHWaterInletNode West
Condenser Water Outlet Node Name		HPWHWaterOutletNode West
Condenser Water Flow Rate	m3/s	autocalculate
Evaporator Air Flow Rate	m3/s	autocalculate
Inlet Air Configuration		ZoneAirOnly
Air Inlet Node Name		West Workspace Outlet
Air Outlet Node Name		West Workspace Inlet
Outdoor Air Node Name		
Exhaust Air Node Name		
Inlet Air Temperature Schedule Name		
Inlet Air Humidity Schedule Name		
Inlet Air Zone Name		Thermal Zone 2
Tank Object Type		WaterHeater:Mixed
Tank Name		HPWHTank West
Tank Use Side Inlet Node Name		
Tank Use Side Outlet Node Name		
DX Coil Object Type		Coil:WaterHeating:AirToWaterHeatPump
DX Coil Name		HPWHDXCoil
Minimum Inlet Air Temperature for Compressor Operation	C	5
Compressor Location		Zone
Compressor Ambient Temperature Schedule Name		
Fan Object Type		Fan:OnOff

Figure 6-10 EnergyPlus Object WaterHeater:HeatPump

Field	Units	Obj1
Name		HRV HX
Availability Schedule Name		Always On Discrete 28
Nominal Supply Air Flow Rate	m3/s	0.046
Sensible Effectiveness at 100% Heating Air Flow	dimensionless	0.84
Latent Effectiveness at 100% Heating Air Flow	dimensionless	0.7
Sensible Effectiveness at 75% Heating Air Flow	dimensionless	0.9
Latent Effectiveness at 75% Heating Air Flow	dimensionless	0.75
Sensible Effectiveness at 100% Cooling Air Flow	dimensionless	0.84
Latent Effectiveness at 100% Cooling Air Flow	dimensionless	0.7
Sensible Effectiveness at 75% Cooling Air Flow	dimensionless	0.9
Latent Effectiveness at 75% Cooling Air Flow	dimensionless	0.75
Supply Air Inlet Node Name		HRV OA Inlet
Supply Air Outlet Node Name		HRV OA Mixer Inlet
Exhaust Air Inlet Node Name		HRV Relief Air Outlet Node
Exhaust Air Outlet Node Name		HRV Exhaust Fan inlet Node
Nominal Electric Power	W	50
Supply Air Outlet Temperature Control		No
Heat Exchanger Type		Plate
Frost Control Type		ExhaustOnly
Threshold Temperature	C	1.7
Initial Defrost Time Fraction	dimensionless	0.083
Rate of Defrost Time Fraction Increase	1/K	0.012
Economizer Lockout		Yes

Figure 6-11 EnergyPlus Object HeatExchanger:AirToAir:SensibleAndLatent

Case A is identical to the Baseline Case with the exception of one added HeatExchanger:AirToAir:SensibleAndLatent object which connects to the heat recovery ventilator exhaust stream

Field	Units	Obj1	Obj2
Name		HRV HX	HRV Hot HPWH HX
Availability Schedule Name		Always On	Always On
Nominal Supply Air Flow Rate	m3/s	0.046	0.2685
Sensible Effectiveness at 100% Heating Air Flow	dimensionless	0.84	0.84
Latent Effectiveness at 100% Heating Air Flow	dimensionless	0.7	0.7
Sensible Effectiveness at 75% Heating Air Flow	dimensionless	0.9	0.9
Latent Effectiveness at 75% Heating Air Flow	dimensionless	0.75	0.75
Sensible Effectiveness at 100% Cooling Air Flow	dimensionless	0.84	0.84
Latent Effectiveness at 100% Cooling Air Flow	dimensionless	0.7	0.7
Sensible Effectiveness at 75% Cooling Air Flow	dimensionless	0.9	0.9
Latent Effectiveness at 75% Cooling Air Flow	dimensionless	0.75	0.75
Supply Air Inlet Node Name		HRV OA Inlet	West Workspace Inlet
Supply Air Outlet Node Name		HRV OA Mixer Inlet	West Workspace Outlet
Exhaust Air Inlet Node Name		HRV Relief Air Outlet Node	HRV Exhaust Outlet
Exhaust Air Outlet Node Name		HRV Exhaust Fan inlet Node	Final Exhaust Port
Nominal Electric Power	W	50	50
Supply Air Outlet Temperature Control		No	No
Heat Exchanger Type		Plate	Plate
Frost Control Type		ExhaustOnly	ExhaustOnly
Threshold Temperature	C	1.7	1.7
Initial Defrost Time Fraction	dimensionless	0.083	0.083

Figure 6-12 EnergyPlus objects HeatExchanger:AirToAir:SensibleAndLatent for Case A

Case B is also identical to the Baseline with the exception of an added heat exchanger object that connects to the heat pump flow stream and one additional node added to the NodeList objects which facilitates the connection to the room air

Field	Units	Obj1	Obj2
Name		HRV HX	HPWH Cool HRV HX
Availability Schedule Name		Always On	Always On
Nominal Supply Air Flow Rate	m3/s	0.046	0.046
Sensible Effectiveness at 100% Heating Air Flow	dimensionless	0.84	0.84
Latent Effectiveness at 100% Heating Air Flow	dimensionless	0.7	0.7
Sensible Effectiveness at 75% Heating Air Flow	dimensionless	0.9	0.9
Latent Effectiveness at 75% Heating Air Flow	dimensionless	0.75	0.75
Sensible Effectiveness at 100% Cooling Air Flow	dimensionless	0.84	0.84
Latent Effectiveness at 100% Cooling Air Flow	dimensionless	0.7	0.7
Sensible Effectiveness at 75% Cooling Air Flow	dimensionless	0.9	0.9
Latent Effectiveness at 75% Cooling Air Flow	dimensionless	0.75	0.75
Supply Air Inlet Node Name		HRV OA Inlet	HPWH HX inlet
Supply Air Outlet Node Name		HRV OA Mixer Inlet	PTHP Indoor Air Intake
Exhaust Air Inlet Node Name		HRV Relief Air Outlet Node	West Workspace Inlet
Exhaust Air Outlet Node Name		HRV Exhaust Fan inlet Node	West Workspace Outlet
Nominal Electric Power	W	50	50
Supply Air Outlet Temperature Control		No	No
Heat Exchanger Type		Plate	Plate
Frost Control Type		ExhaustOnly	ExhaustOnly
Threshold Temperature	C	1.7	1.7
Initial Defrost Time Fraction	dimensionless	0.083	0.083

Figure 6-13 EnergyPlus objects HeatExchanger:AirToAir:SensibleAndLatent for Case B

Field	Units	Obj1	Obj2
Name		Port List 1	Port List 2
Node 1 Name		PTHP Conditioned Air Outlet	PTHP Indoor Air Intake
Node 2 Name		HRV Supply Fan Outlet	HRV Relief Air Outlet Node
Node 3 Name			HPWH HX inlet
Node 4 Name			

Figure 6-14 EnergyPlus objects NodeList for Case B

7. Appendix B - Additional Data Figures

Figures 7-1 and 7-2 show the fan energy savings for Implementing Case A and Case B in Fairbanks and Phoenix respectively. In both climates a very small benefit or penalty is seen for Case A. A larger difference is seen for Case A.

Figure 7-1 Fan Energy savings from Baseline Case for Fairbanks Alaska

Figure 7-2 Fan Energy savings from Baseline Case for Phoenix Arizona

Cooling energy savings from implementing Case A and Case B in Phoenix and Fairbanks are shown in Figures 7-3 and 7-4 respectively. A negligible savings is seen in case B for both climates, while Case A shows a visible but small penalty.

Figure 7-3 Cooling energy savings for Phoenix Arizona

Figure 7-4 Cooling energy savings for Fairbanks Alaska

There is a substantial heat recovery savings for Case B, while Case A shows no benefit or penalty for heat recovery. Figure 7-5 shows that the Phoenix house only benefits on the non summer months. Figure 7-6 shows that the greatest benefit to the Fairbanks house is during the summer months. Case B causes a small penalty in domestic hot water energy for both Phoenix (Figure 7-7) and Fairbanks (Figure 7-8). Case A shows a substantial benefit to domestic hot water energy for both Phoenix and Fairbanks.

Figure 7-5 Heat recovery energy savings for Phoenix Arizona

Figure 7-6 Heat recovery energy savings for Fairbanks Alaska

Figure 7-7 Domestic hot water energy savings for Phoenix Arizona

Figure 7-8 Domestic hot water energy savings for Fairbanks Alaska

In **Figure 7-9** Case B shows savings compared to the baseline case during all but the hottest times of day in Portland which indicates that bypass node is active.

Figure 7-9 HRV power consumption during a hot day in Portland

8. Appendix C - Contents of Supplemental Data Files

Simulation code can be run by opening and executing the input design files in EnergyPlus version 8.1. IDF and EPW are both file types unique to Energy Plus. IDF's contain the inputs for building simulation while EPW's contain a weather file. The IDF must be used concurrently with an EPW for simulations.

Folder Name: EnergyPlus IDFs

File Name	File Type	File Size (KB)	Software	Special hardware requirements
Passive house simple	IDF	218	Energy Plus 8.1	None
Passive house simple B	IDF	220	Energy Plus 8.1	None
Passive house simple A	IDF	220	Energy Plus 8.1	None
USA_AK_Emmonak.702084_TMY3	EPW	1586	Energy Plus 8.1	None
USA_AZ_Phoenix-Sky.Harbor.Intl.AP.722780_TMY3	EPW	1605	Energy Plus 8.1	None
USA_OR_Portland.Intl.AP.726980_TMY3	EPW	1605	Energy Plus 8.1	None