

1978

A technique to calculate complex electromagnetic fields by using the finite element method

Davood Asgharian
Portland State University

Follow this and additional works at: https://pdxscholar.library.pdx.edu/open_access_etds



Part of the [Computer Sciences Commons](#)

Let us know how access to this document benefits you.

Recommended Citation

Asgharian, Davood, "A technique to calculate complex electromagnetic fields by using the finite element method" (1978). *Dissertations and Theses*. Paper 2863.

<https://doi.org/10.15760/etd.2859>

This Thesis is brought to you for free and open access. It has been accepted for inclusion in Dissertations and Theses by an authorized administrator of PDXScholar. Please contact us if we can make this document more accessible: pdxscholar@pdx.edu.


AN ABSTRACT OF THE THESIS OF Davood Asgharian for the Master of Science
in Applied Science presented May 16, 1978.


Title: A Technique to Calculate Complex Electromagnetic Fields by
Using the Finite Element Method.

APPROVED BY MEMBERS OF THE THESIS COMMITTEE:


Vijay K. Garg


Franz N. Rad


Ralph D. Greiling


James L. Hein

A computer program based on Maxwell's equations is developed to calculate two-dimensional complex potentials by the Finite Element Method. This study offers a solution to a complex continuum problem by allowing a subdivision into a series of simple interrelated problems. The region of interest is divided into triangular elements. For each node in the grid, the Finite Element Method is used to set up an equation for the potential as a function of those of the surrounding nodes. All these equations are solved by the Gaussian Elimination Method. For increased accuracy this method requires a high degree of division of the region of interest. This could cause a storage problem on the computer. To alleviate this problem a half-banded scheme is used. A comparison is

provided between the data obtained from the developed algorithm and an actual experiment. In this experiment two-types of sunken swimming pools, reinforced and non-reinforced, were used to hold three different waters of conductivities $29\mu\sigma/\text{cm}$, $1500\mu\sigma/\text{cm}$ and $3000\mu\sigma/\text{cm}$. In order to test the accuracy of the computer program developed, the results of another solved problem are also compared to another computer program's results which was based on capacitive and resistive distribution of potentials. The result of this study shows the hazard may exist on the edges of the swimming pool when the resistivity of the surrounding soil is high.

A TECHNIQUE TO CALCULATE COMPLEX ELECTROMAGNETIC
FIELDS BY USING THE FINITE ELEMENT METHOD

by

DAVOOD ASGHARIAN

A thesis submitted in partial fulfillment of the
requirements for the degree of

MASTER OF SCIENCE
in
APPLIED SCIENCE


Portland State University

1978


TO THE OFFICE OF GRADUATE STUDIES AND RESEARCH:

The members of the Committee approve the thesis of Davood
Asgharian presented May 16, 1978.



Vijay K. Garg



Franz N. Rad


Ralph D. Greiling


James L. Hein

APPROVED:


Fred M. Young, Department Head
Engineering and Applied Science


Stanley E. Rauch, Dean
Graduate Studies and Research

DEDICATED
TO MY
LOVING
WIFE

ACKNOWLEDGMENTS

The author gratefully acknowledges indebtedness to Dr. V. J. Garg for his suggestion of the problem, criticisms, and suggestions during the course of this study and his sacrifice of time and energy during the writing of this thesis.

The author wishes to express his gratitude to Dr. F. Rad for his advice and reviewing this thesis. I would also like to express my appreciation to Professor R. Greiling for making many constructive comments.

Consultation with Dr. W. Mueller was also a great aid in the writing of the computer portion of this study.

The author wishes to thank Ms. Donna Mikulic for the excellent and efficient typing of this thesis.

I am especially indebted to my dear wife for her encouragement, understanding and unfailing patience.

TABLE OF CONTENTS

	Page
ACKNOWLEDGMENTS	iv
LIST OF TABLES	vii
LIST OF FIGURES	viii
CHAPTER	
I INTRODUCTION	1
1.1 REVIEW OF LITERATURE	1
1.2 STATEMENT OF THE PROBLEM	3
II FINITE ELEMENT METHOD	4
2.1 DEFINITION	4
2.2 FORMULATION OF FINITE ELEMENT METHOD	4
2.3 FORMULATION OF POTENTIAL PROBLEMS WITH SPATIAL FINITE ELEMENT SUBDIVISIONS	8
2.4 FINITE ELEMENT SOLUTION OF COMPLEX POTENTIAL ELECTRIC FIELDS	10
III COMPUTER PROGRAM	18
3.1 SOLUTION TECHNIQUE FOR THE FINITE ELEMENT METHOD	18
3.2 RESULTS OF THE COMPUTER SOLUTION	29
3.3 COMPARISON OF RESULTS WITH OTHER COMPUTER TECHNIQUE	35
IV EXPERIMENTAL PROGRAM	38
V RESULTS	42
5.1 COMPARISON OF CALCULATED VALUES WITH EXPERI- MENTAL RESULTS	42
5.2 POTENTIAL HAZARD TO THE HUMAN BODY	52
5.3 THE LIMITATIONS AND ACCURACY OF THE THEORETICAL TECHNIQUE	59
VI CONCLUSION	60
BIBLIOGRAPHY	61

	Page
APPENDIX A EULER'S THEOREM OF VARIATIONAL CALCULUS	63
APPENDIX B THE GAUSSIAN METHOD	66
APPENDIX C CALCULATION OF CURRENT DENSITY	72
APPENDIX D LISTING OF PROGRAMS AND SUBROUTINES	76
APPENDIX E COMPUTER RESULTS	87
APPENDIX F EXPERIMENTAL RESULTS	100

LIST OF TABLES

Table		Page
3.1	Comparison of Results of a Specific Problem	37
5.1 - 5.4	Calculated Current Travelling Through the Human Body Standing on the Soil	54- 57
5.5	Calculated Current Travelling Through the Human Body Inside the Swimming Pool	58
C.1 - C.3	Calculated Current Densities on the Surface of the Earth	73- 75
E.1 - E.9	Current Densities Calculated in Soil	88- 96
E.10 - E.12	Current Densities Calculated in Water	97- 99
F.1 - F.9	Current Densities Measured in Soil	101-109
F.10 - F.12	Current Densities Measured in Water	110

LIST OF FIGURES

Figure		Page
2.1	Triangular Division of the Area	5
2.2	One Triangle	6
2.3	Typical Triangle with Vertices Marked	11
2.4	Area Coordinates	11
3.1	Region 's' is Divided in 18 Triangular Elements	19
3.2	Banded Form of a Symmetrical Matrix	22
3.3	Flow Chart, Subroutine "BANDWIDTH"	24
3.4	Flow Chart, Subroutine "FIND"	25
3.5	The Finite Element Model	31
3.6	Regional Division of the Experimental Model	32
3.7	Flow Chart, Subroutine "GOOD"	33
3.8	Flow Chart, Program "TES"	34
3.9	Resistive and Complex Admittance Networks	35
3.10	Two Materials in Series	36
4.1	Schematic Diagram of the Experimental Model	40
4.2	Schematic Diagram of the Electrical Circuit	41
5.1-5.8	Calculated Current Densities	44-51
5.9	Levels of Current Hazards to the Human Body	53
B	Flow Chart, Subroutine "SOLVE"	70

CHAPTER I

INTRODUCTION

1.1 REVIEW OF LITERATURE

A considerable amount of work has been done in the past in calculating the self and mutual impedance of two parallel ground return wires. The following paragraphs summarize these attempts in chronological order.

The first attempt was made by Carson (1). He investigated the problem of wave propagation along a transmission system composed of an overhead wire parallel to the surface of the earth. However a complete solution of determining the actual impedance is impossible because of the non-homogeneity of the earth. The solution to the problem, where the actual earth is replaced by a plane homogeneous semi-infinite solid has promoted considerable theoretical and practical interest.

In 1951, Lacey and Wasley (2) at the Hydro-Electro Power Commission of Ontario, Canada, developed an equation for the mutual impedance of two finite length earth-return circuits, either parallel or at an angle. The equation developed by them is to be a generalization of Carson's work.

In 1965, Wedepohl (3) published a paper on wave propagation in multiconductor overhead lines which would permit the earth-return path to have a relative permeability other than unity, which was not permissi-

ble in the analysis by Carson. In this paper, the new approach is applied to the case of a two-layer earth, including the effects of displacement currents. The results were in agreement with those obtained for the case of a homogeneous earth.

In 1966, Krakowski (4) developed equations for the mutual impedances of overhead lines with the earth as a return path. In this paper the problem deals with two different lines which cross each other at an angle, α , different from zero. A particular case of this problem is the same as Carson's solution for $\alpha = 0$. The general solution of this problem is considered, assuming that the earth is uniformly conducting and that both overhead conductors are parallel to the surface of the earth.

In 1973, Nakagawa (5) published a paper in this area. This solution permits the earth-return path to be considered as three layers of different resistivities, permitivities and permeabilities. A stratified earth causes marked differences in the earth impedances and the resultant wave deformations from the homogeneous case. The depth of a layer is a significant factor to the value of the stratified-earth impedance. The displacement currents can influence earth-return impedances. This is only at very high frequencies and under the conditions of high earth resistivity and low conductor height.

All these papers prove that there are several ways of calculating the distributed impedance of ground return transmission lines.

Magnusson (6) developed a method of calculating the mutual and self-impedance of overhead lines with the earth as a return path. He also calculated the mutual and self-impedance of the line under the

following conditions:

- A. A conductor height of 35 feet
- B. A line-to-ground short-circuit current of 2000 amperes.
- C. A ground conductivity of 0.01 mho per meter

By the calculated value of the mutual and self-impedance of overhead lines with the earth as a return path and the use of the developed formula, he calculated the current densities in a typical below grade swimming pool.

The densities change with respect to the distance of the swimming pool from the vertical plane of the transmission line. The calculated current densities in the pool were found to be hazardous to the swimmer in the swimming pool.

1.2 STATEMENT OF THE PROBLEM

The purpose of this investigation is to develop a computer code based on Maxwell's equations to calculate potentials between points of interest on the surface of the earth and swimming pool by knowing at least two boundary conditions, using the Finite Element Method.

In order to check the validity of this study, the results are compared to experimental values.

CHAPTER II

FINITE ELEMENT METHOD

2.1 DEFINITION

The Finite Element Method is a numerical technique for obtaining approximate solutions to a wide variety of engineering problems. The ability to use elements of various types and sizes and to model a system of arbitrary geometry, are the main advantages of the Finite Element Method.

Other approximate methods, for example the Finite Difference Method, lacks these advantages. Using these approximate methods, a specific numerical result may be obtained for a specific problem, but a general computer solution applicable to all cases is not possible.

The Finite Element Method offers a way to solve a complex continuum problem by subdividing the continuum into a series of simpler interrelated problems. It gives a consistent technique for modeling the system as an assemblage of discrete parts or finite elements.

2.2 FORMULATION OF FINITE ELEMENT METHOD

It is desirable to obtain results in a general form applicable to any situation. For this purpose a division of the region into triangular shape elements is used as shown in Fig. 2.1.

The problem is to calculate the values of $H_N^{(e)}$ (i.e., voltage) at each node, ($N = 1, 2, \dots, n$) by knowing values of $H_N^{(e)}$ at some node




Figure 2.1 Triangular division of the area.

as boundary conditions.

The integer numbers of 1, 2, ..., n represent the number of the particular node and value of H at node 5 which is written as H_5 . The integer numbers written inside parenthesis, for example, (3) represents the element's number.

Each element has three nodes and each node has its own coordinate values. For example, element (1) has nodes 1,2,7 and coordinate values of (x_1, y_1) , (x_2, y_2) , (x_7, y_7) , and element (5) has nodes 6,7,5 and coordinate values of (x_6, y_6) , (x_7, y_7) , (x_5, y_5) .

Fig. 2.2 shows a typical triangle from the whole area of Fig. 2.1. The assumption is that the value of h (i.e., voltage) at any point inside the triangle is a linear function of H at the triangle's three nodes, or simply:

$$h^{(e)} = [N_{\ell}^{(e)} \quad N_m^{(e)} \quad N_m^{(e)}] \begin{bmatrix} H_{\ell} \\ H_m \\ H_m \end{bmatrix} = [N][H] \quad 2-1$$




Figure 2.2 One triangle element.

Therefore, for the area of Fig. 2.1, the values of h in each element are:

$$h^{(1)} = N_1^{(1)} H_1 + N_2^{(1)} H_2 + N_7^{(1)} H_7 \quad 2-2$$

$$h^{(2)} = N_2^{(2)} H_2 + N_3^{(2)} H_3 + N_7^{(2)} H_7 \quad 2-3$$

$$h^{(3)} = N_3^{(3)} H_3 + N_4^{(3)} H_4 + N_7^{(3)} H_7 \quad 2-4$$

$$h^{(4)} = N_4^{(4)} H_4 + N_5^{(4)} H_5 + N_7^{(4)} H_7 \quad 2-5$$

$$h^{(5)} = N_5^{(5)} H_5 + N_6^{(5)} H_6 + N_7^{(5)} H_7 \quad 2-6$$

$$h^{(6)} = N_6^{(6)} H_6 + N_1^{(6)} H_1 + N_7^{(6)} H_7 \quad 2-7$$

Where $[N]$ is called a shape function and will be seen later to play a paramount role in the Finite Element Method. The shape function is a function of area coordinates:

$$N_n^{(e)} = 1/2A^{(e)} [a_n^{(e)} + b_n^{(e)} X + c_n^{(e)} Y] \quad 2-8$$

Where A = area of the triangle:

$$a_n = x_\ell y_m - x_m y_\ell$$

$$b_n = y_\ell - y_m$$

$$c_n = x_m - x_\ell$$

For example N_7 for element (4) is:

$$N_7^{(4)} = 1/2A^{(4)} [a_7^{(4)} + b_7^{(4)} X + c_7^{(4)} Y]$$

Where:

$$a_7 = x_4 y_5 - x_5 y_4$$

$$b_7 = y_4 - y_5$$

$$c_7 = x_5 - x_4$$

and so on.

The total h in this area is equal to the summation of hS in the elements.

$$h = \sum_{e=1}^E h^{(e)} \quad 2-9$$

Where E is the number of the last node. Eq. 2-9 could be written in matrix form as well as in summation form.

$$\begin{bmatrix} h^{(1)} \\ h^{(2)} \\ h^{(3)} \\ h^{(4)} \\ h^{(5)} \\ h^{(6)} \end{bmatrix} = \begin{bmatrix} N_1^{(1)} & N_2^{(1)} & 0 & 0 & 0 & 0 & N_7^{(1)} \\ 0 & N_2^{(2)} & N_3^{(2)} & 0 & 0 & 0 & N_7^{(2)} \\ 0 & 0 & N_3^{(3)} & N_4^{(3)} & 0 & 0 & N_7^{(3)} \\ 0 & 0 & 0 & N_4^{(4)} & N_5^{(4)} & 0 & N_7^{(4)} \\ 0 & 0 & 0 & 0 & N_5^{(5)} & N_6^{(5)} & N_7^{(5)} \\ N_1^{(6)} & 0 & 0 & 0 & 0 & N_6^{(6)} & N_7^{(6)} \end{bmatrix} \begin{bmatrix} H_1 \\ H_2 \\ H_3 \\ H_4 \\ H_5 \\ H_6 \end{bmatrix} \quad 2-10$$

2.3 FORMULATION OF POTENTIAL PROBLEMS WITH SPATIAL FINITE ELEMENT SUBDIVISIONS

The current density J_T consists of both conduction and displacement components, respectively:

$$J_T = \sigma E + (\partial/\partial t)D \quad 2-11$$

where

$$D = j\omega\epsilon E \quad 2-12$$

After substitution of Eq. 2-12 into Eq. 2-11 one may obtain this result:

$$J_T = (\sigma + j\omega\epsilon)E \quad 2-13$$

Equation 2-13 by Kirchoff's law must satisfy the continuity equation.

$$\nabla \cdot J_T = 0 \quad 2-14$$

or

$$\nabla \cdot (\sigma + j\omega\epsilon)E = 0 \quad 2-15$$

but

$$E = -\nabla V = 0 \quad 2-16$$

$$\nabla \cdot (\sigma + j\omega\epsilon)\nabla V = 0 \quad 2-17$$

where

$$\nabla V = [(\partial/\partial x)Va_x + (\partial/\partial y)Va_y + (\partial/\partial z)Va_z] \quad 2-18$$

Substitute Eq. 2-18 back in Eq. 2-16:

$$\nabla \cdot (\sigma + j\omega\epsilon)[(\partial/\partial x)Va_x + (\partial/\partial y)Va_y + (\partial/\partial z)Va_z] = 0 \quad 2-19$$

$$\nabla \cdot A = (\partial/\partial x)A + (\partial/\partial y)A + (\partial/\partial z)A \quad 2-20$$

Therefore the resultant equation is:

$$(\partial/\partial x)(\sigma + j\omega\epsilon)(\partial/\partial x)V + (\partial/\partial y)(\sigma + j\omega\epsilon)(\partial/\partial y)V +$$

$$(\partial/\partial z)(\sigma + j\omega\epsilon)(\partial/\partial z)V = 0 \quad 2-21$$

In order to solve Eq. 2-21 one may need to know Euler's theorem of variational calculus, as outlined in Appendix A. By the help of variational calculus, a function $I(V)$ could be found where $\delta I(V) = 0$ everywhere.

$$I(V) = 1/2 \int_{\Omega} [(\sigma + j\omega\epsilon)(\partial V/\partial x)^2 + (\sigma + j\omega\epsilon)(\partial V/\partial y)^2 + (\sigma + j\omega\epsilon)(\partial V/\partial z)^2] dx dy dz \quad 2-22$$

but

$$V^{(e)} = \sum_{i=1}^3 N_i V_i = [N][V]^{(e)} \quad 2-23$$

The derivative of $I(V)$ with respect to the V_i is equal to zero.

$$\begin{aligned} \partial I(V)^{(e)} / \partial V_i &= 0 \\ &= \int_{\Omega} \left\{ [(\sigma + j\omega\epsilon)(\partial V^{(e)}/\partial x)(\partial/\partial V_i)(\partial V^{(e)}/\partial x)] + \right. \\ &\quad [(\sigma + j\omega\epsilon)(\partial V^{(e)}/\partial y)(\partial/\partial V_i)(\partial V^{(e)}/\partial y)] + \\ &\quad \left. [(\sigma + j\omega\epsilon)(\partial V^{(e)}/\partial z)(\partial/\partial V_i)(\partial V^{(e)}/\partial z)] \right\} dx dy dz \quad 2-24 \end{aligned}$$

But from Eq. 2-23 it is obvious that the derivative of $V^{(e)}$ with respect to x is:

$$\partial V^{(e)} / \partial x = \sum_{i=1}^3 (\partial N_i / \partial x) V_i = [\partial N / \partial x][V]^{(e)} \quad 2-25$$

$$(\partial/\partial V_i)(\partial V^{(e)}/\partial x) = (\partial/\partial V_i)[(\partial N_i / \partial x) V_i] = \partial N_i / \partial x \quad 2-26$$

where

$$\partial V^{(e)} / \partial V_i = N_i \quad 2-27$$

The result of the substitution of Eq. 2-25, 2-26 and 2-27 back in Eq.

2-24 is:

$$\begin{aligned} \partial I(V)^{(e)} / \partial V_i = 0 = \int_{\Omega} \left\{ (\sigma + j\omega\epsilon) [\partial N / \partial x] [V] (\partial N_i / \partial x) + \right. \\ (\sigma + j\omega\epsilon) [\partial N / \partial y] [V] (\partial N_i / \partial y) + \\ \left. (\sigma + j\omega\epsilon) [\partial N / \partial z] [V] [\partial N_i / \partial z] \right\} dx dy dz \end{aligned} \quad 2-28$$

Equation 2-28 could be written in general form as:

$$[K][V] = [0] \quad 2-29$$

Where:

$$\begin{aligned} K_{i,j} = \int_{\Omega} \left\{ (\sigma + j\omega\epsilon) (\partial N_i / \partial x) (\partial N_j / \partial x) + (\sigma + j\omega\epsilon) (\partial N_i / \partial y) \right. \\ \left. (\partial N_j / \partial y) + (\sigma + j\omega\epsilon) (\partial N_i / \partial z) (\partial N_j / \partial z) \right\} dx dy dz \end{aligned} \quad 2-30$$

2.4 FINITE ELEMENT SOLUTION OF COMPLEX POTENTIAL ELECTRIC FIELDS

The region of the problem can be subdivided into triangles in any desired manner, insuring only that all different material interfaces coincide with triangle sides. Figure 2.3 shows a typical region divided into triangles.

It is assumed that there is a linear variation of potential within each triangular element with respect to the nodal potentials.

A convenient set of coordinates L_1, L_2, L_3 for a triangle ℓ, m, n , Fig. 2.4, is defined by the following linear relation between these and the Cartesian system:




Figure 2.3 Typical triangle with vertices marked.




Figure 2.4 Area coordinates.

$$x = L_1 x_\ell + L_2 x_m + L_3 x_n \quad 2-31$$

$$y = L_1 y_\ell + L_2 y_m + L_3 y_n \quad 2-32$$

$$1 = L_1 + L_2 + L_3 \quad 2-33$$

To every set, L_1, L_2, L_3 (which are not independent, but are related by the third equation) corresponds a unique set of Cartesian coordinates. At point 1, $L_1 = 1$ and $L_2 = L_3 = 0$, etc. A linear relation between the area coordinates and Cartesian coordinates implies that contours of L_1 are equally placed straight lines parallel to side 2-3 on which $L_1 = 0$ etc. It is easy to see that an alternative definition of the coordinate L_1 of a point P is by a ratio of the area of the shaded triangle to that of the total triangle.

$$L_1 = \frac{\text{area Pmn}}{\text{area } \ell mn} \quad 2-34$$

One may write Equations 2-31 through 2-33 in matrix form and solve it for L_1, L_2, L_3 .

$$\begin{bmatrix} x_\ell & x_m & x_n \\ y_\ell & y_m & y_n \\ 1 & 1 & 1 \end{bmatrix} \begin{bmatrix} L_1 \\ L_2 \\ L_3 \end{bmatrix} = \begin{bmatrix} x \\ y \\ 1 \end{bmatrix}$$

$$L_1 = \frac{\begin{vmatrix} x & x_m & x_n \\ y & y_m & y_n \\ 1 & 1 & 1 \end{vmatrix}}{\begin{vmatrix} x_\ell & x_m & x_n \\ y_\ell & y_m & y_n \\ 1 & 1 & 1 \end{vmatrix}} = \frac{(x_m y_n - x_n y_m) + x(y_m - y_n) + y(x_n - x_m)}{2A} \quad 2-36$$

$$L_2 = \frac{\begin{vmatrix} x_\ell & x & x_n \\ y_\ell & y & y_n \\ 1 & 1 & 1 \end{vmatrix}}{\begin{vmatrix} x_\ell & x_m & x_n \\ y_\ell & y_m & y_n \\ 1 & 1 & 1 \end{vmatrix}} = \frac{(x_n y_\ell - x_\ell y_n) + x(y_n - y_\ell) + y(x_\ell - x_n)}{2A} \quad 2-37$$

$$L_3 = \frac{\begin{vmatrix} x_\ell & x_m & x \\ y_\ell & y_m & y \\ 1 & 1 & 1 \end{vmatrix}}{\begin{vmatrix} x_\ell & x_m & x_n \\ y_\ell & y_m & y_n \\ 1 & 1 & 1 \end{vmatrix}} = \frac{(x_\ell y_m - x_m y_\ell) + x(y_\ell - y_m) + y(x_m - x_\ell)}{2A} \quad 2-38$$

Where:

$$2A = 2*(\text{area of the triangle}) = (x_m y_n - x_n y_m) + (x_n y_\ell - x_\ell y_m) + (x_\ell y_m - x_m y_\ell) \quad 2-39$$

The area coordinates are the shape functions: $N_1 = L_1, N_2 = L_2$ and $N_3 = L_3$.

The potential inside the triangular element is a linear function of the nodal's potentials:

$$v^{(e)} = L_1 V_\ell + L_2 V_m + L_3 V_n \quad 2-40$$

After substituting Equations 2-36, 2-37 and 2-38 into Equation 2-40 one obtains:

$$\begin{aligned} v^{(e)} = 1/2A [& [(x_m y_n - x_n y_m) + x(y_m - y_n) + y(x_n - x_m)]V_\ell + \\ & [(x_n y_\ell - x_\ell y_n) + x(y_n - y_\ell) + y(x_\ell - x_n)]V_m + \\ & [(x_\ell y_m - x_m y_\ell) + x(y_\ell - y_m) + y(x_m - x_\ell)]V_n] \end{aligned} \quad 2-41$$

In order to solve Equation 2-28 the shape functions must be known. When they are determined they can be substituted in Equation 2-42.

$$[K][V] = [0] \quad 2-42$$

Matrix K is calculated for a two dimensional problem.

$$K_{ij} = \int_{\Omega} [(\sigma + j\omega\epsilon)(\partial N_i / \partial x)(\partial N_j / \partial x) + (\sigma + j\omega\epsilon)(\partial N_i / \partial y)(\partial N_j / \partial y)] dx dy \quad 2-43$$

For each element $(\sigma + j\omega\epsilon)$ may be taken outside the integration sign.

Therefore:

$$\begin{aligned} K_{1,1} &= [(dN_1/dx)^2 + (dN_1/dy)^2] dx dy \\ &= \left[\frac{(y_m - y_n)^2}{4*A^2} + \frac{(x_n - x_m)^2}{4*A^2} \right] dx dy = \frac{(y_m - y_n)^2 + (x_n - x_m)^2}{4*A} \end{aligned} \quad 2-44$$

$$\begin{aligned} K_{1,2} &= \left[\frac{(y_m - y_n)(y_n - y_l)}{4*A^2} + \frac{(x_n - x_m)(x_l - x_m)}{4*A^2} \right] dx dy = \\ &= \frac{(y_m - y_n)(y_n - y_l) + (x_n - x_m)(x_l - x_m)}{4*A} \end{aligned} \quad 2-45$$

$$K_{1,3} = \frac{(y_m - y_n)(y_l - y_m) + (x_n - x_m)(x_m - x_l)}{4*A} \quad 2-46$$

$$K_{2,1} = K_{1,2} \quad 2-47$$

$$K_{2,2} = \frac{(y_n - y_l)^2 + (x_l - x_n)^2}{4*A} \quad 2-48$$

$$\begin{aligned} K_{2,3} &= \left[\frac{(y_n - y_l)(y_l - y_m)}{4*A^2} + \frac{(x_l - x_n)(x_m - x_l)}{4*A^2} \right] dx dy = \\ &= \frac{(y_n - y_l)(y_l - y_m) + (x_l - x_n)(x_m - x_l)}{4*A} \end{aligned} \quad 2-49$$

$$K_{3,1} = K_{1,3} \quad 2-50$$

$$K_{3,2} = K_{2,3} \quad 2-51$$

$$K_{3,3} = \frac{(y_l - y_m)^2 + (x_m - x_l)^2}{4 * A} \quad 2-52$$

Substituting Equations 2-44 thru 2-51 into Equation 2-42 and writing the result in matrix form:

$$\begin{bmatrix}
 (y_m - y_n)^2 + (x_n - x_m)^2 + (y_m - y_n)(y_n - y_\ell) + (x_n - x_m)(x_\ell - x_n) \\
 (y_m - y_n)(y_n - y_\ell) + (x_n - x_m)(x_\ell - x_n)^2 + (y_n - y_\ell)(y_\ell - y_m) + (x_\ell - x_n)(x_m - x_\ell) \\
 (Y_m - Y_n)(Y_\ell - Y_m) + (X_n - X_m)(X_m - X_\ell) + (Y_n - Y_\ell)(Y_\ell - Y_m) + (X_\ell - X_n)(X_m - X_\ell) + (Y_\ell - Y_m)^2 + (X_m - X_\ell)^2
 \end{bmatrix}
 =
 \begin{bmatrix}
 V_\ell \\
 V_m \\
 V_n
 \end{bmatrix}
 =
 \begin{bmatrix}
 0 \\
 0 \\
 0
 \end{bmatrix}$$

CHAPTER III

COMPUTER PROGRAM

3.1 SOLUTION TECHNIQUE FOR THE FINITE ELEMENT METHOD

A computer program is written to solve Eq. 2-53 for the region of interest which consists of n -type of materials and at least two boundary conditions. This equation in the short form is given by:

$$[K][V] = [O] \quad 3-1$$

Matrix $[K]$ is the coefficient matrix and consists of all the properties of the materials in the region. Each element in the region could have a different property from the others. Matrix $[K]$ is calculated for each element with its own properties and then transferred to the final coefficient matrix $[F]$. One example is given below.

Region S, Fig. 3.1, is divided into 18 triangular elements and each element has been numbered from 1 to 18.

Also all nodes are numbered in a fashion to create a sparse $[F]$ matrix to reduce the band-width of the $[F]$ matrix. To do so, the side which has less nodes than the other is determined. Then the nodes are numbered from one end to the other and returned to the original side, as shown in Fig. 3.1. This method insures the smallest possible band-width for the $[F]$ matrix.




Figure 3.1 Region S is divided in 18 triangular elements.

x

The arbitrary element Z has nodes ℓ, m, n and coordinates of (xN, YN) , (xNm, YNm) , (xNn, YNn) and material property of P. By using Eq. 2-53 we can solve for matrix K:

$$K = \begin{bmatrix} K_{\ell, \ell} & K_{\ell, m} & K_{\ell, n} \\ K_{m, \ell} & K_{m, m} & K_{m, n} \\ K_{n, \ell} & K_{n, m} & K_{n, n} \end{bmatrix} \quad 3-2$$

By transformation, $K_{\ell, \ell}$ goes to the [F] matrix in row ℓ and column ℓ and then added to the previous value of $F_{\ell, \ell}$. Similarly, $K_{\ell, m}$ goes into the row ℓ and column m of the matrix [F] and then added to the previous values of $F_{\ell, m}$, and so on.

After completing the matrix [F], Equation 3-1 becomes:

$$[F][V] = [0] \quad 3-3$$

where it has the dimension of (No. of nodes by No. of nodes) and K is a 3 by 3 matrix. Since Equation 3-3 is equal to zero, it requires the boundary conditions for solution. The boundary conditions are used to create values on the other side of the equation.

For instance, region S in Fig. 3.1 has two boundaries, one at each end. Nodes 1,5,9 and 13 from one end and nodes 4,8,12 and 16 from the other end are the boundary nodals and have known values of voltage. Therefore we can leave these nodes out of our calculations. For example: element (7) has nodes 5,6,9 where nodes 5,9 have known values and node 6 is an unknown.

The matrix notation for this element after calculating the K matrix is:

$$\begin{bmatrix} K_{5,5} & K_{5,6} & K_{5,9} \\ K_{6,5} & K_{6,6} & K_{6,9} \\ K_{9,5} & K_{9,6} & K_{9,9} \end{bmatrix} \begin{bmatrix} v_5 \\ v_6 \\ v_9 \end{bmatrix} = \begin{bmatrix} 0 \\ 0 \\ 0 \end{bmatrix} \quad 3-4$$

Therefore there is just one equation and one unknown and it is easy to transfer the known values to the other side of the equation. The result is:

$$[K_{6,6}][v_6] = [-K_{6,5} * v_5 - K_{6,9} * v_9] = [B_6] \quad 3-5$$

Now this equation is transferred to the [F] matrix:

$$[F][V] = [B] \quad 3-6$$

For the small size of matrix [F] we can find the inverse of the [F] matrix and multiply it with the [B] matrix to find the values of the nodes.

All finite element solutions require a high subdivision of the region for the utmost accuracy. This makes matrix [F] so large that it becomes useless to solve by the inversion of the [F] matrix.

Due to the nature of the problem, provided that the nodes are numbered in a careful manner, the non-zero terms in matrix [F] will be concentrated in a narrow band situated adjacent to the leading diagonal. This fact, combined with the symmetrical nature of matrix [F] indicates that only a relatively small portion of the matrix is of real interest. If advantage is taken of these observations, demands on the computer storage may be considerably reduced. Moreover, if the solution procedure is so arranged that many of the operations involving the zero terms are eliminated, the speed of the solution can be increased. Methods which

take advantage of the banded nature of matrix $[F]$ are often called 'banded methods'.

Methods which offer potentially greater economies are the so-called 'half-banded schemes'. The upper half of the diagonal band of the matrix is stored as a rectangular matrix as shown in Figure 3.2.




Figure 3.2 Banded form of a symmetrical matrix.

The upper half band part of matrix $[F]$ is stored in matrix $[A]$ which is much smaller than matrix $[F]$. Matrix $[A]$ has a number of columns equal to the bandwidth and rows equal to the number of nodes. Each row of matrix $[F]$ is transferred to matrix $[A]$.

To calculate the band-width of a finite element problem, one must know the number of all elements and their node numbers, because bandwidth is equal to the largest difference between two nodes in one element; that is compared to the rest of elements + 1.

Figure 3.3 is a flow chart of the computer program which finds the bandwidth of matrix $[F]$ or any other symmetrical matrix. Figure 3.4 is a flow chart which determines the coefficient matrix and transfers the upper half part of matrix $[F]$ to matrix $[A]$.

Equation 3-6 takes the form:

$$[A][V] = [B]$$

3-7

It is impossible to find the inverse of [A] because it is no longer a square matrix. Therefore, the Gaussian Elimination Technique is used to solve Equation 3-7. Another step to save memory space is to eliminate matrix [V] from the equation. To do so, the problem between [A] and [B] is solved and the result is stored in matrix [B]. Matrix [B] has the same dimension as matrix [V].

For more understanding of the Gaussian Elimination Technique an example is solved in Appendix B along with the flow chart.

Appendix D includes a listing of the main program as well as all subroutines discussed in this chapter.




Figure 3.3 Flow chart, subroutine "BANDWIDTH".




Figure 3.4 Flow chart, subroutine "FIND".




Figure 3.4 (Continued)




Figure 3.4 (Continued)




Figure 3.4 (Continued)

3.2 RESULTS OF THE COMPUTER SOLUTION

The problem was to calculate current densities everywhere in the region S. Region S was a large area of soil with a sunken swimming pool in the center of the region. The region was divided into 760 elements with three types of materials and two boundary conditions. Figure 3.5 shows the subdivided region of 'S'.

For large problems such as this involving many elements, it is useful to possess a routine which generates the complete set of data for the finite element program.

Region 'S' was subdivided into five regions. Region one was below the swimming pool, region two and four were the swimming pool ends and the soil; region three was the swimming pool and surrounding soil; and region five was above the swimming pool. Figure 3.6 shows these five regions.

The reason for dividing region 'S' into five regions was to make data preparation easier. Regions 2,3,4 were divided in a different fashion than 1 and 5. Region 1,5 and 2,4 are identical in values of x and y with some constant. Also the results of each region can be stored in a different matrix and recalled when needed. All nodes on each boundary are given the same number for simplification purposes.

A subroutine was written to find the coordinates of all nodes. Figure 3.7 shows a flow chart of such a subroutine.

Figure 3.5 shows that nodes 1,10,19,28 and 37 have the same value of x and nodes 1,2,3,4,5,6,7,8 and 9 have the same values of y . Therefore coordinates of nodes are calculated and stored in a matrix for later use.

Another data file is generated which consists of all elements with their nodal numbers. Figure 3.8 shows a flow chart of this program (called "TES") which can read the element's number and their nodal numbers from the file and find the corresponding coordinate values and store them in a separate file, which lacks the information about the first and last row of the region 'S'. This information could be added to the file easily.

This data file is ready to be given to the main program for calculation of voltages at each node. A program is written to calculate the current densities in the region in the y-direction. Results of computer program, in tabular form are given in Appendix E.

A comparison of the computer results with experimental results is given in Chapter V.

Figure 3.5 The finite element model.




Figure 3.6 Regional division of the experimental model.




Figure 3.7 Flow chart, subroutine "GOOD".




Figure 3.8 Flow chart, program "TES".

3.3 COMPARISON OF RESULTS WITH OTHER COMPUTER TECHNIQUES

In order to check the accuracy of the proposed theoretical technique which is based on Maxwell's equations, solutions to selected problems were compared to results obtained using another computer program, which calculates electric fields in configurations with both capacitive and resistive distribution of potentials (Anderson, 1976, Ref. No. 16).




Figure 3.9 Resistive and complex admittance networks.

Figure 3.9 shows triangular elements and their complex admittance network. The resultant equation for the complex potential at the center node is:

$$V_o = \frac{1}{\sum_{n=1}^6 (G+jB)_n} \sum_{n=1}^6 (G+jB)_n V_n \quad 3.8$$

To check the accuracy of the program, results of a specific problem are compared.

A square of 100 x 100 mm is divided up into two series connected halves, one where the capacitive distribution dominates, and one where the resistive distribution dominates. Permittivities and conductivities are chosen in such a way that the voltage across each half has the same magnitude (Fig. 3.10). A very coarse subdivision of only 16 triangular elements is used.




Figure 3.10 Two materials in series.

Table 3.1 shows the comparison of results using Andersen's solution and the proposed solution, to the actual values. As evident from Table 3.1, agreement between the proposed solution and the actual values is very close.

TABLE 3.1

Sta.	Actual Values	Andersen's Solution	Proposed Solution
Y	$100+j0$	$100+j0$	$100+j0$
C	$75+j25$	$74.99+j24.97$	$74.9999+j24.9695$
B	$50+j50$	$49.98+j50.02$	$49.9999+j50.0001$
A	$25+j25$	$24.99+j24.99$	$24.9999+j24.9999$
X	$0+j0$	$0+j0$	$0+j0$

Also, the accuracy of the proposed theoretical solution was verified by comparing the results of the theoretical solution to known actual values. In all cases very close agreement was observed.

CHAPTER IV

EXPERIMENTAL PROGRAM

In conjunction with the theoretical analysis, an experimental program was set up. This experiment was based on an average current density of 0.07 amp per square meter in the uniform ground under the transmission line. (See Appendix C.)

In order to create a similar situation for the experiment, a large box with conductors at two ends was chosen to hold the soil and the swimming pool. Figure 4.1 shows a schematic diagram of the box.

To create a uniform current density throughout the soil a known voltage calculated from Equation 4-1 was applied across the conductors.

$$J = E\sigma = E/\rho \quad 4-1$$

where J = current density

ρ = resistivity of soil

σ = conductivity of soil

E = applied voltage

Resistivity of the soil was calculated from Equation 4-2.

$$R = V/I = \rho l/s = l/\sigma s \quad 4-2$$

The experiment was done for three different resistivity values for the soil, each soil type with two different types of swimming pools, reinforced and non-reinforced swimming pool; and each swimming pool

containing three different types of water.

Three resistivity values for soil and conductivity values for water were:

	For Soil	For Water
a:	1000 ohm-meter	30 micro-mho/cm
b:	55 ohm-meter	1500 micro-mho/cm
c:	10 ohm-meter	3000 micro-mho/cm

To determine the current densities, first potentials at predetermined points were measured and then current densities were calculated from potential measurements.

$$\text{current densities} = \frac{\text{difference in two potentials}}{(\text{distance between two potentials}) * \text{conductivity of the material}}$$

Figure 4.2 shows a schematic diagram of the circuit used to measure the potentials at each point.

Reference 18 contains a detailed description of the experimental program and results. Selected results of this experimental program are presented in tabular form in Appendix F.





Figure 4.1 Schematic diagram of the experimental model.



SWITCH 1 TO MEASURE VOLTAGES IN THE SOIL.
 SWITCH 2 TO MEASURE VOLTAGES IN THE WATER.

Figure 4.2 Schematic diagram of the electrical circuit.

CHAPTER V

RESULTS

5.1 COMPARISON OF CALCULATED VALUES WITH EXPERIMENTAL RESULTS

In order to compare the calculated results with the measured values, current densities of medium case (resistivity of the soil = 55 ohm-meter) are plotted in Figures 5.1 to 5.8.

In these figures, current densities are plotted versus distance. Each figure represents calculated and measured current densities in the soil as well as the swimming pool.

The calculated current densities in these figures show the expected symmetry of the system about the center line, Figures 5.1-5.8. This is one verification of the accuracy of the computer program.

The measured values of current densities do not show the same exact symmetry. This could be explained in terms of the accuracy of the instruments. Also the conductivity of the soil is not uniform everywhere and the given value of conductivity is only an average measured value. Another reason for the discrepancy between the theoretical and measured values is the two dimensional computer modeling, which assumes the swimming pool walls to be infinitely long in the z-direction (depth).

The calculated values of the current densities between stations 1 to 6 and 12 to 17, Figures 5.1-5.2, in the soil are higher than measured values. The measured values of current densities inside and outside the swimming pool between stations 6 to 12 are higher than

calculated values. Between stations 6 to 12 the theoretical model assumes a plate of iron bars of infinite depth. Due to this plate of high conductivity, the potential gradients along the plate are zero, resulting in zero current densities along the line 'C'. Furthermore, the current flowing along the paths 'A' and 'B' are attracted toward the infinite iron plate resulting in lower values of current densities along 'A' and 'B' as compared to the experimental case, where only finite plates of iron bars exist.

Along the line 'D', the calculated current densities must go through the infinite iron plate, while in the measured case the current paths go through the bottom surface bars of the swimming pool. Results in tabular form are shown in Appendices D and E.

The reason for higher current densities and potential gradients along the line 'C' between stations 6-8 and 10-12 is the sharp change in material conductivities at these stations (soil conductivity = 1.8×10^{-1} mho/m; iron conductivity = 1.1×10^6 mho/m). Due to high conductivity of iron bars the current is attracted toward the pool walls and thus increasing the field (potential gradient) around the corners.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)

SOIL RESISTIVITY = 5.5 ohm-meters POOL TYPE: Reinforced

WATER CONDUCTIVITY = 1500 micro-mho/cm Non-reinforced




Figure 5.1 Calculated current densities.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)

SOIL RESISTIVITY = 55 ohm-meters POOL TYPE: ☒ Reinforced

WATER CONDUCTIVITY = 1500 micro-mho/cm ☐ Non-reinforced




Figure 5.2 Calculated current densities.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)

SOIL RESISTIVITY = 55 ohm-meters POOL TYPE: Reinforced
 Non-reinforced

WATER CONDUCTIVITY = 3000 micro-mho/cm

LINE C Calculated ——— Measured - - - -




Figure 5.3 Calculated current densities.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)

SOIL RESISTIVITY = 5.5 ohm-meters POOL TYPE: ☒ Reinforced

WATER CONDUCTIVITY = 3000 micro-mho/cm ☐ Non-reinforced




Figure 5.4 Calculated current densities.


CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)SOIL RESISTIVITY = 59.5 ohm-meters POOL TYPE: ReinforcedWATER CONDUCTIVITY = 1600 micro-mho/cm Non-reinforced

Figure 5.5 Calculated current densities.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)

SOIL RESISTIVITY = 59.5 ohm-meters POOL TYPE: □ Reinforced

WATER CONDUCTIVITY = 1600 micro-mho/cm ☒ Non-reinforced

LINE D Calculated ——— Measured - - - -




Figure 5.6 Calculated current densities.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m²)

SOIL RESISTIVITY = 59.5 ohm-meters POOL TYPE: □ Reinforced

WATER CONDUCTIVITY = 3000 micro-mho/cm ☒ Non-reinforced

LINE C Calculated ——— Measured - - - - -




Figure 5.7 Calculated current densities.

CURRENT DENSITIES IN SOIL AND POOL WATER (m-Amps/m^2)SOIL RESISTIVITY = 59.5 ohm-meters POOL TYPE: ReinforcedWATER CONDUCTIVITY = 3000 micro-mho/cm Non-reinforced

LINE D Calculated ——— Measured - - - -




Figure 5.8 Calculated current densities.

5.2 POTENTIAL HAZARD TO THE HUMAN BODY

It is known that the real measure of shock intensity lies in the amount of current (amperes) forced through the body, and not the voltage (17). Figure 5.9 shows levels of current hazards to the human body.

To define how hazardous the observed current densities are to humans, currents through the human body are calculated. The human body's resistance is in the neighborhood of 1000 ohm (17). the human body if one is standing in the vicinity of the swimming pool. Similar calculations are done for a person who is inside the swimming pool and results are shown in Table 5.5.

In comparing the calculated currents traveling through the human body with Fig. 5.9, one concludes that hazard may exist on the edge of the swimming pool where the resistivity of the surrounding soil is very high. However, this analysis does not include the presence of a human body in the model. Also, the effects of short duration currents (1-10 cycles) on the human body need further investigation.




Figure 5.9 Levels of current hazards to the human body.

TABLE 5.1

CALCULATED CURRENT TRAVELING THROUGH THE
HUMAN BODY STANDING ON THE SOIL

LINE A STANDING ON THE SOIL

SOIL RESISTIVITY=1160 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MOH/CM

POOL TYPE: REINFORCED

FOOT TO FOOT RESISTANCE OF HUMAN BODY = 1000 OHM

FOOT TO FOOT DISTANCE = 50 CM.

BETWEEN ST#	ST#	VOLTAGE GRADIENT VOLTS/METER	VOLTAGE ACROSS BODY VOLTS	CURRENT THROUGH BODY AMP.
1	2	102.500	51.250	0.05125
2	3	101.836	50.918	0.05092
3	4	100.472	50.236	0.05024
4	5	96.782	48.391	0.04839
5	6	84.769	42.384	0.04278
6	7	69.020	34.510	0.03451
7	8	67.368	33.684	0.03368
8	9	53.210	26.605	0.02660
9	10	51.741	25.870	0.02587
10	11	64.211	32.105	0.03211
11	12	65.882	32.941	0.03294
12	13	80.417	40.208	0.04021
13	14	91.500	45.750	0.04575
14	15	94.874	47.437	0.04744
15	16	96.447	48.224	0.04822
16	17	96.235	48.118	0.04812

TABLE 5.2

CALCULATED CURRENT TRAVELING THROUGH THE
HUMAN BODY STANDING ON THE SOIL

LINE B STANDING ON THE SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MOH/CM

POOL TYPE: REINFORCED

FOOT TO FOOT RESISTANCE OF HUMAN BODY = 1000 OHM

FOOT TO FOOT DISTANCE = 50 CM.

BETWEEN ST#	ST#	VOLTAGE GRADIENT VOLTS/METER	VOLTAGE ACROSS BODY VOLTS	CURRENT THROUGH BODY AMP.
1	2	104.737	52.368	0.05237
2	3	104.492	52.246	0.05225
3	4	104.961	52.480	0.05248
4	5	105.509	52.755	0.05275
5	6	103.148	51.574	0.05157
6	7	71.176	35.588	0.03559
7	8	62.632	31.316	0.03132
8	9	28.275	14.137	0.01414
9	10	27.056	13.528	0.01353
10	11	58.947	29.474	0.02947
11	12	67.255	33.627	0.03363
12	13	97.199	48.600	0.04860
13	14	99.493	49.747	0.04975
14	15	98.984	49.492	0.04949
15	16	98.852	49.426	0.04943
16	17	98.209	49.105	0.04910

TABLE 5.3

CALCULATED CURRENT TRAVELING THROUGH THE
HUMAN BODY STANDING ON THE SOIL

LINE C STANDING ON THE SOIL

SOIL RESISTIVITY=1160 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MOH/CM

POOL TYPE: REINFORCED

FOOT TO FOOT RESISTANCE OF HUMAN BODY = 1000 OHM

FOOT TO FOOT DISTANCE = 50 CM

BETWEEN ST#	ST#	VOLTAGE GRADIENT VOLTS/METER	VOLTAGE ACROSS BODY VOLTS	CURRENT THROUGH BODY AMP.
1	2	105.066	52.533	0.05253
2	3	104.951	52.475	0.05240
3	4	105.945	52.972	0.05297
4	5	108.403	54.201	0.05420
5	6	122.431	61.215	0.06122
6	7	200.980	100.490	0.10049
7	8	0.000	0.000	0.00000
8	9	0.000	0.000	0.00000
9	10	0.000	0.000	0.00000
10	11	0.000	0.000	0.00000
11	12	188.235	94.118	0.09412
12	13	115.208	57.604	0.05760
13	14	102.185	51.093	0.05109
14	15	99.882	49.941	0.04994
15	16	99.276	49.638	0.04964
16	17	98.536	49.268	0.04927

TABLE 5.4

CALCULATED CURRENT TRAVELING THROUGH THE
HUMAN BODY STANDING ON THE SOIL

LINE D STANDING ON THE SOIL

SOIL RESISTIVITY=1160 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MOH/CM

POOL TYPE: REINFORCED

FOOT TO FOOT RESISTANCE OF HUMAN BODY = 1000 OHM

FOOT TO FOOT DISTANCE = 50 CM

BETWEEN ST#	ST#	VOLTAGE GRADIENT VOLTS/METER	VOLTAGE ACROSS BODY VOLTS	CURRENT THROUGH BODY AMP.
1	2	105.461	52.730	0.05273
2	3	105.410	52.705	0.05270
3	4	106.929	53.465	0.05346
4	5	110.787	55.394	0.05539
5	6	127.153	63.576	0.06358
6	7	131.961	65.980	0.06598
7	8	IN WATER	IN WATER	IN WATER
8	9	IN WATER	IN WATER	IN WATER
9	10	IN WATER	IN WATER	IN WATER
10	11	IN WATER	IN WATER	IN WATER
11	12	123.922	61.961	0.06196
12	13	119.630	59.815	0.05981
13	14	104.394	52.197	0.05220
14	15	100.795	50.398	0.05040
15	16	99,717	49.859	0.04986
16	17	98.863	49.431	0.04943

TABLE 5.5

CALCULATED CURRENT TRAVELING THROUGH THE
HUMAN BODY INSIDE THE SWIMMING POOL

SOIL RESISTIVITY=59.50 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MOH/CM

POOL TYPE: NON-REINFORCED

FOOT TO FOOT RESISTANCE OF HUMAN BODY = 1000 OHM

FOOT TO FOOT DISTANCE = 50 CM

BETWEEN	VOLTAGE GRADIENT	VOLTAGE ACROSS BODY	CURRENT THROUGH BODY
ST# ST#	VOLTS/METER	VOLTS	AMP.
1 2	0.875	0.438	0.00044
2 3	0.800	0.400	0.00040
3 4	0.775	0.388	0.00039
4 5	0.787	0.394	0.00039
5 6	0.788	0.394	0.00039
6 7	0.788	0.394	0.00039
7 8	0.800	0.400	0.00040

5.3 THE LIMITATIONS AND ACCURACY OF THE THEORETICAL TECHNIQUE

The technique used in the proposed solution is called The Finite Element Method. This is a powerful numerical technique to solve problems which require a high degree of accuracy. The solution of problems solved using this technique are comparatively more accurate than those solved by other numerical methods such as the Finite Difference Method.

However, there are some limitations as described below:

- (1) This program as it exists now can only handle two-dimensional problems. However, with further development, it would be possible to solve three-dimensional complex electro-magnetic and electro-static field problems.
- (2) This program uses only the triangular division of the region of interest. Rectangular or other shapes can be accommodated if the program is modified.
- (3) The computer storage is another limitation. This limitation was improved by using the half-banded method.

CHAPTER VI

CONCLUSION

In this study a computer code based on Maxwell's Equations was developed to use the Finite Element Method to calculate complex voltage gradients and current densities on the surface of any desired region.

In order to evaluate the accuracy of this program, the solution to a selected problem was compared to the solution using another computer technique. In addition, solution to several problems were compared to actual known values. In all cases close agreement between the theoretical solution and actual values was observed.

Also in order to check the validity of the program, theoretical results were compared to results obtained from experimental tests, and the comparison showed close agreement.

BIBLIOGRAPHY

1. John R. Carson; "Wave Propagation in Overhead Wires with Ground Return", The Bell System Technical Journal, 1926, 5, pp. 539-554.
2. L. J. Lacey; "The Mutual Impedance of Earth-Return Circuits", IEEE, Vol. 621, 392.2, 1952.
3. L. M. Wedepohl and R. G. Wasley; "Wave Propagation in Multiconductor Overhead Lines", Proc. IEE, 1966, 113, (4).
4. M. Krakowski; "Mutual Impedance of Crossing Earth-Return Circuits", Proceedings of the IEE, Feb. 76, Vol. 114, No. 2.
5. Mr. Nakagawa; "Earth Return Impedance of Overhead Lines Above a 3-Layer Earth", Proceedings of IEE, Dec. 1973, Vol. 120, Number 12.
6. P. Magnusson; "Wave Propagation Over Parallel Wires: The Proximity Effect", Vol. XI, Apr. 1921.
7. H. Bateman; "Partial Differential Equations of Mathematical Physics", Cambridge University Press, 1959.
8. E. D. Sunde; "Earth Conduction Effects in Transmission Systems", Van Nostrand, 1949.
9. B. O. Pierce; "A Short Table of Integrals", Boston: Ginn and Company, 1929.
10. N. W. McLachlan, "Bessel Function for Engineers", 2nd Ed. Oxford University Press, 1955.
11. Wiley; "The Finite Element Method for Engineers", New York, 1975.
12. O. C. Zienkiewicz, "The Finite Element Method in Engineering Science", McGraw-Hill, 1971.
13. P. Silvester; "Finite Element Solution of Saturable Magnetic Field Problems", Transaction on Power Apparatus and Systems, Vol. PAS-89, No. 7, Oct. 1970.
14. O. W. Andersen; "LaPlacian Electrostatic Field Calculations by Finite Elements with Automatic Grid Generations", Transaction on Power Apparatus and Systems, IEEE, Nov. 1972.
15. O. C. Zienkiewicz and Y. K. Cheung; "The Finite Element Method In-structural and Continuum Mechanics", McGraw-Hill, 1967.

16. O. W. Andersen; "Finite Element Solution of Complex Potential Electric Fields", IEEE Transactions on Power, Vol. PAS-96, No. 4, July/August 1977.
17. E. W. Kimbark, "Direct Current Transmission", Vol I, Wiley-Interscience, 1948.
18. V. K. Garg, F. Rad, T. Killian; "Study of Distribution of Ground Fault Currents in Below Grade Swimming Pools Located Near Transmission Lines", Portland State University, 1978.

APPENDIX A

EULER'S THEOREM OF VARIATIONAL CALCULUS

The transition from a variational statement to an equivalent governing differential equation is relatively simple and will be demonstrated here. The reverse process, however, is more involved and any generalized processes restrictive for the very reason that frequently on variational principle can be established.

Let us take a problem which is to be minimized.

$$g = \int_v f(x,y,z,H,H_x,H_y,H_z)dv + \int_c (qH + pH^2/2)ds \quad A-1$$

In this equation f is an arbitrary function, $H_x = \frac{\partial H}{\partial x}$, etc., and c is a portion of the boundary surface on which prescribed values of H are not imposed. On remainder $H = H_B$.

Considering an arbitrary small variation of the unknown function and its derivatives

$$\delta g = \int_v \left(\frac{\partial f}{\partial H} \delta H + \frac{\partial f}{\partial H_x} \delta H_x + \frac{\partial f}{\partial H_y} \delta H_y + \frac{\partial f}{\partial H_z} \delta H_z \right) dv + \int_c (q\delta H + pH\delta H)ds \quad A-2$$

as

$$\delta H_x = \delta \left(\frac{\partial H}{\partial x} \right) = \frac{\partial}{\partial x} (\delta H), \text{ etc.}$$

Equation A-2 can be written as;

$$\delta g = \int_V \left[\frac{\partial f}{\partial H} \delta H + \frac{\partial f}{\partial H_x} \frac{\partial}{\partial x} (\delta H) + \frac{\partial f}{\partial H_y} \frac{\partial}{\partial y} (\delta H) + \frac{\partial f}{\partial H_z} \frac{\partial}{\partial z} (\delta H) \right] dv + \int_V (q \delta H + p H \delta H) ds = 0 \quad \text{A-3}$$

In the above we have equated δx to zero, as at the minimum (or stationary point) the 'variation' becomes zero.

Now putting $dv = dx dy dz$ and integrating the second term of Equation A-3 by parts with respect to x

$$\int_V \frac{\partial f}{\partial H_x} \frac{\partial}{\partial x} (\delta H) dv = \int_S \frac{\partial f}{\partial H_x} \delta H L_x ds - \int_V \frac{\partial}{\partial x} \left(\frac{\partial f}{\partial H_x} \right) \delta H dv$$

In which L_x is the direction cosine of the normal to the outer surface with the x axis. Performing similar operation on the other terms of Equation A-3 and substituting, it becomes;

$$\delta g = \int_V \delta H \left[\frac{\partial f}{\partial H} - \frac{\partial}{\partial x} \left(\frac{\partial f}{\partial H_x} \right) - \frac{\partial}{\partial y} \left(\frac{\partial f}{\partial H_y} \right) - \frac{\partial}{\partial z} \left(\frac{\partial f}{\partial H_z} \right) \right] dv + \int_C \delta H \left[q + p H + L_x \frac{\partial f}{\partial H_x} + L_y \frac{\partial f}{\partial H_y} + L_z \frac{\partial f}{\partial H_z} \right] ds \quad \text{A-4}$$

The second integral is only taken over the boundary C as on the remainder of surface S we have prescribed values of H and therefore $\delta H = 0$.

For Equation A-4 to be true for any arbitrary variation H first integral should be equal to zero;

$$\frac{\partial f}{\partial H} - \frac{\partial}{\partial x} \left(\frac{\partial f}{\partial H_x} \right) - \frac{\partial}{\partial y} \left(\frac{\partial f}{\partial H_y} \right) - \frac{\partial}{\partial z} \left(\frac{\partial f}{\partial H_z} \right) = 0 \quad \text{A-5a}$$

Everywhere within the region V , and on the boundary C

$$L_x \frac{\partial f}{\partial H_x} + L_y \frac{\partial f}{\partial H_y} + L_z \frac{\partial f}{\partial H_z} = 0 \quad \text{A-5b}$$

These two equations, if satisfied by H , minimize g . If the solution is unique then formulations A-1 and A-5 are equivalent. The above differential equations are known as the Euler equations of the problem.

APPENDIX B

THE GAUSSIAN METHOD

As an example, the solution of three equations and three unknowns is described below:

$$200X - 100Y + 0Z = -8$$

$$-100X + 200Y - 100Z = -8 \quad \text{B-1}$$

$$0X - 100Y + 100Z = -8$$

In matrix form:

$$\begin{bmatrix} 200 & -100 & 0 \\ -100 & 200 & -100 \\ 0 & -100 & 100 \end{bmatrix} \begin{bmatrix} X \\ Y \\ Z \end{bmatrix} = \begin{bmatrix} -8 \\ -8 \\ -8 \end{bmatrix} \quad \text{B-2}$$

Let us first solve this problem as it is in the form of B-2 then reduce it to the banded form.

$$\begin{bmatrix} 200 & -100 & 0 \\ -100 & 200 & -100 \\ 0 & -100 & 100 \end{bmatrix}, \begin{bmatrix} -8 \\ -8 \\ -8 \end{bmatrix}$$

Divide the first row by the diagonal element of the first row.

$$\begin{bmatrix} 1 & -0.5 & 0 \\ -100 & 200 & -100 \\ 0 & -100 & 100 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -8 \\ -8 \end{bmatrix}$$

Multiply the first row by the first element of the second row and subtract the first row from the second row.

$$\begin{bmatrix} 1 & -0.5 & 0 \\ 0 & 150 & 100 \\ 0 & -100 & 100 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -12 \\ -8 \end{bmatrix}$$

This manipulation introduced a zero to the second row, therefore these are two unknowns in the second row. Now divide the second row by the diagonal element of the row.

$$\begin{bmatrix} 1 & -0.5 & 0 \\ 0 & 1 & -2/3 \\ 0 & -100 & 100 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -0.08 \\ -8 \end{bmatrix}$$

Multiply the second row by the second element in the third row and subtract the second row from the third row.

$$\begin{bmatrix} 1 & -0.5 & 0 \\ 0 & 1 & -2/3 \\ 0 & 0 & 100/3 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -0.08 \\ -16 \end{bmatrix}$$

This introduced two zeros to the third row and the third row contains just one unknown. The unknown may now be easily calculated. One may proceed to the second and third rows and calculate all the unknowns. The answer:

$$100/3Z = -16 \qquad Z = -0.48$$

$$Y - 2/3Z = -0.08$$

$$Y - 2/3(-0.48) = -0.08 \qquad Y = -0.4$$

$$X - 0.5Y = -0.4$$

$$X = -0.04 + 0.5(-0.4) = -0.24$$

Now put the upper half band of the coefficient matrix in a new [D] matrix and solve the problem.

D	B
*****	*****
200 -100	-8
200 -100	-8
100 0	-8

For simplicity let us not multiply or divide the first columns by any numbers. At the end substitute 1 for all these elements. Also, due to symmetry of [A], $D(1,2) = A(2,1)$ and $D(2,2) = A(3,2)$.

First store $D(1,2)$ in c, because it is the same as $A(2,1)$ and there is no $A(2,1)$ in our [D] matrix.

Divide the first row by the first element of the first row.

$$\begin{bmatrix} 200 & -0.5 \\ 200 & -100 \\ 100 & 0 \end{bmatrix} \rightarrow \begin{bmatrix} -0.04 \\ -8 \\ -8 \end{bmatrix}$$

Then multiply the first row by the stored value of c and subtract $D(1,2)$ from $D(2,1)$, because these two elements correspond to the same unknown in matrix [A].

$$\begin{bmatrix} 200 & -0.5 \\ 150 & -100 \\ 100 & 0 \end{bmatrix} \rightarrow \begin{bmatrix} -0.04 \\ -12 \\ -8 \end{bmatrix}$$

Now store $D(2,2)$ in c and divide the second row by the first element of the row.

$$\begin{bmatrix} 200 & -0.05 \\ 150 & -2/3 \\ 100 & 0 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -0.08 \\ -8 \end{bmatrix}$$

Multiply the second row by the stored value of c and subtract $D(2,2)$ from $D(3,1)$, because these two elements correspond to the same unknowns.

$$\begin{bmatrix} 200 & -0.5 \\ 150 & -2/3 \\ 100/3 & 0 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -0.08 \\ -16 \end{bmatrix}$$

Divide the third row by the first element.

$$\begin{bmatrix} 200 & -0.5 \\ 150 & -2/3 \\ 100/3 & 0 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -0.08 \\ -0.48 \end{bmatrix}$$

Now substitute 1 for column one.

$$\begin{bmatrix} 1 & -0.5 \\ 1 & -2/3 \\ 1 & 0 \end{bmatrix}, \begin{bmatrix} -0.04 \\ -0.08 \\ -0.48 \end{bmatrix}$$

This is the same result as before in banded form. Therefore, the problem has been solved by the use of a simpler method and also it saved memory space. Fig. 3.1 shows a flow chart of such a program.




Figure B. Flow chart, subroutine "SOLVE".




Figure B. (Continued)

APPENDIX C

CALCULATION OF CURRENT DENSITY

The equation for mutual impedance (6) between two infinitely long conductors, at heights h_1 and h_2 meters above the earth, and separated by a horizontal distance of y_1 meters, in the power series form is:

$$\begin{aligned}
 Z_{12}(h_1, 0, y_1) = & \frac{j\omega\mu_0}{4\pi} \left[\ln\left(\frac{4}{h_1'^2 + y_1'^2}\right) + 1 - 2\gamma \right] + \frac{\omega\mu_0}{8} - \\
 & (1 - j) \frac{\omega\mu_0 h_1'}{3\sqrt{2}\pi} - \frac{j\omega\mu_0 (h_1'^2 - y_1'^2)}{64} - \\
 & \frac{\omega\mu_0 (h_1'^2 - y_1'^2)}{32\pi} \left[\ln\left(\frac{h_1'^2 + y_1'^2}{4}\right) + 2\gamma - 5/2 \right] \quad \text{C-1}
 \end{aligned}$$

Where γ is Euler's number, 0.577216

$$h_1' = h_1 \sqrt{\omega\mu_0 \sigma_1} \quad , \quad h_2' = h_2 \sqrt{\omega\mu_0 \sigma_1} \quad , \quad y_1' = y_1 \sqrt{\omega\mu_0 \sigma_1}$$

and current density equation is:

$$J = Z_{12}(h_1, 0, y_1) * \sigma * I_{sc} \quad \text{C-2}$$

Based on equations C-1 and C-2, impedances and current densities on the surface of the earth for various values of y and different values of ρ are calculated and given in Tables C.1 to C.3.

The worst case is for $y = 0$ and the current density for such value of y is 0.07 amp per square meter.

TABLE C.1

CALCULATED CURRENT DENSITIES ON THE
SURFACE OF THE EARTH

DISTANCE FROM CENT	REAL PART IMPEDANCE	IMAGINARY IMPEDANCE	MUTUAL	ANGLE	CURRENT DENSITY	PER SQ. METER
0.0	.5601E-04	.2450E-03	.2523E-03	77.0	0.504623	AMP. PER SQ. METER
10.0	.5663E-04	.2221E-03	.2292E-03	75.7	0.458480	AMP. PER SQ. METER
20.0	.5619E-04	.1892E-03	.1974E-03	73.5	0.394761	AMP. PER SQ. METER
30.0	.5559E-04	.1630E-03	.1730E-03	71.2	0.345908	AMP. PER SQ. METER
40.0	.5487E-04	.1442E-03	.1543E-03	69.2	0.308631	AMP. PER SQ. METER
50.0	.5404E-04	.1286E-03	.1395E-03	67.2	0.279052	AMP. PER SQ. METER
60.0	.5313E-04	.1158E-03	.1274E-03	65.4	0.254778	AMP. PER SQ. METER
70.0	.5215E-04	.1049E-03	.1172E-03	63.6	0.234338	AMP. PER SQ. METER
80.0	.5112E-04	.9558E-04	.1084E-03	61.9	0.216790	AMP. PER SQ. METER
90.0	.5005E-04	.8744E-04	.1007E-03	60.2	0.201498	AMP. PER SQ. METER
100.0	.4895E-04	.8026E-04	.9401E-04	58.6	0.188018	AMP. PER SQ. METER
110.0	.4783E-04	.7398E-04	.8801E-04	57.1	0.176028	AMP. PER SQ. METER
120.0	.4670E-04	.6818E-04	.8264E-04	55.6	0.165285	AMP. PER SQ. METER
130.0	.4556E-04	.6307E-04	.7780E-04	54.2	0.155608	AMP. PER SQ. METER
140.0	.4442E-04	.5846E-04	.7343E-04	52.8	0.146854	AMP. PER SQ. METER
150.0	.4330E-04	.5431E-04	.6945E-04	51.4	0.138908	AMP. PER SQ. METER
160.0	.4219E-04	.5055E-04	.6584E-04	50.2	0.131481	AMP. PER SQ. METER
170.0	.4109E-04	.4716E-04	.6255E-04	48.9	0.125098	AMP. PER SQ. METER
180.0	.4003E-04	.4409E-04	.5955E-04	47.8	0.119100	AMP. PER SQ. METER
190.0	.3899E-04	.4132E-04	.5682E-04	46.7	0.113636	AMP. PER SQ. METER
200.0	.3800E-04	.3884E-04	.5433E-04	45.6	0.108664	AMP. PER SQ. METER
210.0	.3704E-04	.3660E-04	.5208E-04	44.7	0.104151	AMP. PER SQ. METER
220.0	.3613E-04	.3461E-04	.5003E-04	43.8	0.100066	AMP. PER SQ. METER
230.0	.3526E-04	.3285E-04	.4819E-04	43.0	0.096386	AMP. PER SQ. METER
240.0	.3445E-04	.3129E-04	.4654E-04	42.2	0.093089	AMP. PER SQ. METER
250.0	.3370E-04	.2994E-04	.4508E-04	41.6	0.090159	AMP. PER SQ. METER
260.0	.3301E-04	.2878E-04	.4379E-04	41.1	0.087581	AMP. PER SQ. METER
270.0	.3238E-04	.2779E-04	.4267E-04	40.6	0.085345	AMP. PER SQ. METER
280.0	.3182E-04	.2698E-04	.4172E-04	40.3	0.083441	AMP. PER SQ. METER
290.0	.3133E-04	.2634E-04	.4093E-04	40.1	0.081861	AMP. PER SQ. METER
300.0	.3091E-04	.2586E-04	.4030E-04	39.9	0.080600	AMP. PER SQ. METER

TABLE C.2

CALCULATED CURRENT DENSITIES ON THE
SURFACE OF THE EARTH

DISTANCE FROM CENT	REAL PART IMPEDANCE	IMAGINARY IMPEDANCE	MUTUAL	ANGLE	CURRENT DENSITY	AMP. PER SQ. METER
0.0	.5042E-04	.3309E-03	.3360E-03	80.0	0.067201	AMP. PER SQ. METER
10.0	.5040E-04	.3072E-03	.3127E-03	79.2	0.062532	AMP. PER SQ. METER
20.0	.5034E-04	.2741E-03	.2803E-03	78.0	0.056056	AMP. PER SQ. METER
30.0	.5025E-04	.2485E-03	.2553E-03	76.8	0.051057	AMP. PER SQ. METER
40.0	.5014E-04	.2288E-03	.2361E-03	75.7	0.047211	AMP. PER SQ. METER
50.0	.5001E-04	.2129E-03	.2207E-03	74.8	0.044133	AMP. PER SQ. METER
60.0	.5078E-04	.1997E-03	.2079E-03	73.8	0.041583	AMP. PER SQ. METER
70.0	.5770E-04	.1884E-03	.1971E-03	73.0	0.039414	AMP. PER SQ. METER
80.0	.5752E-04	.1786E-03	.1877E-03	72.1	0.037530	AMP. PER SQ. METER
90.0	.5733E-04	.1699E-03	.1793E-03	71.4	0.035869	AMP. PER SQ. METER
100.0	.5712E-04	.1622E-03	.1719E-03	70.6	0.034385	AMP. PER SQ. METER
110.0	.5690E-04	.1551E-03	.1652E-03	69.9	0.033045	AMP. PER SQ. METER
120.0	.5667E-04	.1487E-03	.1591E-03	69.1	0.031826	AMP. PER SQ. METER
130.0	.5643E-04	.1428E-03	.1535E-03	68.4	0.030707	AMP. PER SQ. METER
140.0	.5617E-04	.1373E-03	.1484E-03	67.8	0.029676	AMP. PER SQ. METER
150.0	.5591E-04	.1323E-03	.1436E-03	67.1	0.028719	AMP. PER SQ. METER
160.0	.5564E-04	.1275E-03	.1391E-03	66.4	0.027827	AMP. PER SQ. METER
170.0	.5536E-04	.1231E-03	.1350E-03	65.8	0.026994	AMP. PER SQ. METER
180.0	.5508E-04	.1189E-03	.1311E-03	65.1	0.026211	AMP. PER SQ. METER
190.0	.5478E-04	.1150E-03	.1274E-03	64.5	0.025474	AMP. PER SQ. METER
200.0	.5448E-04	.1113E-03	.1239E-03	63.9	0.024778	AMP. PER SQ. METER
210.0	.5417E-04	.1077E-03	.1206E-03	63.3	0.024119	AMP. PER SQ. METER
220.0	.5386E-04	.1044E-03	.1175E-03	62.7	0.023494	AMP. PER SQ. METER
230.0	.5355E-04	.1012E-03	.1145E-03	62.1	0.022900	AMP. PER SQ. METER
240.0	.5322E-04	.9817E-04	.1117E-03	61.5	0.022334	AMP. PER SQ. METER
250.0	.5290E-04	.9527E-04	.1090E-03	61.0	0.021794	AMP. PER SQ. METER
260.0	.5256E-04	.9250E-04	.1064E-03	60.4	0.021278	AMP. PER SQ. METER
270.0	.5223E-04	.8984E-04	.1039E-03	59.8	0.020784	AMP. PER SQ. METER
280.0	.5189E-04	.8730E-04	.1016E-03	59.3	0.020311	AMP. PER SQ. METER
290.0	.5155E-04	.8485E-04	.9928E-04	58.7	0.019857	AMP. PER SQ. METER
300.0	.5120E-04	.8251E-04	.9710E-04	58.2	0.019421	AMP. PER SQ. METER

TABLE C.3

CALCULATED CURRENT DENSITIES ON THE
SURFACE OF THE EARTH

DISTANCE FROM CENT	REAL PART IMPEDANCE	IMAGINARY IMPEDANCE	MUTUAL	ANGLE	CURRENT DENSITY	PER SQ. METER
0.0	.5896E-04	.4171E-03	.4213E-03	82.0	0.008426	AMP. PER SQ. METER
10.0	.5896E-04	.3978E-03	.3978E-03	81.5	0.007956	AMP. PER SQ. METER
20.0	.5895E-04	.3604E-03	.3652E-03	80.7	0.007303	AMP. PER SQ. METER
30.0	.5894E-04	.3348E-03	.3399E-03	80.0	0.006798	AMP. PER SQ. METER
40.0	.5893E-04	.3150E-03	.3204E-03	79.4	0.006409	AMP. PER SQ. METER
50.0	.5891E-04	.2991E-03	.3048E-03	78.9	0.006096	AMP. PER SQ. METER
60.0	.5889E-04	.2859E-03	.2918E-03	78.4	0.005837	AMP. PER SQ. METER
70.0	.5886E-04	.2745E-03	.2808E-03	77.9	0.005615	AMP. PER SQ. METER
80.0	.5884E-04	.2647E-03	.2711E-03	77.5	0.005422	AMP. PER SQ. METER
90.0	.5881E-04	.2559E-03	.2626E-03	77.1	0.005252	AMP. PER SQ. METER
100.0	.5878E-04	.2481E-03	.2550E-03	76.7	0.005099	AMP. PER SQ. METER
110.0	.5875E-04	.2410E-03	.2480E-03	76.3	0.004961	AMP. PER SQ. METER
120.0	.5871E-04	.2345E-03	.2417E-03	75.9	0.004835	AMP. PER SQ. METER
130.0	.5867E-04	.2285E-03	.2359E-03	75.6	0.004718	AMP. PER SQ. METER
140.0	.5864E-04	.2230E-03	.2305E-03	75.3	0.004611	AMP. PER SQ. METER
150.0	.5859E-04	.2178E-03	.2255E-03	74.9	0.004511	AMP. PER SQ. METER
160.0	.5855E-04	.2130E-03	.2209E-03	74.6	0.004417	AMP. PER SQ. METER
170.0	.5851E-04	.2084E-03	.2165E-03	74.3	0.004330	AMP. PER SQ. METER
180.0	.5846E-04	.2041E-03	.2123E-03	74.0	0.004247	AMP. PER SQ. METER
190.0	.5841E-04	.2001E-03	.2084E-03	73.7	0.004169	AMP. PER SQ. METER
200.0	.5836E-04	.1963E-03	.2047E-03	73.4	0.004095	AMP. PER SQ. METER
210.0	.5831E-04	.1926E-03	.2012E-03	73.2	0.004025	AMP. PER SQ. METER
220.0	.5826E-04	.1891E-03	.1979E-03	72.9	0.003958	AMP. PER SQ. METER
230.0	.5820E-04	.1858E-03	.1947E-03	72.6	0.003894	AMP. PER SQ. METER
240.0	.5815E-04	.1826E-03	.1916E-03	72.3	0.003833	AMP. PER SQ. METER
250.0	.5809E-04	.1795E-03	.1887E-03	72.1	0.003774	AMP. PER SQ. METER
260.0	.5803E-04	.1766E-03	.1859E-03	71.8	0.003718	AMP. PER SQ. METER
270.0	.5797E-04	.1738E-03	.1832E-03	71.6	0.003664	AMP. PER SQ. METER
280.0	.5790E-04	.1711E-03	.1806E-03	71.3	0.003612	AMP. PER SQ. METER
290.0	.5784E-04	.1684E-03	.1781E-03	71.0	0.003562	AMP. PER SQ. METER
300.0	.5778E-04	.1659E-03	.1757E-03	70.8	0.003514	AMP. PER SQ. METER

APPENDIX D

LISTING OF PROGRAMS AND SUBROUTINES

Listing of Programs:

MAIN
GOOD
TES
SEARCH

and Subroutines:

BAND
PROPT
FIND
SOLVE

PROGRAM MAIN

```

COMMON A(401,20),N(3,760),XN(3,760),YN(3,760),MAT(760),IEL(760)
COMMON B(401),V(403)
INTEGER N,NODE,LNODE,IEL,IELE
COMPLEX A,B,PROP,P1,P2,P3,V,BCV
C
P1=(1.8182E-04,3.542E-11)
P2=(30.0E-00,0.00E+01)
P3=(3.0E-03,7.4374E-10)
C
C IBW - BAND-WIDTH OF THE COEFFICIENT MATRIX
C NODE - NUMBER OF NODES
C LNODE- NUMBER OF LAST NODE BEFORE THE NODE WITH BOUNDARY COND.
C IEL - NAME OF MATRIX WHICH STORES ELEMENTS NUMBER
C IELE - NUMBER OF ELEMENTS
C
C
C
1 READ(15,1)NODE,IELE,LNODE,BCV
C FORMAT(I3,1X,I3,1X,I3,2(1X,F7.3))
C
C WRITE(66,69)P1
C WRITE(66,69)P2
C WRITE(66,69)P3
69 FORMAT(2(1X,E14.6))
C
C IBW=0
C DO 20 I=1,IELE
C READ(15,2)IEL(I),N(1,I),N(2,I),N(3,I),XN(1,I),YN(1,I),XN(2,I),YN(2
C,I),XN(3,I),YN(3,I),MAT(I)
C
C
C 2 FORMAT(I3,3(1X,I3),6(1X,F8.3),1X,I1)
C
C 20 CONTINUE
C
C DO 22 I=1,IELE
C
C THIS SUBROUTINE FINDS THE BAND-WIDTH OF THE MATRIX
C
C 22 CALL BAND(N,I,LNODE,IBW)
C
C
C DO 60 I=1,LNODE
C DO 60 J=1,IBW
60 A(I,J)=(0.0,0.0)
C DO 199 KK=1,LNODE
199 V(KK)=(0.0,0.0)
C V(LNODE+1)=(0.0,0.0)
C V(LNODE+2)=BCV
C DO 190 K=1,IELE
C
C SUBROUTINE PROPT FINDS THE PROPERT OF MATERIALS AND AREA OF THE
C ELEMENT.

```


PROGRAM MAIN (CONT.)

```
CALL PROPT(MAT,K,PROP,P3,P1,P2,S,XN,YN)
```

```
C  
C  
C  
C  
C
```

```
THIS SUBROUTINE FINDS THE COEFFICIENT MATRIX AND CONSTANTS.
```

```
CALL FIND(N,K,LNODE,YN,XN,S,PROP,B,V,A)
```

```
C
```

```
190 CONTINUE
```

```
C  
C  
C  
C  
C  
C
```

```
THIS SUBROUTINE CALCULATES THE VOLTAGES AT EACH NODES.
```

```
CALL SOLVE(LNODE,IBW,A,B)
```

```
CALL RESULT(BCV,B)
```

```
C
```

```
C
```

```
1000 CONTINUE
```

```
STOP
```

```
END
```

PROGRAM GOOD

```
DIMENSION X(401),Y(401),XX(17),YY(17)
READ(15,2)L,M,NX,NY
2  FORMAT(4I3)
DO 10 I=1,NX
10 READ(15,1)XX(I)
DO 20 I=1,NY
20 READ(15,1)YY(I)
1  FORMAT(F8.3)
   J=0
   L1=1
   DO 30 I=L,M
     J=J+1
     X(I)=XX(J)
     Y(I)=YY(L1)
     I1=I-L+1
     IF(I1,LT,NX) GO TO 30
     P=I1/FLOAT(NX)
     L1=IFIX(P)
     P=P-L1
     IF(P,EQ,0.0) GO TO 35
     GO TO 36
35  J=0
   36 L1=L1+1
30  CONTINUE
   DO 50 I=L,M
50  WRITE(16,3)I,X(I),Y(I)
   3  FORMAT(3X,13,2(2X,F8.3))
```

PROGRAM TES

```

DIMENSION N(3,760),XN(3,760),YN(3,760),MAT(760),IEL(760),X(401)
DIMENSION Y(401)
DO 5 I=1,401
5 READ(13,1)KK,X(I),Y(I)
1 FORMAT(3X,I3,2(2X,F8.3))
DO 10 I=17,744
READ(14,2)IEL(I),N(1,I),N(2,I),N(3,I),MAT(I)
2 FORMAT(I3,3(1X,I3),1X,I1)
L=N(1,I)
J=N(2,I)
K=N(3,I)
XN(1,I)=X(L)
YN(1,I)=Y(L)
XN(2,I)=X(J)
YN(2,I)=Y(J)
XN(3,I)=X(K)
YN(3,I)=Y(K)
10 CONTINUE
DO 20 I=1,16
20 READ(16,3)IEL(I),N(1,I),N(2,I),N(3,I),XN(1,I),YN(1,I),XN(2,I),YN(2
3 I),XN(3,I),YN(3,I),MAT(I)
FORMAT(I3,3(1X,I3),6(1X,F8.3),1X,I1)
DO 40 I=745,760
40 READ(16,3)IEL(I),N(1,I),N(2,I),N(3,I),XN(1,I),YN(1,I),XN(2,I),YN(2
C,I),XN(3,I),YN(3,I),MAT(I)
DO 100 I=1,760
100 WRITE(17,4)IEL(I),N(1,I),N(2,I),N(3,I),XN(1,I),YN(1,I),XN(2,I),YN(
C2,I),XN(3,I),YN(3,I),MAT(I)
4 FORMAT(I3,3(1X,I3),6(1X,F8.3),1X,I1)
STOP
END

```

PROGRAM SEARCH

```

PIE=3.1415926
W=377.0
XMU=4*PIE*(10E-8)
ZEGMA=0.1
GAMA=0.577216
H1=10.68
H=H1*SQRT(W*XMU*ZEGMA)
WRITE(15,1)
WRITE(15,2)
1  FORMAT(2X,"DISTANCE",4X,"REAL PART",5X,"IMAGINARY",5X," MUTUAL "
C,5X,"ANGLE",3X,"CURRENT")
2  FORMAT(2X,"FROM CENT",3X,"IMPEDANCE",5X,"IMPEDANCE",26X,"DENSITY")
DO 99 N=0,30
Y1=N*10.0
Y=Y1*SQRT(W*XMU*ZEGMA)
A=H**2+Y**2
B=H**2-Y**2
C=A*LOG(A/4)
D=A*LOG(4/A)
REAL1=(1.0/8.0)-(H/(4.24264*PIE))-((B/(32*PIE))*(C+2*GAMA-2.5))
XIMAG1=((D+1.0-2*GAMA)/(4*PIE))+((H/(4.24264*PIE))-(B/64))
REAL=W*XMU*REAL1
XIMAG=W*XMU*XIMAG1
Z=SQRT(REAL**2+XIMAG**2)
PHI=ATAN(XIMAG/REAL)
PHI=PHI*(180.0/PIE)
XJ=Z*ZEGMA*20000.0
WRITE(15,3)Y1,REAL,XIMAG,Z,PHI,XJ
3  FORMAT(2X,F6.1,5X,E9.4,5X,E9.4,5X,E9.4,5X,F5.1,3X,F8.6,2X,
C"AMP. PER SQ. METER")
99  CONTINUE
STOP
END

```

SUBROUTINE BAND

```
SUBROUTINE BAND(N,I,LNODE,IBW)
DIMENSION N(3,760)
IF(N(1,I).GT.LNODE) GO TO 60
IF(N(2,I).GT.LNODE) GO TO 60
IF(N(3,I).GT.LNODE) GO TO 60
IB1=ABS(N(1,I)-N(2,I))
IB2=ABS(N(2,I)-N(3,I))
IB3=ABS(N(1,I)-N(3,I))
IF(IB1.LT.IB2) GO TO 40
IF(IB1.LT.IB3) GO TO 45
IBW1=IB1+1
GO TO 50
40 IF(IB2.LT.IB3) GO TO 45
IBW1=IB2+1
GO TO 50
45 IBW1=IB3+1
50 IF(IBW.LT.IBW1) GO TO 55
GO TO 60
55 IBW=IBW1
IBW1=0
60 RETURN
END
```

SUBROUTINE PROPT

```
SUBROUTINE PROPT(MAT,K,PROP,P3,P1,P2,S,XN,YN)
DIMENSION MAT(760),XN(3,760),YN(3,760)
COMPLEX PROP,P1,P2,P3
IF(MAT(K).EQ.1) GO TO 10
IF(MAT(K).EQ.2) GO TO 20
PROP=P3
GO TO 30
10 PROP=P1
GO TO 30
20 PROP=P2
30 S=2*((XN(1,K)*YN(2,K)-XN(2,K)*YN(1,K))+(XN(2,K)*YN(3,K)-XN(3,K)*YN
C(2,K))+(XN(3,K)*YN(1,K)-XN(1,K)*YN(3,K)))
RETURN
END
```

SUBROUTINE FIND

```

SUBROUTINE FIND(N,K,LNODE,YN,XN,S,PROP,B,U,A)
DIMENSION A(401,20),V(403),B(401),N(3,760),XN(3,760),YN(3,760)
COMPLEX PROP,A,B,X,U
DO 99 M=1,3
DO 90 I=1,3
IF(M.EQ.I) GO TO 80
IF((N(M,K)-N(I,K)).GT.0) GO TO 90
IF(M.EQ.1) GO TO 68
IF(M.EQ.2) GO TO 85
IF(I.EQ.1) GO TO 82
GO TO 83
68 IF(I.EQ.2) GO TO 81
GO TO 82
85 IF(I.EQ.1) GO TO 81
GO TO 83
81 IF(N(M,K).LE.LNODE) GO TO 181
GO TO 90
181 IF(N(I,K).LE.LNODE) GO TO 281
X=(((YN(2,K)-YN(3,K))*(YN(3,K)-YN(1,K))+(XN(2,K)-XN(3,K))*(XN(3,K)
C-XN(1,K)))/S)*PROP
MM=N(I,K)
NN=N(M,K)
B(NN)=-X*V(MM)+B(NN)
GO TO 90
82 IF(N(M,K).LE.LNODE) GO TO 182
GO TO 90
182 IF(N(I,K).LE.LNODE) GO TO 282
X=(((YN(2,K)-YN(3,K))*(YN(1,K)-YN(2,K))+(XN(2,K)-XN(3,K))*(XN(1,K)
C-XN(2,K)))/S)*PROP
MM=N(I,K)
NN=N(M,K)
B(NN)=-X*V(MM)+B(NN)
GO TO 90
83 IF(N(M,K).LE.LNODE) GO TO 183
GO TO 90
183 IF(N(I,K).LE.LNODE) GO TO 283
X=(((YN(3,K)-YN(1,K))*(YN(1,K)-YN(2,K))+(XN(3,K)-XN(1,K))*(XN(1,K)
C-XN(2,K)))/S)*PROP
MM=N(I,K)
NN=N(M,K)
B(NN)=-X*V(MM)+B(NN)
GO TO 90
281 MM=N(I,K)-N(M,K)+1
NN=N(M,K)
A(NN,MM)=(((YN(2,K)-YN(3,K))*(YN(3,K)-YN(1,K))+(XN(2,K)-XN(3,K))*
CXN(3,K)-XN(1,K)))/S)*PROP+A(NN,MM)
GO TO 90
282 MM=N(I,K)-N(M,K)+1
NN=N(M,K)
A(NN,MM)=(((YN(2,K)-YN(3,K))*(YN(1,K)-YN(2,K))+(XN(2,K)-XN(3,K))*
CXN(1,K)-XN(2,K)))/S)*PROP+A(NN,MM)

```

SUBROUTINE FIND(CONT.)

```
-----  
      GO TO 90  
283  MM=N(I,K)-N(M,K)+1  
      NN=N(M,K)  
      A(NN,MM)=(((YN(3,K)-YN(1,K))*(YN(1,K)-YN(2,K))+(XN(3,K)-XN(1,K))*  
CXN(1,K)-XN(2,K)))/S)*PROP+A(NN,MM)  
      GO TO 90  
80   IF(N(M,K).GT.LNODE) GO TO 90  
      IF(M.EQ.1) GO TO 51  
      IF(M.EQ.2) GO TO 52  
      MM=N(M,K)  
      A(MM,1)=(((YN(1,K)-YN(2,K))**2)+(XN(1,K)-XN(2,K))**2)/S)*PROP+A(M  
CM,1)  
      GO TO 90  
51   MM=N(M,K)  
      A(MM,1)=(((YN(2,K)-YN(3,K))**2)+(XN(2,K)-XN(3,K))**2)/S)*PROP+A(M  
CM,1)  
      GO TO 90  
52   MM=N(M,K)  
      A(MM,1)=(((YN(3,K)-YN(1,K))**2)+(XN(3,K)-XN(1,K))**2)/S)*PROP+A(M  
CM,1)  
90   CONTINUE  
99   CONTINUE  
      RETURN  
      END
```


SUBROUTINE SOLVE

```

SUBROUTINE SOLVE(NSIZE,MBAND,A,B)
DIMENSION A(401,20),B(401)
COMPLEX A,B,C
C FORWARD REDUCTION OF MATRIX(GAUSS ELIMINATION)
DO 100 N=1,NSIZE
DO 200 L=2,MBAND
IF(A(N,L).EQ.(0.0,0.0)) GO TO 200
I=N+L-1
C=A(N,L)/A(N,1)
J=0
DO 30 K=L,MBAND
J=J+1
30 A(I,J)=A(I,J)-C*A(N,K)
A(N,L)=C
200 CONTINUE
100 CONTINUE
C FORWARD REDUCTION OF CONSTANTS
DO 10 N=1,NSIZE
DO 20 L=2,MBAND
IF(A(N,L).EQ.(0.0,0.0)) GO TO 20
I=N+L-1
B(I)=B(I)-A(N,L)*B(N)
20 CONTINUE
10 B(N)=B(N)/A(N,1)
C SOLVE FOR UNKOWNS BY BACK-SUBSTITUTION
DO 40 M=2,NSIZE
N=NSIZE+1-M
DO 50 L=2,MBAND
IF(A(N,L).EQ.(0.0,0.0)) GO TO 50
K=N+L-1
B(N)=B(N)-A(N,L)*B(K)
50 CONTINUE
40 CONTINUE
RETURN
END

```

APPENDIX E

COMPUTER RESULTS

TABLE E.1

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 55.00 OHM-METER WATER CONDUCTIVITY= 30 MICRO-MHO/CM

FOOL TYPE: REINFORCED MAXIMUM VOLTAGE= 17.080VOLTS

TOTAL CURRENT=140.4 MILI AMPS

ST NO	X(M)	Z(CM)	Y(CM)	****		****		****		****		****		MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	CURRENT DENSITY
				VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY			
1	0.00	5.0	63.5	17.080	660.4	17.080	800.1	17.080	1079.5	17.080	1079.5	17.080	88.465			
2	1.52	5.0	63.5	16.358	660.4	16.343	800.1	16.341	1079.5	16.338	1079.5	16.338	88.791			
3	4.57	5.0	63.5	14.919	660.4	14.868	800.1	14.859	1079.5	14.850	1079.5	14.850	89.979			
4	7.11	5.0	63.5	13.738	660.4	13.634	800.1	13.613	1079.5	13.593	1079.5	13.593	93.267			
5	11.43	5.0	63.5	11.800	660.4	11.524	800.1	11.446	1079.5	11.378	1079.5	11.378	106.939			
6	15.75	5.0	63.5	10.100	660.4	9.462	800.1	9.000	1079.5	8.838	1079.5	8.838	111.310			
7	16.26	5.0	63.5	9.936	660.4	9.293	800.1	8.527	1079.5	8.527	1079.5	8.527	*****			
8	16.45	5.0	63.5	9.876	660.4	9.238	800.1	8.527	1079.5	*****	1079.5	*****	*****			
9	21.84	5.0	63.5	8.528	660.4	8.527	800.1	8.527	1079.5	*****	1079.5	*****	*****			
10	27.24	5.0	63.5	7.182	660.4	7.817	800.1	8.526	1079.5	*****	1079.5	*****	*****			
11	27.43	5.0	63.5	7.123	660.4	7.762	800.1	8.526	1079.5	*****	1079.5	*****	*****			
12	27.94	5.0	63.5	6.960	660.4	7.595	800.1	8.055	1079.5	8.216	1079.5	8.216	110.988			
13	32.26	5.0	63.5	5.264	660.4	5.539	800.1	5.616	1079.5	5.684	1079.5	5.684	106.590			
14	36.58	5.0	63.5	3.332	660.4	3.436	800.1	3.456	1079.5	3.476	1079.5	3.476	92.964			
15	39.12	5.0	63.5	2.154	660.4	2.206	800.1	2.214	1079.5	2.224	1079.5	2.224	89.1692			
16	42.16	5.0	63.5	0.720	660.4	0.735	800.1	0.738	1079.5	0.740	1079.5	0.740	88.483			
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	1079.5	0.000	1079.5	0.000	88.305			

TABLE E.2

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 55.00 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MHO/CM

FOOL TYPE: REINFORCED MAXIMUM VOLTAGE= 17.080VOLTS

TOTAL CURRENT=141.0 MILLI AMPS

ST NO	X (M)	Z (CM)	Y (CM)	***A**		***B**		***C**		***D**	
				VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY
				MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER	
1	0.00	5.0	63.5	17.080	660.4	17.080	800.1	17.080	1079.5	17.080	88.465
2	1.52	5.0	63.5	16.358	660.4	16.343	800.1	16.341	1079.5	16.338	88.465
3	4.57	5.0	63.5	14.919	660.4	14.868	800.1	14.859	1079.5	14.850	88.791
4	7.11	5.0	63.5	13.738	660.4	13.634	800.1	13.613	1079.5	13.593	89.979
5	11.43	5.0	63.5	11.800	660.4	11.524	800.1	11.446	1079.5	11.378	93.267
6	15.75	5.0	63.5	10.100	660.4	9.462	800.1	9.000	1079.5	8.838	106.935
7	16.26	5.0	63.5	9.936	660.4	9.293	800.1	8.527	1079.5	8.527	111.346
8	16.45	5.0	63.5	9.876	660.4	9.238	800.1	8.527	1079.5	8.527	111.346
9	21.84	5.0	63.5	8.528	660.4	8.527	800.1	8.527	1079.5	8.527	111.346
10	27.24	5.0	63.5	7.182	660.4	7.817	800.1	8.526	1079.5	8.526	111.346
11	27.43	5.0	63.5	7.123	660.4	7.762	800.1	8.526	1079.5	8.526	111.346
12	27.94	5.0	63.5	6.960	660.4	7.595	800.1	8.055	1079.5	8.216	110.952
13	32.26	5.0	63.5	5.264	660.4	5.539	800.1	5.617	1079.5	5.684	106.594
14	36.58	5.0	63.5	3.332	660.4	3.436	800.1	3.456	1079.5	3.476	92.964
15	39.12	5.0	63.5	2.154	660.4	2.206	800.1	2.214	1079.5	2.224	89.692
16	42.16	5.0	63.5	0.720	660.4	0.735	800.1	0.738	1079.5	0.740	88.483
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	1079.5	0.000	88.305

TABLE E.3

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 55.00 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE= 17.080VOLTS

TOTAL CURRENT=141.0 MILLI AMPS

ST NO	X(M)	Y(CM)	Z(CM)	***A**		***B**		***C**		***D**	
				VOLTS	CURRENT DENSITY	VOLTS	CURRENT DENSITY	VOLTS	CURRENT DENSITY	VOLTS	CURRENT DENSITY
				MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER	
1	0.00	5.0	63.5	17.080	660.4	17.080	800.1	17.080	1079.5	17.080	88.465
2	1.52	5.0	63.5	16.358	660.4	16.343	87.869	16.341	88.107	16.338	88.791
3	4.57	5.0	63.5	14.920	660.4	14.868	88.015	14.859	88.433	14.850	89.979
4	7.11	5.0	63.5	13.738	660.4	13.634	88.332	13.613	89.191	13.593	93.267
5	11.43	5.0	63.5	11.800	660.4	11.524	88.846	11.446	91.246	11.378	106.935
6	15.75	5.0	63.5	10.100	660.4	9.462	86.837	9.000	102.990	8.838	111.346
7	16.26	5.0	63.5	9.936	660.4	9.293	60.200	8.527	169.256	8.527	*****
8	16.45	5.0	63.5	9.876	660.4	9.238	52.589	8.527	0.000	*****	*****
9	21.84	5.0	63.5	8.528	660.4	8.527	23.961	8.527	0.020	*****	*****
10	27.24	5.0	63.5	7.182	660.4	7.817	23.907	8.526	0.024	*****	*****
11	27.43	5.0	63.5	7.123	660.4	7.763	52.398	8.526	0.000	*****	*****
12	27.94	5.0	63.5	6.960	660.4	7.595	60.021	8.055	168.647	8.216	110.988
13	32.26	5.0	63.5	5.264	660.4	5.539	86.559	5.617	102.661	5.684	106.594
14	36.58	5.0	63.5	3.332	660.4	3.436	88.560	3.456	90.976	3.476	92.964
15	39.12	5.0	63.5	2.154	660.4	2.206	88.067	2.214	88.869	2.224	89.692
16	42.16	5.0	63.5	0.720	660.4	0.735	87.712	0.738	88.095	0.740	88.483
17	43.69	5.0	63.5	0.000	660.4	0.000	87.712	0.000	88.006	0.000	88.305

TABLE E.4

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY= 30 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=138.4 MILLI AMPS

ST NO	X(M)	Y(CM)	Z(CM)	***A**			***B**			***C**			***D**					
				VOLTAGE	CURRENT Y(CM) DENSITY	VOLTS	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTS	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTS	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTS	VOLTAGE	CURRENT Y(CM) DENSITY	
				MILI AMP PER SQ.METER			MILI AMP PER SQ.METER			MILI AMP PER SQ.METER			MILI AMP PER SQ.METER			MILI AMP PER SQ.METER		
1	0.00	5.0	63.5	18.300	660.4	18.300	800.1	18.300	1079.5	18.300	65.353	1079.5	17.708	65.243				
2	1.52	5.0	63.5	17.701	660.4	17.706	800.1	17.707	1079.5	17.708	65.307	1079.5	16.527	65.142				
3	4.57	5.0	63.5	16.500	660.4	16.519	800.1	16.523	1079.5	16.527	65.110	1079.5	15.550	64.646				
4	7.11	5.0	63.5	15.494	660.4	15.531	800.1	15.539	1079.5	15.550	64.417	1079.5	13.930	63.054				
5	11.43	5.0	63.5	13.758	660.4	13.851	800.1	13.884	1079.5	13.930	61.809	1079.5	12.528	54.569				
6	15.75	5.0	63.5	11.942	660.4	12.129	800.1	12.296	1079.5	12.528	71.462	1079.5	12.437	30.107				
7	16.26	5.0	63.5	11.718	660.4	11.897	800.1	12.080	1079.5	12.437	86.460	1079.5	*****	*****				
8	16.45	5.0	63.5	11.633	660.4	11.808	800.1	11.982	1079.5	12.437	88.183	1079.5	*****	*****				
9	21.84	5.0	63.5	9.150	660.4	9.150	800.1	9.150	1079.5	12.437	88.170	1079.5	*****	*****				
10	27.24	5.0	63.5	6.667	660.4	6.492	800.1	6.318	1079.5	12.437	87.166	1079.5	*****	*****				
11	27.43	5.0	63.5	6.583	660.4	6.403	800.1	6.220	1079.5	12.437	71.230	1079.5	5.772	30.073				
12	27.94	5.0	63.5	6.358	660.4	6.171	800.1	6.004	1079.5	5.772	61.832	1079.5	4.370	54.558				
13	32.26	5.0	63.5	4.542	660.4	4.449	800.1	4.416	1079.5	4.370	64.424	1079.5	2.750	63.058				
14	36.58	5.0	63.5	2.806	660.4	2.769	800.1	2.760	1079.5	2.750	65.063	1079.5	1.773	64.640				
15	39.12	5.0	63.5	1.800	660.4	1.781	800.1	1.777	1079.5	1.773	65.289	1079.5	0.592	65.118				
16	42.16	5.0	63.5	0.600	660.4	0.594	800.1	0.593	1079.5	0.592	65.413	1079.5	0.000	65.291				
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	1079.5	0.000								

TABLE E.5

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=1600 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=142.7 MILLI AMPS

ST NO	X(M)	Y(CM)	Z(CM)	****		***B**		**C**		**D**		CURRENT DENSITY
				VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	
				MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER
1	0.00	5.0	63.5	18.300	660.4	18.300	800.1	18.300	1079.5	18.300	1079.5	81.223
2	1.52	5.0	63.5	17.577	660.4	17.566	800.1	17.565	1079.5	17.563	1079.5	81.524
3	4.57	5.0	63.5	16.134	660.4	16.098	800.1	16.092	1079.5	16.085	1079.5	82.313
4	7.11	5.0	63.5	14.943	660.4	14.871	800.1	14.857	1079.5	14.841	1079.5	84.656
5	11.43	5.0	63.5	12.967	660.4	12.780	800.1	12.725	1079.5	12.666	1079.5	95.633
6	15.75	5.0	63.5	11.153	660.4	10.729	800.1	10.430	1079.5	10.209	1079.5	111.096
7	16.26	5.0	63.5	10.964	660.4	10.536	800.1	10.111	1079.5	9.873	1079.5	*****
8	16.45	5.0	63.5	10.894	660.4	10.467	800.1	10.025	1079.5	*****	1079.5	*****
9	21.84	5.0	63.5	9.150	660.4	9.150	800.1	9.150	1079.5	*****	1079.5	*****
10	27.24	5.0	63.5	7.406	660.4	7.833	800.1	8.275	1079.5	*****	1079.5	*****
11	27.43	5.0	63.5	7.336	660.4	7.764	800.1	8.189	1079.5	*****	1079.5	*****
12	27.94	5.0	63.5	7.147	660.4	7.571	800.1	7.870	1079.5	8.091	1079.5	111.129
13	32.26	5.0	63.5	5.333	660.4	5.520	800.1	5.575	1079.5	5.634	1079.5	95.625
14	36.58	5.0	63.5	3.357	660.4	3.429	800.1	3.443	1079.5	3.459	1079.5	84.656
15	39.12	5.0	63.5	2.166	660.4	2.202	800.1	2.209	1079.5	2.215	1079.5	82.307
16	42.16	5.0	63.5	0.724	660.4	0.734	800.1	0.736	1079.5	0.738	1079.5	81.464
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	1079.5	0.000	1079.5	81.366

TABLE E.6

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=143.3 MILLI AMPS

ST NO	X (M)	Z (CM)	Y (CM)	****		****		****		****		****	
				VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY
				MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER	
1	0.00	5.0	63.5	18.300	660.4	18.300	800.1	18.300	1079.5	18.300	1079.5	18.300	83.097
2	1.52	5.0	63.5	17.562	660.4	17.550	800.1	17.548	1079.5	17.546	1079.5	17.546	83.454
3	4.57	5.0	63.5	16.090	660.4	16.048	800.1	16.041	1079.5	16.033	1079.5	16.033	84.364
4	7.11	5.0	63.5	14.877	660.4	14.793	800.1	14.777	1079.5	14.758	1079.5	14.758	86.992
5	11.43	5.0	63.5	12.871	660.4	12.852	800.1	12.589	1079.5	12.523	1079.5	12.523	99.318
6	15.75	5.0	63.5	11.055	660.4	10.556	800.1	10.206	1079.5	9.971	1079.5	9.971	114.173
7	16.26	5.0	63.5	10.870	660.4	10.364	800.1	9.858	1079.5	9.626	1079.5	9.626	*****
8	16.45	5.0	63.5	10.802	660.4	10.297	800.1	9.769	1079.5	*****	1079.5	*****	*****
9	21.84	5.0	63.5	9.150	660.4	9.150	800.1	9.150	1079.5	*****	1079.5	*****	*****
10	27.24	5.0	63.5	7.498	660.4	8.003	800.1	8.531	1079.5	*****	1079.5	*****	*****
11	27.43	5.0	63.5	7.430	660.4	7.936	800.1	8.442	1079.5	*****	1079.5	*****	*****
12	27.94	5.0	63.5	7.245	660.4	7.745	800.1	8.093	1079.5	*****	1079.5	*****	*****
13	32.26	5.0	63.5	5.429	660.4	5.648	800.1	5.711	1079.5	*****	1079.5	*****	*****
14	36.58	5.0	63.5	3.423	660.4	3.507	800.1	3.524	1079.5	*****	1079.5	*****	*****
15	39.12	5.0	63.5	2.210	660.4	2.252	800.1	2.259	1079.5	*****	1079.5	*****	*****
16	42.16	5.0	63.5	0.739	660.4	0.751	800.1	0.753	1079.5	*****	1079.5	*****	*****
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	1079.5	*****	1079.5	*****	*****

TABLE E.7

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY= .30 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE=359.000VOLTS

TOTAL CURRENT=139.1 MILLI AMPS

ST NO	X (M)	Y (CM)	Z (CM)	****		****		****		****		****		****	
				VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY
				MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER	
1	0.00	5.0	63.5	359.000	660.4	359.000	800.1	359.000	800.1	359.000	800.1	359.000	1079.5	359.000	90.560
2	1.52	5.0	63.5	343.420	88.072	660.4	343.080	89.994	800.1	343.030	90.277	1079.5	342.980	90.960	
3	4.57	5.0	63.5	312.360	87.876	660.4	311.220	90.140	800.1	311.030	90.536	1079.5	310.830	92.146	
4	7.11	5.0	63.5	286.840	86.614	660.4	284.570	90.449	800.1	284.130	91.298	1079.5	283.680	95.530	
5	11.43	5.0	63.5	245.030	83.472	660.4	239.000	90.978	800.1	237.310	93.474	1079.5	235.830	109.625	
6	15.75	5.0	63.5	208.410	73.110	660.4	194.450	88.942	800.1	184.430	105.573	1079.5	180.920	114.207	
7	16.26	5.0	63.5	204.890	59.734	660.4	190.820	61.601	800.1	174.190	173.771	1079.5	174.190	*****	
8	16.45	5.0	63.5	203.610	57.924	660.4	189.630	53.851	800.1	174.190	0.000	1079.5	*****	*****	
9	21.84	5.0	63.5	174.930	45.807	660.4	174.390	24.341	800.1	174.190	0.000	1079.5	*****	*****	
10	27.24	5.0	63.5	146.990	44.625	660.4	159.780	23.335	800.1	174.190	0.000	1079.5	*****	*****	
11	27.43	5.0	63.5	145.770	55.209	660.4	158.660	50.683	800.1	164.590	0.000	1079.5	*****	*****	
12	27.94	5.0	63.5	142.410	57.019	660.4	155.230	58.207	800.1	164.590	162.911	1079.5	167.860	107.419	
13	32.26	5.0	63.5	107.670	69.357	660.4	113.230	83.851	800.1	114.800	99.403	1079.5	116.180	103.177	
14	36.58	5.0	63.5	68.142	78.916	660.4	70.238	85.832	800.1	70.646	88.151	1079.5	71.062	90.076	
15	39.12	5.0	63.5	44.044	81.788	660.4	45.090	85.352	800.1	45.269	86.129	1079.5	45.452	86.920	
16	42.16	5.0	63.5	14.724	82.926	660.4	15.030	85.019	800.1	15.080	85.384	1079.5	15.131	85.757	
17	43.69	5.0	63.5	0.000	83.288	660.4	0.000	85.019	800.1	0.000	85.302	1079.5	0.000	85.590	

TABLE E.8

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE=359.000VOLTS

TOTAL CURRENT=139.1 MILLI AMPS

ST NO	X(M)	Y(CM)	Z(CM)	****		****		****		****		****	
				VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY	VOLTS	CURRENT Y(CM) DENSITY
				MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER	
1	0.00	5.0	63.5	359.000	660.4	359.000	800.1	359.000	1079.5	359.000	1079.5	359.000	90.616
2	1.52	5.0	63.5	343.410	660.4	343.080	800.1	343.030	1079.5	342.970	1079.5	342.970	90.960
3	4.57	5.0	63.5	312.340	660.4	311.210	800.1	311.020	1079.5	310.820	1079.5	310.820	92.180
4	7.11	5.0	63.5	286.820	660.4	284.550	800.1	284.110	1079.5	283.660	1079.5	283.660	95.550
5	11.43	5.0	63.5	245.000	660.4	238.970	800.1	237.280	1079.5	235.800	1079.5	235.800	109.665
6	15.75	5.0	63.5	208.370	660.4	194.410	800.1	184.390	1079.5	180.870	1079.5	180.870	114.207
7	16.26	5.0	63.5	204.850	660.4	190.780	800.1	174.140	1079.5	174.140	1079.5	174.140	*****
8	16.45	5.0	63.5	203.580	660.4	189.590	800.1	174.140	1079.5	174.140	1079.5	174.140	*****
9	21.84	5.0	63.5	174.890	660.4	174.350	800.1	174.140	1079.5	174.140	1079.5	174.140	*****
10	27.24	5.0	63.5	146.950	660.4	159.740	800.1	174.140	1079.5	174.140	1079.5	174.140	*****
11	27.43	5.0	63.5	145.730	660.4	158.620	800.1	174.140	1079.5	174.140	1079.5	174.140	*****
12	27.94	5.0	63.5	142.380	660.4	155.190	800.1	164.540	1079.5	167.820	1079.5	167.820	*****
13	32.26	5.0	63.5	107.640	660.4	113.200	800.1	114.770	1079.5	116.140	1079.5	116.140	103.177
14	36.58	5.0	63.5	68.123	660.4	70.219	800.1	70.426	1079.5	71.042	1079.5	71.042	90.036
15	39.12	5.0	63.5	44.032	660.4	45.077	800.1	45.256	1079.5	45.440	1079.5	45.440	86.892
16	42.16	5.0	63.5	14.720	660.4	15.026	800.1	15.076	1079.5	15.126	1079.5	15.126	85.737
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	1079.5	0.000	1079.5	0.000	85.562

TABLE E.9

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE=359.000VOLTS

TOTAL CURRENT=139.1 MILLI AMPS

ST NO	X (M)	Y (CM)	Z (CM)	****		****		****		****		****			
				VOLTS	CURRENT Y (CM) VOLTAGE DENSITY	VOLTS	CURRENT Y (CM) VOLTAGE DENSITY	VOLTS	CURRENT Y (CM) VOLTAGE DENSITY	VOLTS	CURRENT Y (CM) VOLTAGE DENSITY	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER		
1	0.00	5.0	63.5	359.000	660.4	359.000	800.1	359.000	800.1	359.000	800.1	359.000	1079.5	359.000	90.560
2	1.52	5.0	63.5	343.420	660.4	343.090	800.1	343.040	800.1	343.040	800.1	343.040	1079.5	342.980	90.560
3	4.57	5.0	63.5	312.370	660.4	311.240	800.1	311.040	800.1	311.040	800.1	311.040	1079.5	310.840	90.932
4	7.11	5.0	63.5	286.860	660.4	284.590	800.1	284.150	800.1	284.150	800.1	284.150	1079.5	283.700	92.112
5	11.43	5.0	63.5	245.060	660.4	239.030	800.1	237.340	800.1	237.340	800.1	237.340	1079.5	235.870	95.490
6	15.75	5.0	63.5	208.440	660.4	194.500	800.1	184.480	800.1	184.480	800.1	184.480	1079.5	180.970	109.605
7	16.26	5.0	63.5	204.930	660.4	190.870	800.1	174.240	800.1	174.240	800.1	174.240	1079.5	174.240	114.207
8	16.45	5.0	63.5	203.650	660.4	189.680	800.1	174.240	800.1	174.240	800.1	174.240	1079.5	174.240	114.207
9	21.84	5.0	63.5	174.970	660.4	174.440	800.1	174.240	800.1	174.240	800.1	174.240	1079.5	174.240	114.207
10	27.24	5.0	63.5	147.030	660.4	159.830	800.1	174.240	800.1	174.240	800.1	174.240	1079.5	174.240	114.207
11	27.43	5.0	63.5	145.810	660.4	158.700	800.1	174.240	800.1	174.240	800.1	174.240	1079.5	174.240	114.207
12	27.94	5.0	63.5	142.450	660.4	155.270	800.1	164.630	800.1	164.630	800.1	164.630	1079.5	167.910	107.419
13	32.26	5.0	63.5	107.700	660.4	113.260	800.1	114.830	800.1	114.830	800.1	114.830	1079.5	116.210	103.217
14	36.58	5.0	63.5	68.160	660.4	70.257	800.1	70.666	800.1	70.666	800.1	70.666	1079.5	71.082	90.096
15	39.12	5.0	63.5	44.056	660.4	45.102	800.1	45.281	800.1	45.281	800.1	45.281	1079.5	45.465	86.943
16	42.16	5.0	63.5	14.728	660.4	15.034	800.1	15.084	800.1	15.084	800.1	15.084	1079.5	15.135	85.783
17	43.69	5.0	63.5	0.000	660.4	0.000	800.1	0.000	800.1	0.000	800.1	0.000	1079.5	0.000	85.613

TABLE E.10

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN WATER

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY= 30 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=138.4 MILLI AMPS

ST NO	X(CM)	Z(CM)	Y(CM)	*AAA*		*BBB*		*CCC*		*DDD*			
				VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY		
	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER			
1	10.00	5.0	10.00	12.006	90.00	12.188	170.00	12.266	260.00	12.329			
2	50.00	5.0	10.00	11.737	20.175	11.901	21.525	170.00	11.985	21.075	260.00	12.030	22.425
3	130.00	5.0	10.00	11.278	17.212	11.388	19.237	170.00	11.456	19.838	260.00	11.485	20.437
4	210.00	5.0	10.00	10.846	16.200	10.918	17.625	170.00	10.966	18.375	260.00	10.985	18.750
5	290.00	5.0	10.00	10.426	15.750	10.472	16.725	170.00	10.504	17.325	260.00	10.517	17.550
6	370.00	5.0	10.00	10.014	15.450	10.042	16.125	170.00	10.060	16.650	260.00	10.068	16.838
7	450.00	5.0	10.00	9.606	15.300	9.619	15.859	170.00	9.628	16.189	260.00	9.632	16.346
8	539.75	5.0	10.00	9.150	15.242	9.150	15.680	170.00	9.150	15.988	260.00	9.150	16.115

TABLE E.11

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN WATER

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=1600 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=142.7 MILLI AMPS

ST NO	X(CM)	Z(CM)	Y(CM)	VOLTAGE	*AAA* CURRENT Y(CM) DENSITY	VOLTS	*BBB* CURRENT Y(CM) DENSITY	VOLTS	*CCC* CURRENT Y(CM) DENSITY	VOLTS	*DDD* CURRENT DENSITY
					MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER
1	10.00	5.0	10.00	9.852	90.00	9.793	170.00	9.764	260.00	9.748	
2	50.00	5.0	10.00	9.796	224.000	9.755	154.000	9.729	137.200	9.718	122.800
3	130.00	5.0	10.00	9.689	212.600	9.666	177.000	9.650	159.000	9.643	150.200
4	210.00	5.0	10.00	9.586	207.400	9.571	190.200	9.561	178.200	9.556	172.800
5	290.00	5.0	10.00	9.482	208.400	9.472	198.000	9.466	190.200	9.463	187.000
6	370.00	5.0	10.00	9.376	210.600	9.370	203.400	9.366	198.200	9.365	195.800
7	450.00	5.0	10.00	9.270	212.600	9.267	206.800	9.265	202.800	9.264	201.000
8	539.75	5.0	10.00	9.150	213.749	9.150	208.758	9.150	205.192	9.150	203.766

TABLE E.12

FINITE ELEMENT METHOD

CURRENT DENSITY CALCULATION IN WATER

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=143.3 MILLI AMPS

ST NO	X(CM)	Z(CM)	Y(CM)	*AAA*		*BBB*		*CCC*		*DD*	
				VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT DENSITY
	VOLTS	MILI AMP PER SQ.METER		VOLTS	MILI AMP PER SQ.METER		VOLTS	MILI AMP PER SQ.METER		VOLTS	MILI AMP PER SQ.METER
1	10.00	5.0	10.00	9.572	90.00	9.532	170.00	9.512	260.00	9.502	
2	50.00	5.0	10.00	9.537	261.000	9.510	168.000	9.493	144.750	9.485	128.250
3	130.00	5.0	10.00	9.473	241.875	9.458	196.125	9.447	172.875	9.442	162.000
4	210.00	5.0	10.00	9.411	233.625	9.401	211.875	9.394	196.500	9.391	189.750
5	290.00	5.0	10.00	9.348	233.250	9.342	220.875	9.338	211.125	9.336	207.375
6	370.00	5.0	10.00	9.285	236.250	9.282	227.625	9.279	220.875	9.278	217.875
7	450.00	5.0	10.00	9.222	238.125	9.220	231.375	9.219	226.500	9.218	224.625
8	539.75	5.0	10.00	9.150	240.000	9.150	233.649	9.150	229.638	9.150	227.632

APPENDIX F

EXPERIMENTAL RESULTS

TABLE F.1

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 55.00 OHM-METER WATER CONDUCTIVITY= 30 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE= 17.080VOLTS

TOTAL CURRENT=140.4 MILI AMPS

ST NO	X (M)	Y (CM)	Z (CM)	**A**			**B**			**C**			**D**		
				VOLTS	CURRENT DENSITY	VOLTA	VOLTS	CURRENT DENSITY	VOLTS	CURRENT DENSITY	VOLTS	CURRENT DENSITY			
				MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	
1	0.000	1.90	6.35	17.080	66.04	17.080	78.74	17.080	107.95	17.080	107.95	17.080	107.95	17.080	
2	0.152	1.90	6.35	17.080	66.04	16.630	53.686	16.600	57.266	16.560	57.266	16.560	57.266	16.560	
3	0.457	1.90	6.35	14.940	66.04	15.300	79.337	15.310	76.951	15.310	76.951	15.310	76.951	15.310	
4	0.710	1.90	6.35	14.080	66.04	14.240	61.808	14.270	74.744	14.250	74.744	14.250	74.744	14.250	
5	1.143	1.90	6.35	12.480	66.04	12.470	67.213	12.460	74.035	12.450	74.035	12.450	74.035	12.450	
6	1.578	1.90	6.35	10.960	66.04	10.690	63.852	10.390	86.957	10.020	86.957	10.020	86.957	10.020	
7	1.625	1.90	6.35	10.430	66.04	10.430	96.934	10.080	115.575	9.580	115.575	9.580	115.575	9.580	
8	1.664	1.90	6.35	10.230	66.04	10.230	91.772	9.680	178.955	9.580	178.955	9.580	178.955	9.580	
9	2.185	1.90	6.35	8.840	66.04	8.820	46.745	8.890	27.907	8.890	27.907	8.890	27.907	8.890	
10	2.707	1.90	6.35	7.300	66.04	7.300	53.731	7.990	31.744	7.990	31.744	7.990	31.744	7.990	
11	2.743	1.90	6.35	6.680	66.04	7.160	94.448	7.730	124.274	7.150	124.274	7.150	124.274	7.150	
12	2.795	1.90	6.35	6.680	66.04	6.920	80.705	7.250	168.438	7.250	168.438	7.250	168.438	7.250	
13	3.200	1.90	6.35	5.070	66.04	5.100	82.077	5.110	95.981	5.120	95.981	5.120	95.981	5.120	
14	3.627	1.90	6.35	3.300	66.04	3.180	81.808	3.200	81.382	3.200	81.382	3.200	81.382	3.200	
15	3.901	1.90	6.35	2.240	66.04	2.110	70.919	2.080	74.233	2.040	74.233	2.040	74.233	2.040	
16	4.206	1.90	6.35	0.770	66.04	0.770	79.933	0.740	79.933	0.750	79.933	0.750	79.933	0.750	
17	4.420	1.90	6.35	0.000	66.04	0.000	65.617	0.000	63.060	0.000	63.060	0.000	63.060	0.000	

TABLE F.2

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 55.00 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE= 17.080VOLTS

TOTAL CURRENT=141.0 MILLI AMPS

ST NO	X (M)	Z (CM)	Y (CM)	***		***		***		***		***	
				VOLTAGE	CURRENT DENSITY	VOLTAGE	CURRENT DENSITY	VOLTAGE	CURRENT DENSITY	VOLTAGE	CURRENT DENSITY	VOLTS	MILI AMP PER SQ.METER
1	0.000	1.90	6.35	17.080	66.04	17.080	52.493	78.74	17.080	54.880	107.95	17.080	59.196
2	0.152	1.90	6.35	17.080	66.04	16.640	80.530	78.74	16.620	77.547	107.95	16.500	70.985
3	0.457	1.90	6.35	14.950	66.04	15.290	76.182	78.74	15.320	75.463	107.95	15.310	75.463
4	0.710	1.90	6.35	14.050	66.04	14.230	73.934	78.74	14.270	72.295	107.95	14.260	76.035
5	1.143	1.90	6.35	12.490	66.04	12.470	76.455	78.74	12.430	85.697	107.95	12.450	103.340
6	1.576	1.90	6.35	10.960	66.04	10.650	104.390	78.74	10.390	115.575	107.95	9.990	160.314
7	1.625	1.90	6.35	10.370	66.04	10.370	91.772	78.74	9.680	183.543	107.95	9.560	*****
8	1.664	1.90	6.35	10.170	66.04	10.170	44.303	78.74	8.090	31.744	107.95	8.150	*****
9	2.185	1.90	6.35	8.810	66.04	8.810	53.373	78.74	7.980	119.303	107.95	8.150	*****
10	2.707	1.90	6.35	7.740	66.04	7.740	74.565	78.74	7.250	171.937	107.95	7.630	*****
11	2.743	1.90	6.35	7.220	66.04	7.220	94.741	78.74	7.250	96.429	107.95	7.630	*****
12	2.795	1.90	6.35	6.680	66.04	6.950	81.629	78.74	5.130	81.808	107.95	5.170	*****
13	3.260	1.90	6.35	5.070	66.04	5.130	82.669	78.74	3.180	72.908	107.95	3.200	*****
14	3.627	1.90	6.35	3.280	66.04	3.190	72.908	78.74	2.080	78.740	107.95	2.080	*****
15	3.901	1.90	6.35	2.240	66.04	2.090	80.530	78.74	0.760	63.060	107.95	0.750	*****
16	4.206	1.90	6.35	0.000	66.04	0.740	63.060	78.74	0.000	63.060	107.95	0.000	*****
17	4.420	1.90	6.35	0.000	66.04	0.000	63.060	78.74	0.000	63.060	107.95	0.000	*****

TABLE F.3

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 55.00 OHM-METER WATER CONDUCTIVITY=3000 MICRO-HHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE= 17.080VOLTS

TOTAL CURRENT=141.0 MILLI AMPS

ST NO	X (M)	Z (CM)	Y (CM)	***		***		***		MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	CURRENT DENSITY	Y (CM)	VOLTAGE	CURRENT DENSITY	VOLTS	MILI AMP PER SQ.METER	CURRENT DENSITY
				VOLTAGE	DENSITY	VOLTAGE	DENSITY	VOLTAGE	DENSITY											
1	0.000	1.90	6.35	17.080	66.04	17.080	78.74	17.080	107.95	17.080	54.880	107.95	16.520	66.810						
2	0.152	1.90	6.35	17.080	66.04	16.680	78.74	16.620	107.95	16.520	76.354	107.95	15.310	72.178						
3	0.457	1.90	6.35	14.960	66.04	15.290	78.74	15.340	107.95	15.310	78.338	107.95	14.240	76.900						
4	0.710	1.90	6.35	14.070	66.04	14.250	78.74	14.250	107.95	14.240	74.744	107.95	13.240	76.900						
5	1.143	1.90	6.35	12.500	65.953	12.460	78.74	12.470	107.95	12.420	75.195	107.95	12.420	76.455						
6	1.576	1.90	6.35	10.970	64.273	10.700	78.74	10.400	107.95	9.910	86.957	107.95	9.910	105.441						
7	1.625	1.90	6.35	10.970	66.04	10.460	78.74	10.110	107.95	9.580	108.119	107.95	9.580	123.031						
8	1.744	1.90	6.35	10.970	66.04	10.390	78.74	9.740	107.95	9.580	108.119	107.95	9.580	123.031						
9	2.185	1.90	6.35	8.870	66.04	8.910	78.74	8.910	107.95	8.910	27.558	107.95	8.910	105.441						
10	2.707	1.90	6.35	8.910	66.04	7.380	78.74	8.000	107.95	8.000	31.744	107.95	8.000	105.441						
11	2.743	1.90	6.35	8.910	66.04	7.270	78.74	7.780	107.95	8.200	109.361	107.95	8.200	105.441						
12	2.795	1.90	6.35	6.700	66.04	6.950	78.74	7.230	107.95	7.630	192.991	107.95	7.630	200.008						
13	3.200	1.90	6.35	5.070	73.107	5.150	78.74	5.120	107.95	5.140	94.635	107.95	5.140	111.679						
14	3.627	1.90	6.35	3.290	75.843	3.290	78.74	3.180	107.95	3.270	82.660	107.95	3.270	81.803						
15	3.901	1.90	6.35	2.240	69.594	2.100	78.74	2.090	107.95	2.080	72.245	107.95	2.080	75.559						
16	4.206	1.90	6.35	0.000	66.04	0.710	78.74	0.730	107.95	0.730	81.126	107.95	0.730	80.530						
17	4.420	1.90	6.35	0.000	66.04	0.000	78.74	0.000	107.95	0.000	62.208	107.95	0.000	62.208						

TABLE F.5

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=1600 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=142.7 MILLI AMPS

ST NO	X (M)	Z (CM)	***A***			***B***			***C***			***D***		
			VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY	VOLTS	CURRENT Y (CM) DENSITY		
			MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER		MILI AMP PER SQ.METER	
1	0.000	1.90	6.35	18.300	66.04	18.300	74.991	78.74	18.300	107.95	18.300	107.95	18.300	
2	0.152	1.90	6.35	17.620	66.04	17.620	74.991	78.74	17.620	107.95	17.620	107.95	17.620	
3	0.457	1.90	6.35	15.870	66.04	16.200	78.299	78.74	16.250	107.95	16.240	107.95	16.240	
4	0.710	1.90	6.35	14.960	66.04	15.150	68.756	78.74	15.220	107.95	15.160	107.95	15.160	
5	1.143	1.90	6.35	13.350	66.04	13.330	62.518	78.74	13.390	107.95	13.370	107.95	13.370	
6	1.576	1.90	6.35	11.720	66.04	11.600	67.178	78.74	11.410	107.95	11.040	107.95	11.040	
7	1.625	1.90	6.35	11.360	66.04	11.360	82.710	78.74	11.050	107.95	10.620	107.95	10.620	
8	1.664	1.90	6.35	11.140	66.04	11.140	93.314	78.74	10.770	107.95	10.620	107.95	10.620	
9	2.167	1.90	6.35	9.440	66.04	9.440	54.810	78.74	9.460	107.95	9.460	107.95	9.460	
10	2.707	1.90	6.35	7.670	66.04	7.670	57.075	78.74	8.150	107.95	8.420	107.95	8.420	
11	2.743	1.90	6.35	7.440	66.04	7.440	105.685	78.74	7.840	107.95	8.420	107.95	8.420	
12	2.795	1.90	6.35	7.070	66.04	7.190	81.088	78.74	7.400	107.95	7.800	107.95	7.800	
13	3.200	1.90	6.35	5.350	66.04	5.380	71.309	78.74	5.370	107.95	5.370	107.95	5.370	
14	3.627	1.90	6.35	3.490	66.04	3.390	78.378	78.74	3.390	107.95	3.390	107.95	3.390	
15	3.901	1.90	6.35	2.410	66.04	2.260	69.232	78.74	2.260	107.95	2.280	107.95	2.280	
16	4.206	1.90	6.35	0.850	66.04	0.850	77.748	78.74	0.860	107.95	0.850	107.95	0.850	
17	4.420	1.90	6.35	0.000	66.04	0.000	66.956	78.74	0.000	107.95	0.000	107.95	0.000	

TABLE F.6

R.P.A PROJECT F.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=143.3 MILLI AMPS

ST NO	X (M)	Y (CM)	Z (CM)	****			**B**			**C**			****		
				VOLTAGE	CURRENT DENSITY	Y (CM)	VOLTAGE	CURRENT DENSITY	Y (CM)	VOLTAGE	CURRENT DENSITY	Y (CM)	VOLTAGE	CURRENT DENSITY	Y (CM)
				VOLTS	MILI AMP PER SQ.METER		VOLTS	MILI AMP PER SQ.METER		VOLTS	MILI AMP PER SQ.METER		VOLTS	MILI AMP PER SQ.METER	
1	0.000	1.90	6.35	18.300	66.04	18.300	78.74	18.300	107.95	18.300	107.95	18.300	107.95	18.300	80.505
2	0.152	1.90	6.35	17.580	66.04	17.580	78.74	17.580	107.95	17.580	107.95	17.570	107.95	17.570	74.991
3	0.457	1.90	6.35	15.870	66.04	16.210	78.74	16.210	107.95	16.210	107.95	16.210	107.95	16.210	71.749
4	0.710	1.90	6.35	14.960	60.455	15.140	78.74	15.140	107.95	15.140	107.95	15.130	107.95	15.130	68.343
5	1.143	1.90	6.35	13.300	64.460	13.290	78.74	13.330	107.95	13.330	107.95	13.370	107.95	13.370	97.078
6	1.576	1.90	6.35	11.700	62.130	11.540	78.74	11.280	107.95	11.280	107.95	10.870	107.95	10.870	137.850
7	1.625	1.90	6.35	11.000	66.04	11.260	78.74	11.020	107.95	11.020	107.95	10.470	107.95	10.470	137.850
8	1.664	1.90	6.35	9.430	66.04	11.100	78.74	10.470	107.95	10.470	107.95	9.460	107.95	9.460	137.850
9	2.085	1.90	6.35	7.650	66.04	9.460	78.74	9.460	107.95	9.460	107.95	8.390	107.95	8.390	137.850
10	2.707	1.90	6.35	6.604	66.04	7.650	78.74	8.390	107.95	8.390	107.95	7.610	107.95	7.610	137.850
11	2.742	1.90	6.35	6.604	66.04	7.230	78.74	8.010	107.95	8.010	107.95	7.990	107.95	7.990	137.850
12	2.795	1.90	6.35	5.350	72.967	66.04	78.74	7.610	107.95	7.610	107.95	7.990	107.95	7.990	137.850
13	3.200	1.90	6.35	5.350	72.967	66.04	78.74	5.440	107.95	5.440	107.95	5.420	107.95	5.420	137.850
14	3.627	1.90	6.35	3.470	73.258	66.04	78.74	3.400	107.95	3.400	107.95	3.400	107.95	3.400	137.850
15	3.901	1.90	6.35	2.440	64.330	66.04	78.74	2.270	107.95	2.270	107.95	2.290	107.95	2.290	137.850
16	4.206	1.90	6.35	0.840	81.607	66.04	78.74	0.870	107.95	0.870	107.95	0.880	107.95	0.880	137.850
17	4.420	1.90	6.35	0.000	66.168	66.04	78.74	0.000	107.95	0.000	107.95	0.000	107.95	0.000	137.850

TABLE F.7

B.F.A PROJECT F.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY= 30 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE=359.000VOLTS

TOTAL CURRENT=139.1 MILI AMPS

ST NO	X (M)	Y (CM)	Z (CM)	***A**		***B**		***C**		***D**		
				CURRENT DENSITY	VOLTAGE	CURRENT DENSITY	VOLTAGE	CURRENT DENSITY	VOLTAGE	CURRENT DENSITY	VOLTAGE	
	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER
1	0.000	1.90	6.35	359.000	66.04	359.000	78.74	359.000	107.95	359.000	141.416	
2	0.152	1.90	6.35	327.000	181.012	327.000	78.74	332.000	152.729	332.000	193.193	
3	0.457	1.90	6.35	300.000	76.364	304.000	78.74	305.000	76.364	306.000	74.967	
4	0.710	1.90	6.35	277.000	78.375	283.000	78.74	284.000	71.560	284.000	74.967	
5	1.143	1.90	6.35	248.000	57.761	248.000	70.74	248.000	70.74	248.000	70.74	
6	1.576	1.90	6.35	219.000	57.761	207.000	78.74	196.000	78.74	196.000	78.74	
7	1.625	1.90	6.35	200.000	123.739	200.000	78.74	184.000	212.123	182.000	70.708	
8	1.664	1.90	6.35	198.000	43.512	198.000	78.74	180.000	87.025	180.000	70.708	
9	2.185	1.90	6.35	178.000	33.010	178.000	78.74	180.000	-1.634	180.000	70.708	
10	2.707	1.90	6.35	157.000	34.734	157.000	78.74	180.000	1.654	180.000	70.708	
11	2.743	1.90	6.35	153.000	94.277	153.000	78.74	177.000	70.708	181.000	70.708	
12	2.795	1.90	6.35	135.000	99.823	147.000	78.74	165.000	199.645	173.000	133.097	
13	3.200	1.90	6.35	106.000	61.670	106.000	78.74	165.000	78.74	165.000	78.74	
14	3.627	1.90	6.35	66.000	80.809	70.000	78.74	70.000	78.74	70.000	78.74	
15	3.701	1.90	6.35	51.000	47.139	49.000	78.74	49.000	65.994	48.000	72.279	
16	4.206	1.90	6.35	22.000	82.021	19.000	78.74	18.000	84.849	18.000	76.364	
17	4.420	1.90	6.35	0.000	88.890	0.000	78.74	0.000	76.768	0.000	84.849	

TABLE F.8

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY=1500 MICRO-MHO/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE=359.000VOLTS

TOTAL CURRENT=139.1 MILLI AMPS

ST NO	X (M)	Z (M)	Y (CM)	***A***			***B***			***C***			***D***		
				VOLTAGE	CURRENT Y (CH) DENSITY	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS
				MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER
1	0.000	1.90	6.35	359.000	66.04	359.000	78.74	359.000	107.95	359.000	155.782				
2	0.152	1.90	6.35	325.559	189.164	66.04	329.493	166.909	78.74	330.477	161.345	107.95	331.460	155.782	
3	0.457	1.90	6.35	298.019	77.891	66.04	300.970	80.673	78.74	301.953	80.673	107.95	302.937	80.673	
4	0.710	1.90	6.35	278.348	67.032	66.04	279.332	73.735	78.74	280.315	73.735	107.95	280.315	77.087	
5	1.143	1.90	6.35	246.874	62.689	66.04	246.874	62.689	78.74	246.874	62.689	107.95	246.874	62.689	
6	1.576	1.90	6.35	219.334	54.853	66.04	208.515	54.853	78.74	195.739	54.853	107.95	185.893	54.853	
7	1.625	1.90	6.35	219.334	54.853	66.04	199.663	54.853	78.74	193.926	54.853	107.95	180.975	54.853	
8	1.664	1.90	6.35	219.334	54.853	66.04	195.729	54.853	78.74	181.959	54.853	107.95	180.975	54.853	
9	2.125	1.90	6.35	177.041	44.444	66.04	176.050	44.444	78.74	180.975	44.444	107.95	180.975	44.444	
10	2.707	1.90	6.35	146.386	36.222	66.04	156.386	36.222	78.74	179.992	36.222	107.95	179.992	36.222	
11	2.743	1.90	6.35	146.386	36.222	66.04	153.436	36.222	78.74	177.041	36.222	107.95	173.107	36.222	
12	2.795	1.90	6.35	135.732	33.333	66.04	145.567	33.333	78.74	164.255	33.333	107.95	168.189	33.333	
13	3.200	1.90	6.35	106.225	25.000	66.04	106.225	25.000	78.74	164.255	25.000	107.95	168.189	25.000	
14	3.627	1.90	6.35	69.833	16.667	66.04	69.833	16.667	78.74	164.255	16.667	107.95	168.189	16.667	
15	3.901	1.90	6.35	51.145	12.778	66.04	48.195	12.778	78.74	164.255	12.778	107.95	168.189	12.778	
16	4.266	1.90	6.35	21.638	5.556	66.04	17.704	5.556	78.74	164.255	5.556	107.95	168.189	5.556	
17	4.426	1.90	6.35	0.000	0.000	66.04	0.000	0.000	78.74	164.255	0.000	107.95	168.189	0.000	

TABLE F.9

B.P.A PROJECT F.S.U.

CURRENT DENSITY CALCULATION IN SOIL

SOIL RESISTIVITY=1160.00 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHD/CM

POOL TYPE: REINFORCED MAXIMUM VOLTAGE=359.000VOLTS

TOTAL CURRENT=139.1 MILLI AMPS

ST NO	X (M)	Z (CM)	Y (CM)	***A**			***B**			***C**			***D**		
				VOLTAGE	CURRENT Y (CM) DENSITY	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS	VOLTS
				MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER
1	0.000	1.90	6.35	359.000	66.04	359.000	78.74	359.000	107.95	359.000	150.218	107.95	359.000	150.218	
2	0.152	1.90	6.35	325.559	189.164	329.493	166.909	332.444	150.218	332.444	80.673	107.95	332.444	80.673	
3	0.457	1.90	6.35	298.019	77.691	295.068	97.364	303.921	80.673	303.921	73.735	107.95	303.921	73.735	
4	0.710	1.90	6.35	272.447	97.141	280.315	50.274	282.282	73.735	281.299	*****	107.95	281.299	*****	
5	1.143	1.90	6.35	245.890	52.894	*****	*****	*****	*****	*****	*****	107.95	*****	*****	
6	1.576	1.90	6.35	218.351	54.853	208.515	*****	196.712	*****	184.910	*****	107.95	184.910	*****	
7	1.625	1.90	6.35	*****	*****	201.630	121.705	184.910	208.636	181.959	57.159	*****	*****	*****	
8	1.644	1.90	6.35	*****	*****	199.663	47.797	182.942	42.797	107.95	*****	*****	*****	*****	
9	2.185	1.90	6.35	178.025	*****	177.041	37.416	180.975	3.254	107.95	*****	*****	*****	*****	
10	2.707	1.90	6.35	*****	*****	157.370	32.536	179.992	1.627	107.95	*****	*****	*****	*****	
11	2.743	1.90	6.35	*****	*****	155.403	46.364	178.025	46.364	107.95	*****	*****	*****	*****	
12	2.795	1.90	6.35	135.732	*****	145.567	163.636	164.235	229.091	107.95	*****	*****	*****	*****	
13	3.200	1.90	6.35	106.225	62.748	*****	*****	*****	*****	107.95	*****	*****	*****	*****	
14	3.627	1.90	6.35	68.849	75.506	69.833	*****	70.816	*****	107.95	*****	*****	*****	*****	
15	3.901	1.90	6.35	50.162	58.727	49.178	64.909	50.162	64.909	107.95	*****	*****	*****	*****	
16	4.206	1.90	6.35	21.638	80.673	19.671	83.455	19.671	86.236	107.95	*****	*****	*****	*****	
17	4.420	1.90	6.35	0.000	87.429	66.04	79.480	0.000	79.480	107.95	*****	*****	*****	*****	

TABLE F.10

B.F.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN WATER

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY= 30 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=138.4 MILLI AMPS

ST NO	X(CM)	Z(CM)	Y(CM)	*AAA*		*BBB*		*CCC*		*DD*	
				VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY	VOLTAGE	CURRENT Y(CM) DENSITY
				MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER	VOLTS
1	1.00	0.5	1.00	11.140	9.00	11.430	17.00	11.480	26.00	11.340	11.340
2	5.00	0.5	1.00	10.920	9.00	11.150	21.000	11.210	20.250	26.00	11.180
3	13.00	0.5	1.00	10.700	9.00	10.760	14.625	10.775	16.312	26.00	10.730
4	21.00	0.5	1.00	10.450	9.00	10.460	11.250	10.460	11.813	26.00	10.420
5	29.00	0.5	1.00	10.170	9.00	10.170	10.875	10.150	11.625	26.00	10.110
6	37.00	0.5	1.00	9.880	9.00	9.890	10.500	9.870	10.500	26.00	9.810
7	45.00	0.5	1.00	9.600	9.00	9.600	10.875	9.580	10.875	26.00	9.530
8	53.50	0.5	1.00	9.280	9.00	9.290	10.941	9.270	10.941	26.00	9.230

TABLE F.11

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN WATER

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=1600 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=142.7 MILLI AMPS

ST NO	X(CM)	Z(CM)	Y(CM)	VOLTS	*AAA* CURRENT DENSITY	Y(CM)	VOLTS	*BBB* CURRENT DENSITY	Y(CM)	VOLTS	*CCC* CURRENT DENSITY	Y(CM)	VOLTS	*DDD* CURRENT DENSITY
					MILI AMP PER SQ.METER			MILI AMP PER SQ.METER			MILI AMP PER SQ.METER			MILI AMP PER SQ.METER
1	1.00	0.5	1.00	9.570	9.00	9.580	17.00	9.580	26.00	9.580	26.00	9.580	26.00	9.580
2	5.00	0.5	1.00	9.560	40.000	9.570	40.000	17.00	9.570	40.000	26.00	9.570	40.000	40.000
3	13.00	0.5	1.00	9.520	80.000	9.510	120.000	17.00	9.510	120.000	26.00	9.510	120.000	130.000
4	21.00	0.5	1.00	9.460	120.000	9.450	120.000	17.00	9.440	140.000	26.00	9.440	140.000	130.000
5	29.00	0.5	1.00	9.380	160.000	9.370	160.000	17.00	9.360	160.000	26.00	9.360	160.000	160.000
6	37.00	0.5	1.00	9.300	160.000	9.290	160.000	17.00	9.290	140.000	26.00	9.290	140.000	160.000
7	45.00	0.5	1.00	9.210	180.000	9.210	160.000	17.00	9.200	180.000	26.00	9.200	180.000	160.000
8	53.50	0.5	1.00	9.110	188.235	9.110	188.235	17.00	9.110	169.412	26.00	9.110	169.412	169.412

TABLE F.12

B.P.A PROJECT P.S.U.

CURRENT DENSITY CALCULATION IN WATER

SOIL RESISTIVITY= 59.50 OHM-METER WATER CONDUCTIVITY=3000 MICRO-MHO/CM

POOL TYPE: NON-REINFORCED MAXIMUM VOLTAGE= 18.300VOLTS

TOTAL CURRENT=143.3 MILI AMPS

ST NO	X(CM)	Z(CM)	Y(CM)	*AAA*		*BBB*		*CCC*		*DD*			
				VOLTS	DENSITY	VOLTS	DENSITY	VOLTS	DENSITY	VOLTS	DENSITY		
				MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	MILI AMP PER SQ.METER	VOLTS	MILI AMP PER SQ.METER		
1	1.00	0.5	1.00	9.400	9.00	9.410	17.00	9.400	26.00	9.390			
2	5.00	0.5	1.00	9.400	0.000	9.390	150.000	17.00	9.380	150.000	26.00	9.380	75.000
3	13.00	0.5	1.00	9.360	150.000	9.350	150.000	17.00	9.340	150.000	26.00	9.350	112.500
4	21.00	0.5	1.00	9.310	187.500	9.310	150.000	17.00	9.310	112.500	26.00	9.310	150.000
5	29.00	0.5	1.00	9.260	187.500	9.270	150.000	17.00	9.270	150.000	26.00	9.270	150.000
6	37.00	0.5	1.00	9.220	150.000	9.220	187.500	17.00	9.210	225.000	26.00	9.210	225.000
7	45.00	0.5	1.00	9.170	187.500	9.170	187.500	17.00	9.170	150.000	26.00	9.170	150.000
8	53.50	0.5	1.00	9.110	211.765	9.110	211.765	17.00	9.110	211.765	26.00	9.110	211.765