Portland State University

PDXScholar

Dissertations and Theses

Dissertations and Theses

1-14-2022

Development of a Testing Station for Grid-Interactive Smart Inverter Systems

Yudong Lan

Portland State University

Follow this and additional works at: https://pdxscholar.library.pdx.edu/open_access_etds

Part of the [Power and Energy Commons](#)

Let us know how access to this document benefits you.

Recommended Citation

Lan, Yudong, "Development of a Testing Station for Grid-Interactive Smart Inverter Systems" (2022).
Dissertations and Theses. Paper 5892.
<https://doi.org/10.15760/etd.7763>

This Thesis is brought to you for free and open access. It has been accepted for inclusion in Dissertations and Theses by an authorized administrator of PDXScholar. Please contact us if we can make this document more accessible: pdxscholar@pdx.edu.

Development of a Testing Station for Grid-Interactive Smart Inverter Systems

by

Yudong Lan

A thesis submitted in partial fulfillment of the
requirements for the degree of

Master of Science
in
Electrical and Computer Engineering

Thesis Committee:
Robert Bass, Chair
Mahima Gupta
John M. Acken

Portland State University
2021

© 2021 Yudong Lan

Abstract

As renewable energy penetration increases within the electrical power grid, flexible power is required to ensure reliability. Reliability can be jeopardized by the fluctuation and non-dispatch ability of renewable generators. This instability is caused by an imbalance between the amount of power produced and the amount of power consumed. Grid-enabled battery inverter systems are considered a solution to offset voltage and frequency fluctuations, which arise due to this power imbalance.

The objective of this work is to develop a system for testing grid-enabled inverters. These inverters use one or more communication standards to control their interactions with the grid. This testing system verifies bis functionality before utilities deploy them to provide grid services. The system contains three portions. One is the hardware components of the system. Next is the information exchange using communication protocols. The third is the testing procedures that check if the bis does what is expected when it receives control commands.

Dedication

For my parents and my girlfriend who always believe and support me

Acknowledgements

Throughout the entire research period, I received so much support from my professor, family, friends, and my girlfriend. Without their help and support, I would not have finished my thesis research.

I would like first thank my professor, Dr. Robert Bass, for allowing me to join the research group. His patience, guidance, and experience helped me to be a qualified researcher. I also want to thank a Ph.D. Tylor Slay. He gave me so much help with program writing, interacting between hardware and software, and troubleshooting with Raspberry Pi.

The people I want to thank the most are my parents, Zhimei Wang and Wenzhao Lan. Without their support, I would not have had the opportunity to study abroad nor would I have had a chance to improve myself. My appreciation also goes to my girlfriend, Jihong Guo. She accompanied me during the pandemic and my research period. Without her, I cannot imagine how I would have lived through this time.

A special thanks go to my friend Shahad Alomani. She provided precious suggestions and guidelines to my thesis writing. It is her help that enabled me to do a better job on my thesis writing.

Contents

Abstract	i
Dedication	ii
Acknowledgements	iii
List of Tables	vii
List of Figures	ix
Acronyms	xii
1 Introduction	1
1.1 Problem Statement	1
1.2 Objectives of Work	2
2 literature review	3
2.1 Distributed Energy Resources	3
2.2 Battery Storage	3
2.2.1 Battery Storage Trend	4
2.2.2 Applications	5
2.3 Smart Inverter	5
2.4 California Rule 21	6
2.4.1 Phase 1	7
2.4.2 Phase 2	8
2.4.3 Phase 3	9
2.5 IEEE 2030.5	10
2.6 Use of IEEE 2030.5 between Server and Client	11
3 Smart Inverter Test Station	13
3.1 Smart Inverter	14
3.2 Battery Storage System	16
3.3 Grid Simulator	18
3.4 PA 4000 Power Analyzer	19
3.5 TDS2000B Digital Storage Oscilloscope	19

4	DER Program Development	20
4.1	DER attributes	21
4.1.1	randomizeStart	21
4.1.2	randomizeDuration	21
4.1.3	opModEnergize	22
4.1.4	opModFixedW	22
4.1.5	DateTimeInterval	22
4.1.6	opModVoltVar	22
4.1.7	opModFreqWatt	23
4.2	DER Program Overview	23
4.3	DER Control Overview	24
4.4	DER Curve Overview	25
4.5	Testing Program of DER-Inverter	26
5	Testing procedure	27
5.1	Check battery level	27
5.2	Firmware update	29
5.2.1	Firmware checking	29
5.2.2	Firmware Update	30
5.2.3	GS8048A firmware update	32
5.3	Setting the Grid Simulator	33
5.3.1	Change configuration of grid simulator NHR 9410	34
5.3.2	Change settings of grid simulator using the software NHR 9400 panel	35
5.4	Setting the GS8048A smart inverter	37
5.4.1	Turn on the inverter	37
5.4.2	Enable module GS8048A and GS4048A	38
5.4.3	Enable Grid-Tied Mode	39
5.4.4	Change Relay Operation Time	40
5.4.5	Selling power to grid	41
5.5	Identify IP address of AXS port	41
5.6	Charging Battery	42
5.7	Remote Development of the DER program on the Raspberry Pi	43
5.8	Measuring output parameters from inverter	45
5.9	Checking SunSpec Registers Status	47
5.9.1	Using modbus poll software	47
5.9.2	Using Outback Shell program	49
5.9.3	Running DER program	50
6	Results & Analysis	51
6.1	Verify The Values Written Into The SunSpec Registers	51
6.2	Energize and De-energize Testing	53
6.2.1	Energize and De-energize Testing Analysis	54
6.3	Maximum Export Power Testing	55

6.3.1	Maximum Export Power interoperability Testing Analysis	56
6.3.2	Maximum Power Export Testing Connected with Grid Simulator . .	57
6.3.3	Maximum Export Power Sub-component Testing Analysis	59
6.4	Volt-VAr function Testing	60
6.4.1	Verification of Writing Volt-VAr Curve Points	61
6.4.2	Volt-VAr function interoperability testing analysis	63
6.4.3	GS8048A Volt-VAr Function Testing with Grid Simulator	63
6.4.4	Volt-VAr function Sub-component Testing Analysis	76
6.5	Frequency Watt Function Testing	77
6.5.1	Verification of Writing Frequency-Watt Curve Points	79
6.5.2	Frequency-Watt function interoperability testing analysis	81
6.5.3	Frequency-Watt Sub-component testing preparation	82
6.5.4	GS8048A Frequency-Watt Function Testing with Grid Simulator . .	83
6.5.5	Frequency-Watt function Sub-component Testing Analysis	97
7	Conclusion	98
	Bibliography	100

List of Tables

3.1	Voltage reference points and time for battery charging.	17
4.1	Mapping IEEE 2030.5 to SunSpec register.	26
5.1	SunSpe registers as shown in Modbus Poll.	48
6.1	Result of writing and transferring IEEE 2030.5 “ <i>opmodConnect</i> ” to SunSpec “ <i>Conn</i> ”	53
6.2	Verify energize and de-energize numbers were transferred into SunSpec registers using OutBack Shell Program	53
6.3	Verify Energize or De-energize of an inverter through observing the voltage and current changes	54
6.4	Test result of verifying connection and setting maximum power of the inverter. .	55
6.5	Using DER program to set curve points for Volt-VAr function.	61
6.6	Verify Volt-VAr points were transferred into SunSpec registers using OutBack Shell program.	62
6.7	Default Volt-VAr curve points.	64
6.8	Default Volt-VAr curve points.	65
6.9	Minimum Volt-VAr curve points.	68
6.10	Minimum Volt-VAr curve points.	69
6.11	Maximum Volt-VAr curve points.	72
6.12	Maximum Volt-VAr curve points.	73
6.13	Using DER program to write values into SunSpec registers Hz 1 to Hz 4	80
6.14	Using DER program to write values into SunSpec registers W1 to W4.	80
6.15	Verify frequency-Watt points were transferred into SunSpec registers using OutBack Shell program.	81
6.16	Control parameters of the Freq-Watt function in GS 8048A smart inverter . . .	82
6.17	Frequency-Watt curve points with 58 Hz and 61 Hz sweep from the minimum to the maximum frequency.	84
6.18	Frequency-Watt curve points with 58 Hz and 61 Hz sweep from the maximum to the minimum frequency.	85
6.19	Frequency-Watt curve points with 58 Hz and 61 Hz sweep from the minimum to the maximum frequency.	89
6.20	Frequency-Watt testing (61 Hz - 55 Hz) with 2ss and maximum power capacity	90

6.21	Frequency-Watt testing (59.5 Hz - 65 Hz) with 2 seconds time step and half power capacity	93
6.22	Frequency-Watt testing (65 Hz - 59.5 Hz) with 2 seconds time step and full power capacity	95

List of Figures

2.1	Large scale battery storage usage trend	4
2.2	Small scale battery usage trend	5
2.3	Worldwide smart inverter usage trend	7
2.4	Utility to DER communication working algorithm	12
3.1	Smart inverter test station	14
3.2	Radian series GS8048A smart inverter	15
3.3	Mate3s	16
3.4	SunSpec Modbus interface	16
3.5	Aqueous Hybrid Ion battery	17
3.6	NHR grid simulator	18
3.7	Power Analyzer	19
3.8	Oscilloscope	19
4.1	DER Program flow chart	24
4.2	DER Control flow chart	25
4.3	DER curve flow chart	25
5.1	MATE3s home screen	27
5.2	Hot and neutral line of GS8048A smart inverter	28
5.3	Dr. Meter power supply	28
5.4	MATE3s password	29
5.5	Firmware interface of MATE3s and GS8048A inverter	30
5.6	Power rack	33
5.7	Circuit of grid simulator	34
5.8	Circuit breaker on power rack	34
5.9	Neutral switch on power rack	35
5.10	NHR 9410 software interface	35
5.11	Configuring grid simulator on NHR software	36
5.12	Power switch of GS8048A smart inverter	37
5.13	Module selection on GS8048A	38
5.14	Enable Grid Tied mode of GS8048A	39
5.15	Enable Offset operation of GS8048A	40
5.16	Time delay settings for GS8048A	41
5.17	Inverter IP address	42

5.18	Battery voltage reference points	43
5.19	Outback Shell	50
6.1	SunSpec blocks in AXS port	52
6.2	Verify the maximum power written into the SunSpec register	56
6.3	Maximum active power export from inverter	57
6.4	Grid simulator absorb power from load	58
6.5	Grid simulator export power to load	58
6.6	Exporting half power from inverter	59
6.7	Standard Volt-VAr curve	60
6.8	Expected Volt VAr curve	62
6.9	Default Volt-VAr curve sweep voltage from the minimum to maximum with 2 seconds time step	64
6.10	Default Volt-VAr testing sweep voltage from high to low with 2 seconds time step	66
6.11	Default Volt-VAr testing sweep voltage from low to high with 5 seconds time step	67
6.12	Default Volt-VAr testing sweep voltage from high to low with 5 seconds time step	67
6.13	Minimum Volt-VAr testing sweep voltage from low to high with 2 seconds time step	69
6.14	Minimum Volt-VAr testing sweep voltage from the high to low with 2 seconds time step	70
6.15	Minimum Volt-VAr testing sweep voltage from low to high with 5 seconds time step	70
6.16	Minimum Volt-VAr testing sweep voltage from high to low with 5 seconds time step	71
6.17	Maximum Volt-VAr testing sweep voltage from low to high with 2 seconds time step	73
6.18	Maximum Volt-VAr testing sweep voltage from high to low with 2 seconds time step	74
6.19	Maximum Volt-VAr testing sweep voltage from low to high with 5 seconds time step	74
6.20	Maximum Volt-VAr testing sweep voltage from high to low with 5 seconds time step	75
6.21	Frequency-Watt curve for over-frequency	77
6.22	Bi-directional Frequency-Watt Curve	78
6.23	User-defined expected bi-directional Frequency-Watt curve.	79
6.24	Frequency-Watt testing (58Hz - 61 Hz) with 2 seconds time step and half power capacity	84
6.25	Frequency-Watt testing (61 Hz - 58 Hz) with 2 seconds time step and maximum power capacity	86
6.26	Frequency-Watt testing (58 Hz - 61 Hz) with 5 seconds time step and maximum power capacity	87
6.27	Frequency-Watt testing (61 Hz - 58 Hz) with 5 seconds time step and maximum power capacity	87

6.28	Frequency-Watt testing (55 Hz - 61 Hz) with 2 seconds time step and maximum power capacity	89
6.29	Frequency-Watt testing (55 Hz - 61 Hz) with 2 seconds time step and maximum power capacity	90
6.30	Frequency-Watt testing (55 Hz - 61 Hz) with 5 seconds time step and maximum power capacity	91
6.31	Frequency-Watt testing (61 Hz - 55 Hz) with 5 seconds time step and maximum power capacity	92
6.32	Frequency-Watt testing (59.5 Hz - 65 Hz) with 2 seconds time step and half power capacity	94
6.33	Frequency-Watt testing (65 Hz - 59.5 Hz) with 2 seconds time step and full power capacity	95
6.34	Frequency-Watt testing (59.5 Hz - 65 Hz) with 5 seconds time step and full power capacity	96
6.35	Frequency-Watt testing (65 Hz - 59.5 Hz) with 5 seconds time step and full power capacity	97

Acronyms

AHI Aquion Hybrid Ion

AXS Axis Port Gateway

BIS Battery Inverter System

CSIP Common Smart Inverter Profile

DCM Distributed Control Module

DER Distributed Energy Resource

DERMS Distributed Energy Resource Management System

DHCP Dynamic Host Configuration Protocol

EGoT Energy Grid of Things

EIA Environmental Impact Assessment

EVSE Electrical Vehicle Service Equipment

FSA Function Set Assignment

FTP File Transfer Protocol

HTTP Hypertext Transfer Protocol

HVAC Heating Ventilation and Air Conditioning

IDE Integrated Development Environment

IEC International Electrotechnical Commission

IEEE Institute of Electrical and Electronics Engineers

IP Internet Protocol

ISOs Independent System Operators

LAN Local Area Network

MAC Media Access Control

NHR NH Research

RTOs Regional Transmission Organizations

SIWG Smart Inverter Working Group

TCP Transmission Control Protocol

UPS Uninterruptible Power Supply

UTC Coordinated Universal Time

XML Extensible Markup Language

1 Introduction

1.1 Problem Statement

The electrical grid must have the capacity to transfer all the power generated from the power plant to satisfy load demand. However, load demand varies vastly during a day, and generators face a big challenge in the peak-to-base spread to match this load demand [1]. Additionally, around 20% of generation capacity needs to be provided in case of an unpredicted real power increase in load demand because of uncertainty in generation availability [2]. Moreover, reliability decreases as more non-dispatchable renewable energy becomes involved in the power grid. The output power from renewable generators fluctuates a lot because of weather and environmental conditions. Renewable generation is also non-dispatchable; it is only available when weather conditions are right. This could lead to an unstable grid frequency [3]. Therefore, Battery Inverter System (BIS)s are being considered as a solution that can help address the above problems. BISs are capable of quickly responding to grid demand, and provide energy storage to continue supply power for a period of time [4]. However, in order to dispatch BIS, inverters must be able to communicate with a Distributed Energy Resource Management System (DERMS). To do this, BIS use communication protocols such as Institute of Electrical and Electronics Engineers (IEEE) 2030.5 and Modbus SunSpec. And, the information exchange between

the BIS and DERMS must be functionally correct.

1.2 Objectives of Work

Grid operators can not control millions of Distributed Energy Resources (DERs) individually, so DERMSs are used to aggregate many DERs. A DERMS is a software platform that is able to dispatch a very large number of DERs simultaneously and automatically, such as BIS, Electrical Vehicle Service Equipment (EVSE), and residential appliances through information exchange with a controller installed on each DER [5]. In this research, the DER of concern are BISs. However, to successfully dispatch BISs before they interact with an electric grid, there must be a communication bridge. For instance, the communication standard for a DERMS maybe IEEE 2030.5 while the standard for a BIS maybe SunSpec Modbus. The information exchange between the DERMS and BIS must be functionally correct, which means the BIS must correctly perform a specified action for each message it receives.

Therefore, the objective for this thesis is to create a testing system for grid-enabled BIS to test this functionality. This system tests grid-enabled BIS working under different communication protocols to ensure the BIS does what is expected when it receives a resource message from a DERMS. This testing must be done before a BIS can be deployed in an electric power system. The functional testing conducted in this research demonstrates the ability of this system to test grid-enabled BIS.

2 literature review

2.1 Distributed Energy Resources

DERs are customer-owned generation, storage, and load assets that are grid-enabled. These resources are located behind a customer meter and are not traditionally directly managed by utilities. DER are usually small in size and support modularity. Generally, the capacity of DER is less than 10 kilowatts (kW). Wind turbines, photovoltaics (PV), fuel cells, and energy storage systems are the most widely applied generation DER. Storage DER are usually BIS. Load DER include HVAC systems, electric water heaters, EVSE and so on. Utilities are interested in using DER to reduce load or add power generation in order to maintain the stability of the power grid by reducing peak load demand, regulating frequency, and regulating voltage [6].

2.2 Battery Storage

As an increasingly adopted energy storage system, battery storage systems are deployed on both the utility-scale and the residential scale. To better understand the usage situations and applications of a battery storage system, the following subsections are provided.

2.2.1 Battery Storage Trend

Battery Inverter System include low-power uses such as installed in a home or as high-power resources for a utility to support the grid. As reported by the EIA in the United States, the amount of power capacity added to the grid between 2003 and 2010 from large-scale battery storage system was only 59 MW in the US [7]. However, this situation has completely changed since 2011. As of 2018, there was 869 MW of power capacity installed in the form of large-scale BIS [7]. Moreover, there was a rapid large-scale power installation increase between 2015 and 2018, as shown in Figure 2.1. Independent System Operators (ISOs) and Regional Transmission Organizations (RTOs) are major users of large-scale BIS [7].

Figure 2.1: Large-scale battery storage capacity by region (2003-2018) [7].

Not only large-scale battery storage system, but small-scale battery storage power also has a bright future. As reported in 2018, the power capacity of small-scale battery storage was 234 MW in the US [7]. More than 50% of this capacity was used for commercial purposes,

31% power was installed for residences, 15% used in industry, and 3% was connected to the distribution grid. Small-scale battery usage in the residential and commercial fields has grown quickly in recent years and is being deployed in many states in the U.S., as shown in Figure 2.2.

Figure 2.2: The usage purpose and location of small-scale battery storage systems in the US [7].

2.2.2 Applications

Current utility-scale BIS provide grid-scale services such as peak load shifting, frequency and voltage regulating, excess power storing, and so on. However, grid-interactive small-scale BIS are also under development. Small-scale batteries deployed in residence and commercial locations provide power outage protection and optimize energy usage.

2.3 Smart Inverter

Unlike a traditional inverter that simply feeds power into the grid, a smart inverter can dynamically work with the grid to increase grid reliability and stability. In other words, a

smart inverter can autonomously make decisions to help maintain reliability. To achieve autonomous control, a smart inverter must be programmable to allow precise control of its input and output power as well as its ramp rate. In addition, a smart inverter should also be capable of grid-support functions and have the ability for bidirectional communication. As more DERs equipped with grid-support functionality become available, utilities can work with them to compensate the grid. These DERs can be valuable assets instead of a burden to the grid [8].

When connected to DERMS, smart inverters can instruct BIS to make react in responds to message from a utility to help solve problems of grid abnormalities. Moreover, DERMS can reprogram smart inverters in real-time to make sure the inverters always have the best response to anticipated events on the electric grid [9]. By offering automatic response to electric grid disturbances, smart inverters have become more widely adopted in recent years, as shown in the graph in Figure 2.3

2.4 California Rule 21

CA Rule 21 specifies smart inverter requirements. It was created based on the recommendations of the Smart Inverter Working Group. It has three phase of implementations:

- Phase 1: Autonomous function implementation of smart inverters
- Phase 2: Choose and apply communication requirement to smart inverters
- Phase 3: Add advanced functions to smart inverters

Figure 2.3: World market share of standard inverters and smart inverters[10].

2.4.1 Phase 1

Utilities in each state in the U.S. have different interconnection policies, so some settings of smart inverters have to be configured differently in order to conform to the utilities' interconnection handbook. Once the settings are configured, the smart inverter can be programmed to autonomously adjust the output based on the local conditions, thereby keeping the grid stable and reliable [11]. The functions and settings that need to be configured in smart inverters are:

- **Low/High Voltage Ride-through:** *The inverter must not trip (i.e. disconnect from the grid), during AC voltage excursions outside the normal operating range, during a specified time duration. It must either cease output momentarily, or continue outputting power, depending on the severity of the voltage deviation, while sustaining*

its electrical connection to the grid. The inverter must trip for time durations longer than the ride-through times specified [12].

- *Low/High Frequency Ride-through: The inverter must continue to output power to the grid during AC frequency excursions of specified duration and deviation from the normal operating frequency of 60 Hz. The inverter must trip for time durations longer than the specified ride-through times [12].*
- **Volt-VAr Function:** This function allows smart inverters to dynamically respond to the grid voltage fluctuation by supplying or absorbing VAr to help stabilize the grid.
- **Ramp Rate:** The rate of change in the output power of the inverter
- **Fixed Power Factor:** Provide certain reactive power by setting a fixed power factor
- **Soft Reconnect:** Provide “soft-start” methods
- **Anti-Islanding:** Trip off inverter under long term abnormal condition

2.4.2 Phase 2

In order to exchange information between smart inverters and DERMS, a communication protocol must be selected. According to Gordon Lum: *"This protocol must operate over Transmission Control Protocol (TCP)/Internet Protocol (IP); must operate over different media interfaces; use the international standard International Electrotechnical Commission (IEC) 61850 as the information model; provide cybersecurity at the transport and application layers, and provide cyber-security for user and device authentication"* [11].

Based on the listed restriction above, IEEE 2030.5 was selected as one of three default communication standards. Within IEEE 2030.5, direct control, autonomous curve control,

and other capabilities of DER are well defined. These attributes ensure DERMS can dispatch DERs based on utilities' needs to stabilize the grid.

To describe how one would implement IEEE 2030.5 to satisfy the requirements described in CA Rule 21 Phase 2, a guideline called the Common Smart Inverter Profile (CSIP) was created. The following are some guiding principles of CSIP [13]:

- *All smart inverters require communications to achieve their full value as DER*
- *To achieve complete interoperability, a complete profile is required, including a data model, a messaging model, a communication protocol, and security. Without a complete profile specification it would be impossible to achieve communications interoperability without additional systems integration activities*
- *Leverage existing standards and models from both engineering (e.g., IEEE 1547) and communications (e.g., IEEE 2030.5) standards. The development of a new, stand-alone standard would create additional burdens for all parties and only serve to raise costs of both development and maintenance.*

2.4.3 Phase 3

Advanced functions added to smart inverters will assist in improving power system reliability by reducing effects caused by disturbances, and increase energy efficiency. The following are some advanced functions that the Smart Inverter Working Group (SIWG) completed analysis in smart inverters [14]:

- *Limit maximum real power mode: This function provides a maximum real power limit that a DER client can produce or output to a electrical connection points such as PCC or an aggregation system.*
- *Set Real power mode: This function defines a real power value that a DER client can produce or output to a electrical connection points.*
- *Provide a Frequency-Watt Emergency mode: This mode allows the frequency-watt function to increase or decrease power when the grid frequency is unstable. Also, this mode becomes a controllable setting, which means the frequency-watt function can be either enabled or disabled when needed. The rate of the active power change shall be settable as well.*
- *Provide a Volt-Watt mode: This function try to deal with the issue such as High/Low voltage ride through, localized high service voltage and high penetration of DER systems at the distribution level.*
- *Provide a dynamic reactive current support mode*
- *Allow scheduling of power values and modes*
- *Allow for DER functions that are also important to DER integrators and other third parties*

2.5 IEEE 2030.5

The IEEE 2030.5 communication standard was developed from 2013 through 2018 based on the Common Information Model (CIM), with the goal of creating a message-based commu-

nication standard for the modern grid, distributed smart devices, and interoperability [15]. It adopted a wide-range of communication protocols, such as TCP/IP and Hypertext Transfer Protocol (HTTP), so DER devices can be managed either individually or in aggregate between utilities and end-users [16]. In IEEE 2030.5, the communication messages between a DERMS server and DER clients uses Extensible Markup Language (XML) schema, as defined in IEEE 2030.5 XML Schema. Typically, the server exposes the available resource to the client through hosting the related URL and the client will GET or PUT/POST the updated information back to the resource [17].

2.6 Use of IEEE 2030.5 between Server and Client

The general working algorithm between the DERMS server (or Aggregator) and DER clients is as follow: the server send the control information to the DER client then DER client send information back to the server after executing the control. The DER controls sent from Server to DER devices include [17]:

- Autonomous control: Volt-VAr, Freq-Watt, and Volt-Watt curve based control
- Protection settings: High/Low Voltage Ride-Through, High/Low Frequency Ride through
- Immediate controls: active power curtailment, fixed reactive power, fixed power factor

The information sent from DER client to server include [17]:

- DER nameplate ratings and settings

- DER alarms and status
- DER measurements (W, VAr, V, A, PF, Wh, Hz, etc.)

Fig 2.4 shows a diagram of the communication options between the server and DER clients.

Option C is adopted in this research to show if the inverter provides a functionally correct response to the IEEE 2030.5 messages sent from a DER controller.

Figure 2.4: Utility-to-DER communications options per CA Rule 21 and CSIP [17].

3 Smart Inverter Test Station

The smart inverter test station has three main hardware components: a smart inverter, a battery, and a grid simulator. The smart inverter is the device under test. The battery and the grid simulator support the testing. The smart inverter coupled with a battery is called a BIS. When a controller is used to control the BIS, the whole system will be used as a DER. The controller mentioned here is a Raspberry Pi 3 Model B single-board computer. It communicates with the smart inverter through an Ethernet cable and communicates with DERMS via a Wi-Fi Local Area Network (LAN) in the Portland State University Power Lab. The Raspberry Pi and control software together are composed as a Distributed Control Module (DCM), which communicate with a DERMS. The DCM receives controls from the DERMS and converts them into SunSpec Modbus commands for the inverter. The grid simulator connects to the inverter through a power cord and is used for testing the grid-enabled BIS. The equipment connection of smart inverter test station is shown in Figure 3.1.

Figure 3.1: Equipment connection of the smart inverter test station.

3.1 Smart Inverter

The smart inverter used in this research is a Radian A-series inverter from OutBack POWER company. The model of this inverter is the Radian GS8048A. It has two modules. If only one module is enabled, the maximum output power is 4000 VA. If both modules are enabled, the maximum output power is 8000 VA. Seven AC input modes are available in the inverter: Generator, Support, Grid Tied, Uninterruptible Power Supply (UPS), Backup, Mini Grid, and Grid Zero. Each mode has a different application. In this research, tests are conducted with the inverter in Grid Tied mode because this mode allows the inverter to be a grid-interactive device. Within this mode, the inverter not only absorbs power from the utility grid, but it can also supply power to the grid when excess battery energy is available.

Figure 3.2: Outback Power GS8048A-01 Radian Series 8 kW Inverter [18].

Because the GS8048A does not have a user interface, an external control device is provided for the users to control it. The MATE3s is a system display and controller made by Outback Power. This controller has the ability to set multi-level passwords in case of unintended changes and also provides some necessary functions for user convenience.

Users can also use the Axis Port Gateway (AXS) Modbus TCP communication box to change SunSpec registers in order to set inverter functions. All SunSpec registers are contained in the AXS port. This device supports users to download system data using Modbus-read or File Transfer Protocol (FTP) transfer. Since the AXS is a TCP-supported device, users can set the SunSpec registers using modbus poll or outback shell program installed on the computer through finding the default IP address of the AXS or the IP address assigned by a router using Dynamic Host Configuration Protocol (DHCP).

In this research, both the MATE3s and AXS are all used. According to the GS8048A user manual, "*the MATE3s must be used when upgrading the inverter to firmware revision 001.006.063 or higher* [18]"

Figure 3.3: OutBack MATE3s System Controller Figure 3.4: AXS Modbus/TCP Interface Device [20]. [19].

3.2 Battery Storage System

The battery used in this research is an Aquion Hybrid Ion (AHI) battery. It has a long charge and discharge cycle life span and is designed to serve as a stand-alone system. The battery has twelve battery stacks and each stack can be either connected in parallel or series according to the different stationary applications [21].

Although the battery chemistry is AHI, the three-stage charging process for lead-acid batteries is applied: bulk, absorption, and float. The first charging stage is the bulk charge. In this stage, the battery voltage will increase as a constant current charge the battery. Usually, the battery will reach 75% to 90% of its capacity in this stage. Absorption charge is the second stage in the three-stage charging cycle. In this stage, voltage is constant and current varies to maintain the voltage level. At the end of this stage, the battery will reach 100% of its capacity. Float charge is the third stage of charging. Within this stage, the battery maintains 100% of storage capacity [18]. Otherwise, the inverter will slowly self-discharge. When different types of inverters connect to the AHI battery, some settings of three-stage charging are different. In this research, the smart inverter is the Radian Class Inverter, so the voltage settings and charging time settings are [21]:

Voltage Reference Point	Volts	Hour
Bulk	59.4	N/A
Re-bulk	50	N/A
Absorb	59.4	1 hr
Float	54.4	4 hr
Re-float	52	N/A

Table 3.1: Voltage reference points and time for battery charging.

The re-bulk voltage is the voltage set point for the inverter to restart the charge cycle when battery voltage decreases due to discharge. The re-float charge is still in the float charge stage. Similar to the bulk charge, re-float is also a constant-current charge stage, but it is used to offset the battery self-discharge. Therefore, the charger will use re-float voltage as the set point when the battery voltage lower than this value [18].

Figure 3.5: Aquion Energy Aqueous Hybrid Ion Battery [21].

3.3 Grid Simulator

The NH Research (NHR) 9410-12 grid simulator used in this research is a programmable four-quadrant bi-directional AC/DC power source. It supports grid-tied inverter testing and is capable of providing a wide range of frequencies and voltages. The frequency can be changed between 30 Hz and 100 Hz. The output real power can be adjusted up to 12 kW. The maximum apparent power that the simulator can handle is 33 kVA. The NHR 9410 includes a measurement system, so voltage, current, and power can be monitored in real-time. This grid simulator also supports multiple output power combinations: DC source, 1-phase, 2-phase, and 3-phase AC source [22]. Users can control per-phase magnitudes and waveform when different phases of AC source are under simulation.

In this research, the grid simulator is used for sweeping the voltage and frequency points to test the Volt-VAr and Frequency-Watt function of the inverter once the user-defined values are written into the relevant SunSpec registers.

Figure 3.6: The Regenerative Grid Simulator NHR 9410 [22].

3.4 PA 4000 Power Analyzer

To collect the Volt-VAr, Frequency-Watt, and maximum exporting power testing results, a power analyzer is used. The PA 4000 power analyzer from Tektronix supports multiple channel measurements with high accuracy. It supports up to 30 A maximum current input, which matches the GS8048A smart inverter. Since the inverter is a split-phase unit, two channels are selected to use on the power analyzer to separately monitor the parameters in each phase.

Figure 3.7: PA4000 Power Analyzer [23].

Figure 3.8: TPS2000B Digital Storage Oscilloscope [24].

3.5 TDS2000B Digital Storage Oscilloscope

To verify the reactive power is capacitive or inductive that the inverter provides or absorbs when the Volt-VAr function is enabled, an oscilloscope is used. The oscilloscope can show the leading or lagging refers to current and voltage. When the current leads the voltage, the reactive power is capacitive. In contrast, the reactive power is inductive when the current lags the voltage. The TDS2024C Digital Storage Oscilloscope is from Tektronix. It allows user to quickly and accurately measure a power system without too many operations. This oscilloscope supports four channels, so current and voltage in each phase of the inverter can be shown concurrently.

4 DER Program Development

A BIS DER client is unable to be dispatched by a DERMS server when the communication standard is different, so a communication standard transformation bridge is necessary. The DER bridge program developed in this research relates the specific IEEE 2030.5 (standard of the Portland State University Power lab DERMS) attributes to corresponding SunSpec (standard of the Outback BIS) registers for inverter testing. In the DER program, two features of the inverter must be verified:

1. If the inverter can be energized at a specific time to export or import active power
2. If the Volt-VAr and Frequency-Watt curve points can be set using IEEE 2030.5 attributes and mapped to SunSpec registers in AXS port to enable the related function.

To test the above features, different DER attributes defined in IEEE 2030.5 are used, each of which are defined in the following section.

A DER control is based on an Event. The definition of an Event in IEEE 2030.5 is: "*Any instance of a resource with a defined valid duration for which a client should take action. This would include all resources that are derived from the Event resource defined in the schema (IEEE Std 2030.5 supplemental material)*" [25]. Briefly, an Event is an instance that has been sent from an aggregation server to a distributed client, which contains a scheduled

start time and a finite time duration for a single device or a group of device to take action [26].

4.1 DER attributes

In IEEE 2030.5, many DER attributes are defined for client devices. For the testing system conducted in this research, five attributes are included. These attributes defines the operation time and output power of a smart inverter.

4.1.1 randomizeStart

The randomizeStart attribute defines a time span, in seconds, within which the client device can choose to start an Event any time in the range. For example, if the scheduled start time of an Event is set at 12:00 pm and the randomizeStart is set as -300, the a client device can choose a number between [0,300]. 300 means five minutes, so if a client chooses -120, then the Event will begin at 11:58 pm. The negative sign means a randomized time of an Event will be applied before an Event starts and the positive sign means the opposite [25].

4.1.2 randomizeDuration

Similar to the randomizeStart, randomizeDuration defines a time in seconds for when an Event ends. For example, if an Event is scheduled to end at 12:00 pm and the randomizeDuration is set as -120, then the client device can choose a number from [0, 120]. If a client chooses 60, the Event will end at 11:59 pm. A negative sign means an Event will end before the scheduled time and a positive sign means the opposite [25].

4.1.3 opModEnergize

The opModEnergize attribute defines if the DER client connects or disconnects to the power source or electric grid. This attribute is a Boolean condition. 0 is "disconnected" and 1 is "connected" [25].

4.1.4 opModFixedW

To set Active Power Mode, two DER attributes are available: opModFixedW and opModTargetW. opModFixedW determines a set point in percentage of maximum power. The opModTargetW determines a set point in Watts. However, opModTargetW is more suitable for aggregators, not for DER, so opModFixedW is selected to set the power level of the smart inverter in this research [25].

4.1.5 DateTimeInterval

The DateTimeInterval attribute is used to set the time interval of a DERControl event for a DER client. This attribute counts time in seconds. The time interval of each event shall be no longer than 86400 seconds (1 day) [25].

4.1.6 opModVoltVar

The opModVoltVar attribute defines a curve control-based static Volt-VAr function. The Volt-VAr curve is created by an array with multiple pairs of points. The pairs are interpolated into a linear function with hysteresis. The x value of each pair of points is a

percentage voltage value referred to the reference voltage and the y value is a signed percentage value (-100, 100) [25].

4.1.7 opModFreqWatt

The opModFreqWatt attribute defines a curve controlled function. The Freq-Watt curve is created by an array with multiple pairs of points. The pairs are interpolated into a linear function with hysteresis [25]. The x value of each pair of points is a frequency value in Hz and the y value is a corresponding active power output value [25].

4.2 DER Program Overview

Each DER client is managed by a single DERControl event that follows the DER control algorithm. The DER control flow chart is shown in Figure 4.1. Before the control event is exposed to the DER client, the first step for clients is to identify which Function Set Assignment (FSA) applies to them. A FSA is a collection of resources related to the specific device. Then a DER client needs to distinguish the particular DERProgram related to the FSA. The DERProgram is composed of four control links: Default DER Control link, Active DER Control list link, DER Control list link, and DER Curve control list link. After entering the specific DER link, the client needs to determine which controls it needs. After distinguishing the specific controls, the client needs to read the control information and expose the related control parameters to the specific device based on the information.

Figure 4.1: DER Program flow chart.

4.3 DER Control Overview

Before executing the control event, the client firstly determines if an active control event is coming. If there is no active event, then the client will use the default control to set the device. If the active event exists, then the client needs to identify the device category type to make sure if the event is for the device it controls. If the event is not for the device, then the client will ignore it. If the event is for the device, then the client needs to determine the status of the event. If the event is active, the client shall calculate the effective start time and specific end time. If the effective start time is in the past and the end time is in the future, then the client shall use the current time to set the control parameters by entering the control base. If the event is superseded, the client shall terminate the current event immediately and execute the new event. If the event is cancelled, the client shall determine if the cancellation event is applied to them and cancel the event instantly if possible. If the event is scheduled, the client need to keep the event until the event becomes active [25]. The flow chart of DER

control is shown in Figure 4.2.

Figure 4.2: DER Control flow chart.

4.4 DER Curve Overview

Some functions of the distributed device, such as Volt-VAr and Frequency-Watt, are curve-based control function. For curve control events, the client need to firstly distinguish the curve type of the event and then set the relevant control parameters of the curve. To determine the shape of the curve, the client needs to set points on the curve using the curve data library.

Figure 4.3: DER curve flow chart.

4.5 Testing Program of DER-Inverter

The DER program developed in this research is mainly focused on executing the DER-Control event to test the inverter. This DER program consists of three parts. The first part is trying to test if the inverter is capable of consuming or supplying power at a specific time. The second part is trying to test if Volt-VAr control can be enabled and used when IEEE 2030.5 attributes are involved to control the inverter. The third part is similar to the second part except the control function is changed to Frequency-Watt control. To control the inverter using the DER program, all IEEE 2030.5 attributes are mapped to related SunSpec Modbus registers in the AXS port. To create a scheduled time for a smart inverter to energize and de-energize, the Chrono library is used to get current time to refer to the Coordinated Universal Time (UTC). According to CSIP [13], the SunSpec registers in DER Grid Support Functions associated with IEEE 2030.5 attributes are shown in Table 4.1.

Using Purpose	IEEE 2030.5 attribute	SunSpec Block	SunSpec Register	SunSpec Register Description
Energize or De-energize inverter	opmodEnergize	123	Conn	Connection Control
Set maximum real power level of inverter	opmodFixedW	123	WMaxLimPct	Set maximum Power lelve
Create a user-defined Volt-VAr Curve	opmodVoltVAr	126	Static Volt-VAr	Static Volt-VAr array
Crteate a user-defined Freq-Watt Curve	opmodFreqWatt	134	Freq-Watt Crv	Curve Based Freq-Watt array

Table 4.1: Mapping IEEE 2030.5 to SunSpec register.

5 Testing procedure

To test the grid-enabled GS8048A smart inverter, specific testing procedures are required. The testing procedures include charging the battery, setting the inverter, configuring the grid simulator, installing the package on Raspberry Pi, running the DER program, and interacting with the smart inverter and grid simulator.

5.1 Check battery level

Before setting the GS8048A smart inverter, checking the battery voltage is always necessary since the inverter does not work until the battery voltage is greater than or equal to 44 VDC. To measure the battery voltage initially, the MATE3s system display and controller is used. The battery voltage information is located on the top right corner of the home screen of the MATE3s as shown in Figure 5.1. The battery voltage shown in 5.1 is a percentage value, but it can be programmed to show a real voltage value.

Figure 5.1: MATE3s home screen [27].

However, using the MATE3s to check battery voltage is only possible when the battery voltage is above 44 VDC. If the battery voltage below 44 VDC, a voltmeter has to be used to measure the voltage. This is done by measuring voltages between the hot and neutral terminals, which are connected below the smart inverter as shown in Figure 5.2. Note that a battery voltage measured using a voltmeter will be zero if the switch of the inverter is not in the *On* position.

Figure 5.2: Hot and neutral line used to measure battery voltage.

If the battery voltage is lower than 44 VDC, the battery needs to be charged until the voltage level increases to 44 volts to initiate the GS8048A smart inverter. This process requires an external DC power supply to provide a constant current charge. The DC power supply used to do this is the PS305DM-DC Bench Power Supply from Dr. Meter, shown in Figure 5.3.

Figure 5.3: Dr.Meter Single-output Regulated Variable DC Power Supply.

The maximum absorb voltage in the battery charge field of the GS8048A is 64 VDC [18]. The absorption voltage at $25^{\circ}C$ ambient temperature for the Aquion ion battery is 66 VDC. The average current into the battery is 10 A [21]. Since the ambient temperature of the inverter is usually around $25^{\circ}C$, choosing a charge current of 10 Amps until the voltage increased to 44 VDC is reasonable. The output constant current setting of the DC power supply can be found on pages 7 and 8 in section 4.2- Constant Current Settings in the PS305DM-DC Bench Power Supply user manual [28].

5.2 Firmware update

5.2.1 Firmware checking

In order to manipulate the inverter using the MATE3s and AXS port, the firmware versions of these devices should always support each other. The current firmware version of the GS8048A and the MATE3s can be found within the MATE3s. To check the firmware information, execute the following steps as ordered:

1. When the MATE3s illuminates after the inverter startes, **click** the hot key **Lock** on the MATE3s. At this time, a screen will shown as 5.4.

Figure 5.4: Password interface after click hot key lock.

2. The user number of the inverter is 132 and the installer password is 0311.

3. After entering the password, go to **Setting** → **System** → **Firmware Versions**.
4. All the firmware version of the devices that connected to GS8048A are shown here.

Figure 5.5: Firmware interface shown on MATE3s.

The user number 132 is to change the basic settings of the inverter. In this research, module GS8048A is modified in user 132. In case of change settings by mistake, user 141 is being used. Some functions are hidden in 141 such as module selection.

The MATE3s cannot read version information of the AXS port because MATE3s does not support communicate with the AXS port. Hence, the MATE3s cannot work at the same time as the AXS port. To check the firmware version of the AXS port, both approaches work as follow:

- open the read-me file that is stored in the SD card inserted in the AXS port
- read the OutBack Block information through using Modbus poll software

5.2.2 Firmware Update

The firmware update files of the MATE3s, AXS port, and GS8048A can all be found on the official website of Outback Power. Note that incompatible firmware versions between the MATE3s, AXS port, and GS8048A will lead to the MATE3s and AXS port being unable to control the GS8048A. Therefore, double check the firmware version of these devices.

5.2.2.1 AXS port update

The firmware version of the AXS port can be updated using a micro SD card or using an FTP site with a micro SD card. However, directly using a micro SD card is easier for a user who firstly uses the AXS port. The specific procedures for updating the AXS port are well explained in the AXS port user manual on page 16-17 [20].

5.2.2.2 MATE3s update

The firmware update procedures are shown below:

1. Take the SD card from the MATE3s
2. Download the needed version of firmware from the official website
3. Then unzip the download folder
4. Open the download folder and keep the window open
5. Insert the SD card on the computer
6. Open the SD card folder and keep the window open
7. If any files existing in SD card, move the files to any folder you can memorize incase of unexpected changes
8. Format or erase the card before copying the firmware files
 - a) Back to the SD card window
 - b) Right-click the removeable drive icon and select format from the pop-up window.
 - c) Make sure the Files system is selected as FAT
 - d) Then press start
9. Copy all download files into the SD card folder

10. Make sure have 5 files: WEBFILES, M3e.bin, M3Ethev3.bin, MATE3 (version number) Read Me.txt, screens.xml
11. Insert the SD card back to MATE3s
12. Power the MATE3s
13. Open MATE3s and enter the user number 141
14. Then go to Main Menu find **Settngs**→**System**→**Clear Internal Date Log**→**Yes**
15. Go back to Main Menu find **Firmware update** → **MATE3** → **Update**
16. Do not unplug or reset until MATE3s Restarts.
17. Wait for two more minutes until the MATE3s can show information like battery voltage level

5.2.3 GS8048A firmware update

The procedures for updating the GS8048A is similar to that of the MATE3s.

1. Take the SD card from the MATE3s
2. Download the needed version of firmware from the official website
3. Then unzip the download folder
4. Open the download folder and keep the window open
5. Insert the SD card on the computer
6. Open the SD card folder and keep the window open
7. Copy all downlaod files into the SD card folder. (The existing files can be replaced)
8. Eject the SD card from computer
9. Insert the SD card back to MATE3s.
10. Power the MATE3s
11. Open MATE3s and change the user number to 141.
12. Go to Main Menu

13. Click **Firmware update** → **GS Inverter**
14. The newer version firmware should display
15. Click **Update**
16. Wait until the screen on the MATE3s shows "All Inverters Update"

5.3 Setting the Grid Simulator

The NHR 9410-12 grid simulator is used in this testing system to test the functions of the grid-enabled GS8048A inverter through control of grid frequency and voltage. Before interacting with the GS8048A, the configuration of the Grid simulator has to be changed and the monitor program has to be ready to observe the voltage, current, real power, complex power, and frequency. Since the grid simulator cannot directly connect with the inverter, a rack was created to provide a power interface, shown in Figure 5.6

Figure 5.6: This rack provides a power interface between the GS8048A smart inverter and the NHR 9410-12 Grid Simulator.

5.3.1 Change configuration of grid simulator NHR 9410

The Grid simulator NHR 9410 supports several different voltage configurations. To test grid-enabled smart inverters, the Grid-Simulator shall be adjusted to a specific configuration, 120/240 VAC.

1. Check the state of the grid simulator and make sure it is powered off. (As shown in Figure 5.7: turn the circuit breaker to the right to power off the grid simulator.)

Figure 5.7: Circuit breaker of NHR 9410-12 smart grid simulator.

2. Configuring grid simulator to 120/240 VAC split phase on the rack:
 - a) Turn on circuit breakers (the switch on the right) labeled as 240 V as shown in Figure 5.8.

Figure 5.8: Circuit breakers of different output voltages.

- b) Change neutral switching mode into mode 5: One 2-phase AC and One AC
- c) Turn off S-1, S-2, S-3, and S-4 neutral switches as shown below
- d) Turn on S-5 neutral switch as shown below

Figure 5.9: Neutral switch of different output voltages.

5.3.2 Change settings of grid simulator using the software NHR 9400 panel

- a) Open the NHR 9400 Panel user interface on power lab computer PWRLAB04.ece.pdx.edu.

The NHR 9400 Panel interface is shown in Figure 5.10

Figure 5.10: NHR 9410 grid simulator user interface software.

- b) Verify the IP address of the NHR 9400 grid simulator on the top left corner
(192.168.0.149)

- c) Click “Connect” next to the IP address
- d) Click “Configure” on the top right corner
- e) A window will pop out, Click “Yes” to change the configuration
- f) A window called “Configure Hardware” will be displayed, as shown in Figure

5.11

Figure 5.11: Change NHR grid simulator wire configuration setting.

- g) Change the “Mode” to 2-Phase AC1 and AC3
 - h) Click "Ok" to finish setting split phase for inverter
 - i) Go back to home interface
 - j) Change the voltage value from top to the bottom in AC GRID 1 as shown in
- Figure 5.10
- i. 240 V - The first voltage value (split phase value)

- ii. 120 V – The second voltage value (A-phase)
 - iii. 120 V- The third voltage value (B-phase)
3. Click “ON” to enable grid simulator. (Note: This step SHALL take action after connect the power trip of the inverter to the rack)

5.4 Setting the GS8048A smart inverter

The inverter is unable to undergo any testing if it is not in the correct operating mode and the connected battery voltage is low. Therefore, some settings must be changed to ensure the inverter is ready for testing.

5.4.1 Turn on the inverter

1. Put on insulating gloves
2. Connect power trip of inverter to the rack as shown in Figure 5.6
3. Turn the red switch on as shown in Figure 5.12

Figure 5.12: Power switch to turn on inverter.

5.4.2 Enable module GS8048A and GS4048A

As mentioned before, the smart inverter used in this research has three modes. Mode 1: uses only one 4 kVA module (GS4048). Mode 2: uses two 4 kVA modules (GS8048) simultaneously, 0 - 8 kVA. Mode 3: uses two modules, but sequentially, firstly using one module for 0-4 kVA and then two modules for 4 kVA-8 kVA (GS8048). The third module is more efficient but there is a switch-over period that affects performance. In this research, the mode 2 is used for testing the function of the inverter. The DC input power of GS8048A is 9.5 kVA and output power is 8 kVA. Either mode mentioned above can be selected using MATE3s. To select the GS8048, the following steps should be executed as ordered:

1. If the GS8048A is working without any interruptions, then there is **no need** to enter the user number and installer password.
2. If the GS8048A is interrupted when it is normally working, then user **has to** enter the user number and installer password.
3. After entering the password, go to **Setting** → **Inverter** → **Module select** → **GS8048A**.
4. **Select** module GS8048A.
5. The mode that is currently selected will be shown in Figure 5.13.

Figure 5.13: GS8048A is selected as the default mode.

5.4.3 Enable Grid-Tied Mode

The Grid Tied mode enables the smart inverter to interact with the electric grid. In other words, the inverter can export power back to electric grid when excess power is available in the battery. However, in order to export power to the utility, the inverter has to use the operation of **Offset**. This operation is not a programmable function. It is an automatic operation that will export energy from the battery to compensate for the power when the load demand is higher than the power from the AC source. To enable the grid-tied mode, operate the MATE3s as followings:

1. If the GS8048A is working without any interruption, then there is **no need** to enter the user number and installer password.
2. If the GS8048A is interrupted when it normally working, then the user **has to** enter the user number and installer password.
3. After entering the password if needed, go to **Setting** → **Inverter** → **Grid AC input Mode and Limits** → select the **Grid Tied** input mode.
4. After finish setting, the result should be the same as Figure 5.14

Figure 5.14: Grid Tied mode is selected as the operation mode.

To enable the **Offset** operation, the following steps should be executed as ordered:

1. Back to **Main Menu** of MATE3s
2. Go to **Setting** → **Inverter** → **Grid-Tie Sell**
3. Inside of **Grid-Tie Sell**, the user can enable the offset operation, as shown in Figure 5.15

Figure 5.15: Offset operation enabled to export power from inverter.

5.4.4 Change Relay Operation Time

A time delay exists before the inverter exports power to the utility grid. In this time duration, the inverter will not connect to the grid and export power. This time setting is controlled by the function **Re-Connect Delay Timer**. The time is default-set to five minutes, but it is adjustable [18]. To change the relay time, the following steps should be executed in the MATE3s as ordered:

1. Back to Main Menu
2. Go to **Settings** → **Inverter** → **Grid Interface Protection** → **Grid Support** → **Re-connect Parameters**
3. In **Reconnect Parameters**, the Reconnect Delay can be changed, in seconds, as shown in Figure 5.16

Figure 5.16: Time delay setting before inverter export power.

5.4.5 Selling power to grid

To test if GS8048A can export power from the inverter, some settings should be changed using the MATE3s in advance before exporting power from the inverter.

1. Go back to the main menu
2. GO to **Inverter** → **Grid-Tie Sell** → Enable the offset operation
3. Change the **Sell Voltage** value higher than current battery voltage.
4. Click hot key **Inverter** on MATE3s
5. Turn on the Mode from **Off** to **On**
6. Go back to home screen of the MATE3s
7. Observing output power level of GS8048A.

5.5 Identify IP address of AXS port

Before modifying the SunSpec registers to control the GS8048A, the first step is to identify the IP address of the AXS port. To find the AXS port IP address, users first need to know

the Media Access Control (MAC) address of the AXS port. The MAC address is a unique identifier used to distinguish this device in a network. The MAC address of the AXS port is labeled on the interface of the device. After identifying the MAC address of the AXS port, users can find the IP address that was randomly assigned by the router on the IP address interface of the router. Since the MAC address and the IP address are both shown on the IP address interface of the router, users determine the IP address of the AXS port directly. In Figure 5.17, the name "Unknown" with the MAC address 00:90:EA:E0:87:6D represents the AXS port.

ID	Name	IP Address	MAC Address
1	DESKTOP-GHOSMTS	192.168.0.100	34:E8:94:F0:43:25
2	Unknown	192.168.0.102	00:90:EA:E0:87:6D
3	pi3	192.168.0.101	B8:27:EB:95:82:3B

Figure 5.17: TP-Link 6A92 LAN router interface.

5.6 Charging Battery

To keep the AHI battery healthy, the voltage level of the battery must always be maintained between 30 VDC and 59 VDC. If the voltage is outside of this safety voltage range for a while, chemical damage to the battery occurs. As mentioned before, the voltage reference points for the AHI battery should be set as shown in Table 3.1:

To set these reference voltage points and related time points, operate the MATE3s as following procedures:

1. Back to Main Menu
2. Go to **Settings** → **Inverter** → **Battery Charger**
3. Change the voltage reference points and time as shown in 5.18

Battery Charger				Port	0
Absorb Voltage	47.2	VDC	Time	1.5	
Float Voltage	47.2	VDC	Time	1.5	
Re-Float Voltage	47.2	VDC			
Re-Bulk Voltage	58.8	VDC			

Figure 5.18: Voltage reference point and time for battery charging.

4. Bulk charge the inverter.
 - a) Click the hot key **CHARGER** on the MATE3s
 - b) Click the **Bulk Charge** after click on hot key **CHARGER**
 - c) Click **Start Bulk** after enter the **Bulk charge**
 - d) Click hot key Up on the MATE3s to go back the **CHARGER** interface
 - e) Click **Charger Mode**
 - f) Enable the charger control **On**
5. Wait until the battery finishes all charging stages

5.7 Remote Development of the DER program on the Raspberry Pi

To make sure the DER program can run on the Raspberry Pi, and that the Pi can be remotely controlled, some configurations and documents have to be set and install on the Pi. The specific configure information and installation procedures of the Pi are shown in the

Raspberry Pi tutorial on GitHub of Portland State University Power Lab.¹ The following procedures are a general guide for users to understand how to configure a Raspberry Pi and remotely develop the DER program on a computer and then run it on Raspberry Pi.

1. Configuring the Raspberry Pi

- a) Headless Setup - Remote control Raspberry Pi through SSH
- b) Increase Swap memory - Increase RAM memory space
- c) Dependency Installation - Develop and debug DER program
 - Installing Cmake file
 - Installing Boost file
 - Installing XercesC file
- d) Clone EGoT-DCS file on Raspberry Pi
- e) Download the CLion Integrated Development Environment (IDE)

2. Interacting with the Raspberry Pi via computer ².

- a) Download the CLion IDE
- b) Clone the ssh-dev repository to the desired directory of the desktop environment
- c) Clone the ssh-dev repository to the raspberry pi
- d) Open CLion IDE and navigate to the ssh-dev repository

¹<https://github.com/PortlandStatePowerLab/raspberrypi-tutorial>

²<https://github.com/PortlandStatePowerLab/raspberrypi-tutorial>

- e) Add a toolchain on the CLion IDE to create a host name for raspberry Pi and install Cmake on the local computer to interact with the Pi
- f) Open the DER program file created on the Raspberry Pi on the computer and upload the DER program.
- g) Debug and run the program

5.8 Measuring output parameters from inverter

To measure the output power, voltage, and current from the inverter, external measurement tools have to be used. In this testing system, the PA 4000 power analyzer is used for measuring power flow between the GS8048A inverter and the NHR 9410-12 Grid Simulator.

To collect the power flow data, configure the PA 4000 as follows:

1. Choose one measurement channel to be used on the PA 4000. The PA 4000 has four measurement channels. Each channel has the same voltage and current ratings.
2. Connect the PA 4000 to the junction box using test lead cables. Test leads must be rated 32 amps.
3. Turn on the PA 4000 power analyzer
4. Change the configuration of the PA 4000 into "One-phase, Three-wires" (1p3w)
5. Collect measurement values
 - Collect measurement values on PA 4000 front panel
 - a) Press soft key **MENU** on PA 4000 front panel
 - b) Click **Measurement** on the interface

- c) Choose measurement values such as V_{rms} , A_{rms} , Watt, PF, etc
 - d) Go back to main manu to observe the changes of measurement values
 - e) Plug a USB drive into USB port on PA 4000
 - f) Observe the LED light next to the USB port. When it stop flushing, unplug the USB drive
 - g) The data are stored as a CSV file
- Read measurement values using the PA 4000 software-PWRVIEW [29]
 - a) Connect the power analyzer to the computer using an Ethernet cable
 - b) Open the PWRVIEW software on the desktop of computer
PWRLAB04.ece.pdx.edu
 - c) Make sure the IP address of the PA 4000 is configured in Network Setup
 - d) Press **Add** button to detect and identify the PA 4000 power analyzer
 - e) Click **Connect** button to connect the PA 4000 with the computer
 - f) Under **Setup** tab, choose the channel that the PA 4000 is connect to the power rack.
 - g) Choose 1p3w next to the channel label
 - h) Choose V_{rms} , A_{rms} , Watt, PF in the **Measurement Selection** section.
 - i) Click **Start** or **Stop** in the **Measurement** tab to begin or stop measurement
 - j) Click **Result** to view the collected data files.
 - k) Choose the data file to store on the local computer

5.9 Checking SunSpec Registers Status

The functions of the smart inverter are controlled using SunSpec registers. In order to check the SunSpec register status in the AXS port, multiple methods can be used. The AXS Port is the device that maps the internal register addresses of the inverter to the SunSpec Modbus registers. Using Modbus Poll software is the first method. Using the outback shall program created by the Outback power company is the second method. Running the DER program for testing the inverter is the third method. However, no matter which method is conducted, users must know the IP address of the AXS port and link it to the related software.

5.9.1 Using modbus poll software

To check the register status using Modbus Poll, conduct the following procedures in order:

1. Open Modbus Poll software on the desktop of the power lab computer: PWR-LAB06.ece.pdx.edu
2. Click **Connection** on the header
3. Choose **Modbus TCP/IP** as default connection
4. Enter IP-address of the AXS port
5. Choose IPv4 as internet protocol version
6. Click **File** → **New**, then a window will pop up.
7. Right click the data address on the right column and choose "Read/write Definition"
8. Find the particular SunSpec Modbus register model address that begins with 40011.

Each block is clearly labeled with a number at the beginning and has a specific length.

The block information is contained in the SunSpec Information Model Reference.

9. Change the **Quality** to 125. This is the maximum number of registers that can be shown in a single window. Multiple windows are needed if hundreds of registers are being checked.
10. In the view section, choose **Fit to Quality**
11. Click **OK**
12. The **Alias** of each register can be changed refer to the specific version of SunSpec Information Model Reference
13. The SunSpec block such as "Immediate Control 123" shown in the Modbus poll will be same as shown in Table 5.1

Register address	Alias	Register status
40736	ID	123
40737	length	24
40739	Conn_WinTms	-1
40740	Conn_RvrtTms	-1
40741	Conn	1
40742	WMaxLimPct	50
40743	WMaxLimPct_WinTms	-1
40744	WMaxLimPct_RvrtTms	-1
40745	WMaxLimPct_RmpTms	-1
40746	OutPFSet	100
40747	OutPFSet_WinTms	-1
40748	OutPFSet_RvrtTms	-1
40749	OutPFSet_RmpTms	-1
40750	OutPFSet_Ena	0
40751	VArWMaxPct	-32768
40752	VArMaxPct	-32768
40753	VArAvalPct	-32768
40754	VArPct_WinTms	-1
40755	VArPct_RvrtTms	-1
40756	VArPct_RmpTms	-1
40757	VArPct_Mod	-1
40758	VArPct_Ena	-1
40759	WMaxLimPct_SF	0
40760	OutPFSet_SF	-2
40761	VArPct_SF	0

Table 5.1: SunSpe registers as shown in Modbus Poll.

14. Check the register **Conn** to verify if the inverter is energize or not
15. Check the register **WMaxLimPct** to verify maximum power output level defined by the users.

The models that contain the registers used for testing inverter functions are shown in the file labeled as **Modbus PSU** on the desktop of the PWRLAB06.ece.pdx.edu computer.

5.9.2 Using Outback Shell program

The Outback shell program uses created by the Outback Power Company, but the company no longer maintains it, which means the most recent SunSpec blocks cannot be read in the AXS port. According to the Outback Power technical support team, the SunSpec registers are not all correct to use. Many SunSpec registers have not implemented.

1. Open the file OutbackShell SDK file on the Desktop of the PSU power lab computer- PWRLAB06.ece.pdx.edu
2. Execute the outback.shell application in the OutbackShell SDK file.
3. Click 'h' to get more commands to operate the shell program as shown in Figure 5.19
4. Identify the AXS port IP address
5. Click 'c' to enter the IP address of the AXS port
6. Then all SunSpec blocks in the AXS port will appear once the Outback Shell program is connected to the AXS port
7. Click 'r' to identify the offset number of SunSpec blocks and registers
8. Click 'w' write the values into specific SunSpec blocks or registers

```

OutBack SunSpec Communications Shell, Version 4.0.0.2052
*****

Type command or 'h' for help
>> h

Commands:

    Help          'h'
    Connect       'c'
    Disconnect    'd'
    List Blocks   'l'
    Read All      'a'
    Read          'r'
    Read Series   's'
    Write         'w'
    Write Multiple 'm'
    Unlock        'u'
    List Errors   'e'
    Quit          'q'

To connect to the default IP address, enter 'c' then 'd'.
Default is defined as DEF_SERV_IP_ADDR in outback.h.

To disconnect and automatically reconnect to the same address,
enter 'c' while connected.

See the User Guide for more information.

```

Figure 5.19: Outback shell program designed for AXS port.

5.9.3 Running DER program

1. Connect Raspberry Pi to a monitor or ssh into Raspberry Pi
2. Go to Energy Grid of Things (EGoT)-DER → EGoT-DCS → src
3. Figure out the AXS port IP address. When the Pi does not connect to the AXS port, connection errors will appear and simulation model will be created.
4. Enter the IP address assigned by the router in the DER program
5. Compile the main.cpp file in the src folder under the path EGoT-DER/EGoT-DCS/src.
(cmake --build build/)
6. Build the main.cpp file (./build/src/app). Then, all SunSpec blocks and register information will be shown.

6 Results & Analysis

6.1 Verify The Values Written Into The SunSpec Registers

To make sure the DER program can detect the SunSpec blocks and the registers in the block in the AXS port, the first thing to do is checking if the number of blocks and registers in the AXS port match with the SunSpec model reference. If the number of SunSpec blocks and their length does not match with the reference, then the DER program will be terminated as it is running and will not read all the SunSpec blocks and registers in the AXS port. All the SunSpec blocks and registers in the AXS port are created based on the specific version of the SunSpec model reference and type noted in the XML files for users to read and modify.

In order to check the number of SunSpec blocks and registers in the AXS port, the Outback shell program is used. According to the Outback Power technical support group, the people who created the SunSpec models for the AXS port have left the company. Therefore, Outback is not sure which version of the SunSpec model that the AXS port applies. The SunSpec model references that were created in 2015 and later can be found on the SunSpec organization website. Through comparing the SunSpec models in the AXS port and the reference, some differences were found. As shown in Figure 6.1, block 64110 "Outback AXS devices" has 420 registers, but the number of registers defined in the reference only have 282. Other SunSpec blocks such as 64120, 64115, 64116, and 64255 created in the

AXS port are not defined in the SunSpec model references that were created in 2015 and later.³ Therefore, the programmer has to add the additional blocks and registers defined in the AXS port to the XML SunSpec model base for the DER program to use. To complete the XML SunSpec models for DER programs, the additional information of the SunSpec blocks in the AXS port can be found on the Outback Power company website. Once the XML SunSpec models are created and kept the same with the AXS port, the DER program is ready to run. But not all SunSpec registers in the AXS port allow the values to be passed.⁴

SunSpec	Device	Detected!	
Block	Address	DID	Offset
0	40002	1	65
1	40069	64110	420
2	40491	64120	27
3	40520	102	50
4	40572	64255	56
5	40630	120	26
6	40658	121	30
7	40690	122	44
8	40736	123	24
9	40762	124	24
10	40788	126	64
11	40854	129	60
12	40916	130	60
13	40978	132	64
14	41044	134	68
15	41114	135	60
16	41176	136	60
17	41238	137	60
18	41300	138	60
19	41362	139	60
20	41424	140	60
21	41486	145	8
22	41496	64115	58
23	41556	64116	89
24	41647	65535	0

Figure 6.1: SunSpec blocks and their length in AXS port.

³SunSpec Information Model Reference 09/28/2017 or later

⁴https://www.outbackpower.com/downloads/documents/system_management/axsport/axsappnote.pdf

6.2 Energize and De-energize Testing

In order to test the interoperability of a smart inverter, the first tests conducted in this research are energizing and de-energizing. As shown in Table 6.1, when the user-defined value 1 (energize) or 0 (de-energize) was transferred into the SunSpec register *Conn* after executing the DER program, the status of the register will be changed to "**Connect**" or "**Disconnect**".

IEEE 2030.5 attribute	Transfer Value	SunSpec Register	SunSpec Register status	Connect or Disconnect
op_mod_energize	WritePoint: 40740, 1	Conn	1	Connect
op_mod_energize	WritePoint: 40740, 0	Conn	0	Disconnect

Table 6.1: Result of writing and transferring IEEE 2030.5 "*opmodConnect*" to SunSpec "*Conn*"

To make sure the user-defined value was indeed transferred into the SunSpec register *Conn*, the Outback Shell program was used. As shown in Table 6.2, the SunSpec register is "**Connect**" when the defined value **1** was transferred and **Disconnect** when **0** was transferred.

Register Address	Block offset	Register Name	Value
40736	882	IMMED_INVERTER_CONTROLS_DID	123
40737	883	IMMED_INVERTER_CONTROLS_LEN	24
40738	884	IMMED_INVERTER_CONTROLS_Conn_WinTms	Not implemented
40739	885	IMMED_INVERTER_CONTROLS_Conn_RvrtTms	Not implemented
40740	886	IMMED_INVERTER_CONTROLS_Conn	Connect
40740	886	IMMED_INVERTER_CONTROLS_Conn	Disconnect

Table 6.2: Verify energize and de-energize numbers were transferred into SunSpec registers using OutBack Shell Program

To verify the inverter will be energized after the value is transferred into the register, SunSpec block 102 - Split Phase inverter is used. As shown in Table 6.3, the phase current and phase voltage value will be updated to the defined voltage and current value after the inverter is connected to the grid. Those updated values will remain as 0 once the inverter is de-energized.

Register Address	Block offset	SunSpec Resiter name	Value
40520	304	I_SunSpec_DID	102
40521	305	I_SunSpec_Length	50
40522	306	I_AC_Current	24.30 A
40523	307	I_AC_CurrentA	12.54 A
40524	308	I_AC_CurrentB	11.69 A
40525	309	I_AC_CurrentC	0 A
40526	310	I_AC_Current_SF	0
40527	311	I_AC_VoltageAB	244 V
40528	312	I_AC_VoltageBC	Not implemented
40529	313	I_AC_VoltageCA	Not implemented
40530	314	I_AC_VoltageAN	122 V
40531	315	I_AC_VoltageBN	122 V
40532	316	I_AC_VoltageCN	Not implemented

Table 6.3: Verify Energize or De-energize of an inverter through observing the voltage and current changes

6.2.1 Energize and De-energize Testing Analysis

From above test results, the inverter is compliant with IEEE 2030.5 attribute *opModEnergize*.

In conclusion, the inverter can provide a functionally correct response to the IEEE 2030.5 attribute related to energize or de-energize.

6.3 Maximum Export Power Testing

SunSpec register "WMaxLimPct" determines the maximum power level of the inverter, which is the representative register that allows the values to be changed. If the value "80" can be transferred into the register, then the status of the register can be verified using the function "ReadBlock" and "PrintBlock" after running the DER program. If the value cannot be transferred into the register, then a reason such as "Illegal Data Value" will be shown to remind the user. If the value successfully transfers, then the grid operator can set parameters for the inverter by using the IEEE 2030.5 attributes and the attributes can be linked to the specific SunSpec register. The result of setting the maximum power of the inverter is summarized in Table 6.4.

IEEE 2030.5 attribute	Transfer Value (%)	SunSpec Register	SunSpec Register Status (%)	Maximum Export Power
op_mod_fixed_w	80	WMaxLimPct	80	No response
op_mod_fixed_w	6	WMaxLimPct	6	No response
op_mod_fixed_w	5	WMaxLimPct	Illegal Data Value	No response
op_mod_fixed_w	100	WMaxLimPct	Illegal Data Value	No response

Table 6.4: Test result of verifying connection and setting maximum power of the inverter.

Any value greater or equal to 6 % and lower or equal to 80 % can be written into the register "WMaxLimPct". The value in SunSpec register "WMax" in SunSpec block 121 (Basic Settings) will vary as the value changes in the register "WMaxLimPct". The SunSpec register "WMax" will be used as the reference in frequency-Watt control to set the maximum power that the inverter can export or absorb in the later section. The maximum power that

inverter can absorb or export is 7200 VA according to value shown in the "WMax" as the "WMaxLimPct" was set to 100%. The scale factor of SunSpec register "WMax" is 1, which means the decimal point moves to the right by one position.

To double check if the inverter has been correctly written into the SunSpec register "WMaxLimPct", the Outback shell program is used. As shown in Figure 6.2, the value has been successfully passed into the SunSpec register "WMaxLimPct".

```
>> r
Block number: 8
Field number (0 to list): \
40736 885 : IMMED_INVERTER_CONTROLS_DID 123
40737 886 : IMMED_INVERTER_CONTROLS_LEN 24
40738 887 : IMMED_INVERTER_CONTROLS_Conn_WinTms Not implemented
40739 888 : IMMED_INVERTER_CONTROLS_Conn_RvrtTms Not implemented
40740 889 : IMMED_INVERTER_CONTROLS_Conn 0 [Disconnect]
40741 890 : IMMED_INVERTER_CONTROLS_WMaxLimPct 80 %
40742 891 : IMMED_INVERTER_CONTROLS_WMaxLimPct_WinTms Not implemented
40743 892 : IMMED_INVERTER_CONTROLS_WMaxLimPct_RvrtTms Not implemented
40744 893 : IMMED_INVERTER_CONTROLS_WMaxLimPct_RmpTms Not implemented
40745 894 : IMMED_INVERTER_CONTROLS_WMaxLim_Ena Not Implemented
40746 895 : IMMED_INVERTER_CONTROLS_OutPFSet 1.00 Cos angle
40747 896 : IMMED_INVERTER_CONTROLS_OutPFSet_WinTms Not implemented
40748 897 : IMMED_INVERTER_CONTROLS_OutPFSet_RvrtTms Not implemented
40749 898 : IMMED_INVERTER_CONTROLS_OutPFSet_RmpTms Not implemented
40750 899 : IMMED_INVERTER_CONTROLS_OutPFSet_Ena 0 [Disabled]
40751 900 : IMMED_INVERTER_CONTROLS_VarWMaxPct Not implemented
40752 901 : IMMED_INVERTER_CONTROLS_VarMaxPct Not implemented
40753 902 : IMMED_INVERTER_CONTROLS_VarAvalPct Not implemented
40754 903 : IMMED_INVERTER_CONTROLS_VarPct_WinTms Not implemented
40755 904 : IMMED_INVERTER_CONTROLS_VarPct_RvrtTms Not implemented
40756 905 : IMMED_INVERTER_CONTROLS_VarPct_RmpTms Not implemented
40757 906 : IMMED_INVERTER_CONTROLS_VarPct_Mod Not Implemented
40758 907 : IMMED_INVERTER_CONTROLS_VarPct_Ena Not Implemented
40759 908 : IMMED_INVERTER_CONTROLS_WMaxLimPct_SF 0
40760 909 : IMMED_INVERTER_CONTROLS_OutPFSet_SF -2
40761 910 : IMMED_INVERTER_CONTROLS_VarPct_SF 0

>> r
Block number: 8
Field number (0 to list): 890
Value: 80 %
```

Figure 6.2: The maximum power value of the inverter had been successfully written into SunSpec resiter 'WMaxLimPct'.

6.3.1 Maximum Export Power interoperability Testing Analysis

Based on the above testing result, percentage value in the range of [6,80] defined in IEEE 2030.5 attribute can be transferred in the SunSpec register *WMaxLimPct*, but the inverter will not use the SunSpec parameters to enable the function and export the maximum power

as defined. Therefore, the testing system discovers that the GS8048A smart inverter is not fully compliant with IEEE 2030.5 *opModFixedWatt* attribute. In conclusion, the inverter does not provide a functionally correct response to the IEEE 2030.5 attribute.

6.3.2 Maximum Power Export Testing Connected with Grid Simulator

Even the inverter is not compliant with attribute *opModFixedWatt*, the testing system can perform the test of exporting maximum power of an inverter when the inverter is connected to a grid simulator. To enable the maximum export power function of the inverter, the voltage reference points must be used, which are Absorb voltage and Sell voltage. These two voltages must be set at the same value to enable the maximum power output function of an inverter. In order to export the maximum power, the Absorb voltage and Sell voltage must be set at the lowest value which is 44 VDC. As shown in the figure 6.3 , when the voltage reference points were set as the minimum value, the inverter will export the maximum power around 3.3 kW.

Figure 6.3: Exporting maximum power from inverter.

The reason that active power is negative is because the power value was measured on the grid-simulator side, so the export power from the inverter means import power to the grid-simulator. The LED light on the grid simulator indicates the direction of power. As shown in Figure 6.4, the power flows into the grid-simulator. In Figure 6.5, the power flows out from the grid-simulator. "**Sink**" means power goes in, "**source**" means power goes out.

Figure 6.4: Grid simulator absorb power from load, blue LED light.

Figure 6.5: Grid simulator export power to load, yellow LED light.

To change the maximum power level from the inverter, simple calculation is required. For example, if the maximum battery voltage is 60 VDC and the Absorb voltage and Sell voltage were set as 52 VDC ($((60 - 44)/2 + 44 = 52)$), then inverter will export half of maximum power around 1.65 kW, as shown in Figure 6.6.

Figure 6.6: Exporting half power from inverter.

6.3.3 Maximum Export Power Sub-component Testing Analysis

Based on the above test result, the testing system has the ability to test the maximum export power from an inverter especially when the inverter is connected to a grid simulator. Also, the testing system shows it can perform different exported power levels testing for the inverter.

6.4 Volt-VAr function Testing

The Volt-VAr function is an autonomous control function, which means the inverter will produce or consume reactive power autonomously when it senses a grid voltage that is lower or higher than the limit. When the grid AC voltage lower than the nominal volatge, the inverter will produce *capacitive* power. When the grid AC voltage is higher than the nominal voltage, the inverter will consume *inductive* power.

Since the Volt-VAr function is a curve-based control, it is necessary to choose points to construct the curve. To construct a Volt-VAr curve, at least four points shall be used, as shown in Figure 6.7. Point (V1,Q1) sets the maximum capative reactive power that inverter will provide. Points (V2,Q2) and (V3,Q3) set the dead-band for the inverter. When grid AC voltage in the dead-band, the inverter has no reaction to the grid voltage. The dead-band shown in Figure 6.7 the reactive power is 0, but usually the reactive power is not 0. It will be the minimum reactive power that inverter will produce. Point (V4,Q4) sets the maximum inductive reactive power that inverter will consume.

Figure 6.7: Standard Volt-VAr curve [12].

6.4.1 Verification of Writing Volt-VAr Curve Points

In the DER program, the $(V1, Q1)$ was set as $(41, 460)$, $(V2, Q2)$, $(V3, Q3)$ were set as $(44, 0)$, $(52, 0)$, and $(V4, Q4)$ was set as $(55, 460)$. Since x value in each pair of points is a percentage value, $41.00\% = 240 \times 0.41 = 98.4VAC$, $44.00\% = 240 \times 0.44 = 105.6VAC$, $52.00\% = 240 \times 0.52 = 124.8VAC$, $55.00\% = 240 \times 0.55 = 132VAC$. In SunSpec register, the default sign of Q4 is negative. Table 6.5 shows the process and the result of Volt-VAr curve points defined in IEEE 2030.5 attributes and transferred into the SunSpec registers after executing the DER program. Based on the curve created above, the expected Volt-VAr curve will like as shown in Figure 6.8.

IEEE 2030.5 attribute	Transfer Value	SunSpec Register	SunSpec Register Status
opmodVoltVAr CurveData vv[0].x=41	WritePoint: 40802, 4100	V1	4100
opmodVoltVAr CurveData vv[0].y=460	WritePoint: 40803, 460	VAr1	460
opmodVoltVAr CurveData vv[1].x=44	WritePoint: 40804, 4400	V2	4400
opmodVoltVAr CurveData vv[1].y=0	WritePoint: 40805, 0	VAr2	0
opmodVoltVAr CurveData vv[2].x=52	WritePoint: 40806, 5200	V3	5200
opmodVoltVAr CurveData vv[2].y=0	WritePoint: 40807, 0	VAr3	0
opmodVoltVAr CurveData vv[3].x=55	WritePoint: 40808, 5500	V4	5500
opmodVoltVAr CurveData vv[3].y=460	WritePoint: 40809, 460	VAr4	460

Table 6.5: Using DER program to set curve points for Volt-VAr function.

Figure 6.8: Expected Volt-Var curve based on the user defined curve points.

To make sure if the Volt-Var curve points are written into the AXS port, Outback Shell program is used. Table 6.6 summarized the test results of Volt-Var curve points that are written into the SunSpec registers.

Register Address	Block offset	Register Name	Value
40788	937	STATIC_VOLT_VAR_DID	126
40789	938	STATIC_VOLT_VAR_LEN	64
40790	939	STATIC_VOLT_VAR_ActCrv	1
40791	940	STATIC_VOLT_VAR_ModEna	0x0001 [Enabled]
40792	941	STATIC_VOLT_VAR_WinTms	Not implemented
40793	942	STATIC_VOLT_VAR_RvrtTms	Not implemented
40794	943	STATIC_VOLT_VAR_RmpTms	Not implemented
40795	944	STATIC_VOLT_VAR_NCrv	1
40796	945	STATIC_VOLT_VAR_NPt	4
40797	946	STATIC_VOLT_VAR_V_SF	-2
40798	947	STATIC_VOLT_VAR_DeptRef_SF	-1
40799	948	STATIC_VOLT_VAR_RmpIncDec_SF	0
40800	949	STATIC_VOLT_VAR_ActPt	4
40801	950	STATIC_VOLT_VAR_DeptRef	1 [WMax]
40802	951	STATIC_VOLT_VAR_V1	41.00 % VRef
40803	952	STATIC_VOLT_VAR_VAr1	46.0
40804	953	STATIC_VOLT_VAR_V2	44.00 % VRef
40805	954	STATIC_VOLT_VAR_VAr2	0.0
40806	955	STATIC_VOLT_VAR_V3	52.00 % VRef
40807	956	STATIC_VOLT_VAR_VAr3	0.0
40808	957	STATIC_VOLT_VAR_V4	55.00 % VRef
40809	958	STATIC_VOLT_VAR_VAr4	46.0

Table 6.6: Verify Volt-Var points were transferred into SunSpec registers using OutBack Shell program.

6.4.2 Volt-VAr function interoperability testing analysis

Even the user-defined points can be transferred into the SunSpec registers, but the inverter does not use those values to set a Volt-VAr curve for the inverter to operate. Therefore, the smart inverter is not fully compliant with the `opModVoltVar` attribute. In conclusion, the inverter does not provide a functionally correct response to this attribute.

6.4.3 GS8048A Volt-VAr Function Testing with Grid Simulator

Although the inverter is not compliant with IEEE 2030.5 attribute *opModVoltVar*, the sub-component works in the testing system. The Volt-VAr function of the inverter can be tested when the grid-simulator is connected. As defined in the GS8048A operator manual, there are three sets of voltage points for the Volt-VAr curve: the default voltage points, minimum voltage points, and maximum voltage points. The Volt-VAr testing in this section was conducted using those voltage points. The time step for voltage changes on the grid simulator was set as 2 or 5 seconds. The voltage sweep direction is from maximum to minimum and from minimum to maximum.

6.4.3.1 Default Volt-VAr test

This default Volt-VAr test explores how the inverter is sensitive to the voltage changes as the voltage does not reach the minimum and maximum bound with the default voltage set points.

1. Default Volt-VAr test sweep voltage from low to high with 2 seconds time step

The first test explores how the Volt-VAr function works with the minimum acceptable voltage-time changes and the sweep direction from the minimum to the maximum. The time step for voltage change is 2 seconds. The default voltage set points are summarized in the Table 6.7. The maximum reactive power is 1980 VAr, which is the maximum reactive power as the inverter export the maximum apparent power VA.

Volt	V_phase	V_LL	Q(VAr)	Q_value	S=3.3kVA, PF=0.8
V1	106	212	Q1	1980	$Q_{max}=\sqrt{S^2-P^2}$
V2	114	228	Q2	500	$Q_{deadband}$
V3	126	252	Q3	500	$Q_{deadband}$
V4	132	264	Q4	-1980	Q_{max}

Table 6.7: Default Volt-VAr curve points.

Figure 6.9: Default Volt-VAr curve sweep voltage from the minimum to maximum with 2 seconds time step.

As shown in Figure 6.9, point V1’ is lower than the desired V1 point, and Q1’ is a higher than the desired Q1. The dead-band is shifted to the left. The reason that the tested Volt-VAr curve has a big drop between V3 and V4 is because the reactive power within the dead-band is not zero. The direction of the reactive power has to change quickly in order to keep up the voltage changes as the voltage sweep from the V3 to V4, which the inverter is not able to do.

2. Default Volt-VAr test sweep voltage from high to low with 2 seconds time step

The second test explores how the Volt-VAr function works when the voltage sweep from the maximum to the minimum with a 2 seconds time step and when the maximum reactive power is in a low condition. The GS8048A smart inverter cannot only export reactive power because the minimum power factor that can be set is 0.8 in the Volt-VAr function to provide the maximum reactive power. Therefore, active power will be exported when the inverter provides reactive power. Since the active power is continuously exported from the inverter when the Volt-VAr function is enabled, the amount of reactive power decreases to keep the fixed power factor 0.8. The maximum reactive power of this test is 1000 VAR. That is the maximum value as the inverter export around one-third of the maximum apparent power of 3300 VA. The voltage set points of this test are summarized in the Table 6.8.

Volt	V_phase	V_LL	Q(VAr)	Q_value	Reactive power (Q)
V1	106	212	Q1	1000	Q_max
V2	114	228	Q2	215	Q_deadband
V3	126	252	Q3	215	Q_deadband
V4	132	264	Q4	-1000	Q_max

Table 6.8: Default Volt-VAr curve points.

Figure 6.10: Default Volt-VAr testing sweep voltage from high to low with 2 seconds time step.

As shown in Figure 6.10, the tested Volt-VAr curve is shifted to the left compared to the expected Volt-VAr curve. The Volt-VAr control of this test behaves more accurately compared to the previous test.

3. Default Volt-VAr test sweep voltage from low to high with 5 seconds time step

In order to test the accuracy of the Volt-VAr function respond to a different time step of the voltage changes, the time step of this test is switched to 5 seconds. In this third test, the voltage sweeps from the minimum to the maximum. The voltage set points are summarized in the Table 6.7.

As shown in Figure 6.11, when the voltage is swept from the minimum to the maximum, the tested Volt-VAr curve mostly follows the user-defined expected curve, except for the maximum reactive power decreased due to the inverter continuously discharging, as explained in the previous test statement.

Figure 6.11: Default Volt-VAr testing sweep voltage from low to high with 5 seconds time step.

4. Default Volt-VAr test sweep voltage from high to low with 5 seconds time step

Similar to the third test, the fourth test of this explores how Volt-VAr function behaves when the voltage swept from the maximum to the minimum with 5 seconds time step.

The voltage set points are summarized in the Table 6.7.

Figure 6.12: Default Volt-VAr testing sweep voltage from high to low with 5 seconds time step.

As shown in Figure 6.12, when the voltage is swept from the maximum to the minimum, the dead-band was extended. Point 1 and point 2 shifted to the left. The

maximum reactive power was reduced due to the inverter being discharged as the test went.

6.4.3.2 Minimum Volt-VAr Test

In order to test the performance of Volt-VAr control when the voltages are set to the minimum acceptable value, the following tests were conducted. Similar to the default Volt-VAr tests, the following are also conducted with different time steps for voltages and with voltage sweep directions.

1. Minimum Volt-VAr test sweep voltage from low to high with 2 seconds time step

This test explores how well the Volt-VAr control performs when the voltages were set as the minimum acceptable value. The time step for voltage changes is 2 seconds and the voltage sweep direction is from the minimum to the maximum in this test. The voltage set points of this test are summarized in the Table 6.9.

Volt	V_phase	V_LL	Q(VAr)	Q_value
V1	98	196	Q1	1980
V2	106	212	Q2	500
V3	114	228	Q3	500
V4	116	232	Q4	-1980

Table 6.9: Minimum Volt-VAr curve points.

As shown in Figure 6.13, the dead-band of the test Volt-VAr curve is shifted to the left compared to the expected curve. The maximum inductive and capacitive power were provided when the sweep voltage hits the V1 and V4 points on tested curve.

2. Minimum Volt-VAr test sweep voltage from high to low with 2 seconds time step

Figure 6.13: Minimum Volt-VAr testing sweep voltage from low to high with 2 seconds time step.

Different from the previous test, the voltage sweep direction of this test was changed from maximum to minimum. The voltage step time is set as 2 seconds. Moreover, this test also explores the performance of the Volt-VAr control when the maximum reactive power is provided. The voltage set points are summarized in the Table 6.10.

Volt	V_phase	V_LL	Q(VAr)	Q_value
V1	98	196	Q1	1000
V2	106	212	Q2	215
V3	114	228	Q3	215
V4	116	232	Q4	-1000

Table 6.10: Minimum Volt-VAr curve points.

As shown in Figure 6.14, the dead-band of the tested Volt-VAr curve is shifted to the left. The maximum inductive and capacitive power provided by the inverter has a 500 VAr difference when the voltage swept at (V1',Q1') and (V4',Q4') .

Figure 6.14: Minimum Volt-VAr testing sweep voltage from high to low with 2 seconds time step.

3. Minimum Volt-VAr test sweep voltage from low to high with 5 seconds time step

This test explores the performance of the Volt-VAr control as the voltage-time step extends to 5 seconds, and the voltage points are set close to the minimum acceptable value. The voltage sweep direction of this test is from the minimum to the maximum.

The voltage set points are summarized in Table 6.10.

Figure 6.15: Minimum Volt-VAr testing sweep voltage from low to high with 5 seconds time step.

As shown in Figure 6.15, the performance of the Volt-VAr curve does not improve

compared to the Figure 6.13. The dead-band of the tested Volt-VAr curve is shifted to the left. The maximum reactive power on the tested curve is lower than the expected curve due to the inverter was under discharging as the test went.

4. Minimum Volt-VAr test sweep voltage from high to low with 5 seconds time step

This test explores the performance of the Volt-VAr control when the voltage-sweep direction is from maximum to the minimum. The voltage time step was set as 5 seconds. The voltage set points are summarized in Table 6.10.

Figure 6.16: Minimum Volt-VAr testing sweep voltage from high to low with 5 seconds time step.

As shown in Figure 6.16, when the voltage sweep is from maximum to minimum, point (V2', Q2') shifts to the left. Other voltage points on the tested curve match with user-defined points.

6.4.3.3 Maximum Volt-VAr curve Test

In order to test the performance of Volt-VAr control when the voltages are set to the maximum acceptable value, the following tests were conducted. Similar to the default Volt-VAr tests, the followings are also conducted with different voltage sweep times and directions.

1. Maximum Volt-VAr test sweep voltage from low to high with 2 seconds time step

This test explores how well the Volt-VAr control was conducted when the voltage points were set as the maximum acceptable value with voltage-time step 2 seconds and sweep direction from minimum to maximum. The voltage set points of this test are summarized in the Table 6.11.

Volt	V_phase	V_LL	Q(VAr)	Q_value
V1	124	248	Q1	1980
V2	126	252	Q2	500
V3	132	264	Q3	500
V4	139	278	Q4	-1980

Table 6.11: Maximum Volt-VAr curve points.

As shown in the Figure 6.17, the tested maximum Volt-VAr function has a noticeable difference compared to the expected test result. The Volt-VAr control did not follow the user defined voltage points.

2. Maximum Volt-VAr test sweep voltage from high to low with 2 seconds time step

Different from the previous test, the voltage-sweep direction of this test was changed from the maximum to the minimum. The voltage step time is set as 2 seconds. More-

Figure 6.17: Maximum Volt-VAr testing sweep voltage from low to high with 2 seconds time step.

over, this test also explores the performance of the Volt-VAr control with maximum acceptable voltage when the maximum reactive power is reduced. The voltage set points are summarized in the Table 6.12.

Volt	V_phase	V_LL	Q(VAr)	Q_value
V1	124	248	Q1	1000
V2	126	252	Q2	215
V3	132	264	Q3	215
V4	139	278	Q4	-1000

Table 6.12: Maximum Volt-VAr curve points.

As shown in Figure 6.18, point (V1', Q1') and (V2', Q2') were shifted to the left as the voltage swept from the maximum to the minimum. Point (V3', Q3') and (V4', Q4') on the tested curve followed the user-defined voltage points and the maximum reactive power was provided as the swept voltage hit point 1 and point 4. The dead-band of the tested curve in this test is extended due to point 2 being shifted.

3. Maximum Volt-VAr test sweep voltage from low to high with 5 seconds time step

Figure 6.18: Maximum Volt-VAr testing sweep voltage from high to low with 2 seconds time step.

This test explores the performance of the Volt-VAr control as the voltage-time step extended to 5 seconds, and the voltage points were set close to the maximum acceptable value. The voltage sweep direction of this test is from minimum to maximum. The voltage set points are summarized in Table 6.12.

Figure 6.19: Maximum Volt-VAr testing sweep voltage from low to high with 5 seconds time step.

As shown in Figure 6.19, point (V1', Q1') and (V2', Q2') were shifted to the left as

the voltage swept from the minimum to the maximum. Point (V3'', Q3'') and (V4, Q4') on the tested curve followed the user-defined voltage points. The dead-band of the tested curve in this test is extended due to point 2 being shifted to the left. There is a 500 VAr different between the capacitive VAr and inductive VAr.

4. Maximum Volt-VAr test sweep voltage from high to low with 5 seconds time step

This test explores the performance of the Volt-VAr control when the voltage-sweep direction was changed: from the maximum to the minimum. The voltage time step was set as 5 seconds. The voltage set points are summarized in Table 6.12.

Figure 6.20: Maximum Volt-VAr testing sweep voltage from high to low with 5 seconds time step.

As shown in Figure 6.20, point (V1', Q1') and (V2', Q2') were shifted to the left as the voltage swept from the maximum to the minimum. Point (V3', Q3') and (V4', Q4') on the tested curve followed the user-defined voltage points. The dead-band of the tested curve in this test is extended due to point 2 being shifted to the left. There

is a 500 VAr different between the capacitive VAr and inductive VAr. Based on the observation, there is no improvement compared to the previous test.

6.4.4 Volt-VAr function Sub-component Testing Analysis

Based on the above testing result, the inverter testing system has the ability to test both the lower band and higher band of the voltages in the Volt-VAr function. The inverter has the ability to test the Volt-VAr function with different voltage sweep directions and is able to test the Volt-VAr function with different voltage time step changes even the GS 8048A smart inverter not always follow the user-defined curve very well.

6.5 Frequency Watt Function Testing

Similar to the voltage, frequency is also an essential factor of a reliable electric grid. However, unlike the Volt-VAr function control where the inverter can provide autonomous bi-directional reactive power, most commercial and residential inverters sold today can only provide frequency-Watt control for over-frequency situations. Under-frequency control in the solar PV inverter is possible, but it will require the inverter to operate below the minimum available power from the PV solar panels. This new control is currently underdevelopment and has not been widely adopted in residential and commercial inverters [30]. Therefore, the desired frequency-Watt control curve for over-frequency events will look as shown in Figure 6.21. As the frequency increases, the inverter will reduce exporting power to the grid. But it will always export its maximum set power as the frequency is below the nominal value. According to the SIWG Phase 3 DER Functions [30], *"The curve is assumed to extend horizontally to the left below the lowest point and to the right above the highest point in the array."*

Figure 6.21: Frequency-Watt Curve for over-frequency. [30]

As defined in IEEE 2030.5, the opModFreqWatt attribute requires the frequency-Watt curve-based function be composed of pairs of points in an array. The "x" value in each pair of points defines the frequency in Hz and the "y" value defines a real power level in the percentage of maximum power (WMax). For an inverter capable of reacting to under-frequency situations, the frequency-Watt curve will be as shown in Figure 6.22. Point 1 specifies the maximum power that the inverter needs to export when the grid frequency is below the nominal value. Points 2 and 3 specify the dead-band of the frequency-Watt curve. As shown in the Figure 6.22, the ideal export power from the inverter in dead-band is 0, but in a real case, it is the minimum export power that the inverter provides. This has been verified by the test results shown in the later section. Point 4 specifies the maximum power that the inverter can absorb when the grid frequency is above the nominal value.

Figure 6.22: The frequency-Watt curve used to adjust the frequency response characteristics of the BIS [31].

6.5.1 Verification of Writing Frequency-Watt Curve Points

In the DER program, point 1 (Hz1,W1) was set as (57,80), (Hz2,W2) and (Hz3,W3) were set as (58,0) and (60,0), and (Hz4,W4) was set as (62,-80). Since the W 1 and W 4 are percentage values, $W1 = 80\% \times 720W = 576W$ and $W4 = -80\% \times 720 = -576W$. Therefore, the expected bi-directional frequency-Watt curve will be like Figure 6.23.

Figure 6.23: User-defined expected bi-directional frequency-Watt curve.

Because the bi-directional frequency-Watt curve control has not been implemented in the GS8048A smart inverter, the SunSpec registers "W1", "W2", "W3", "W4" in the block 134 "Freq-Watt Curve" cannot be written into the AXS port. Also, the SunSpec registers "Hz 1" and "Hz 2" only allow small numbers to be written into them, so the maximum frequency numbers that can be written into the registers are 5 Hz. Other frequency points: "Hz 3" and "Hz 4" do not allow values to be transferred into them. The value defined in the IEEE 2030.5 attribute is firstly scaled up to 100 times in the DER program and then scale down to

the normal value, so the value stored in the SunSpec register should be 57 Hz, 59 Hz, 61 Hz and 63 Hz. Table 6.13 summarized the test result of writing frequency values into SunSpec registers using DER program.

IEEE 2030.5 attribute	Transfer Value	SunSpec Register	SunSpec Register Status	Success or Failure
opmodFreqWatt CurveData fw[0].x=57	WritePoint: 41057, 5700	Hz1	Illegal Data Value	Failure
opmodFreqWatt CurveData fw[0].x=5	WritePoint: 41057, 500	Hz1	No error message	Success
opmodFreqWatt CurveData fw[0].x=59	WritePoint: 41059, 5900	Hz2	Illegal Data Value	Failure
opmodFreqWatt CurveData fw[0].x=61	WritePoint: 41061, 6100	Hz3	Illegal Data Value	Failure
opmodFreqWatt CurveData fw[0].x=5	WritePoint: 41061, 500	Hz3	No error message	Success
opmodFreqWatt CurveData fw[0].x=63	WritePoint: 41063, 6300	Hz4	Illegal Data Value	Failure

Table 6.13: Using DER program to write values into SunSpec registers Hz 1 to Hz 4 .

User-defined active power values cannot be written into the SunSpec registers from "W1" to "W4". Table 6.14 summarized the test result of writing values into SunSpec register from "W1" to "W4" after running DER program. The values stored in the SunSpec register W1 and W3 are always 100%. The possible explanation of this problem is the SunSpec block 134 (frequency-Watt Curve) has not been fully implemented in the AXS port.

IEEE 2030.5 attribute	Transfer Value	SunSpec Register name	SunSpec Register Stored Value	SunSpec Register Status
opmodFreqWatt CurveData fw[0].y=80	WritePoint: 41058, 80	W1	100	100
opmodFreqWatt CurveData fw[1].y=0	WritePoint: 41060, 0	W2	0	0
opmodFreqWatt CurveData fw[2].y=0	WritePoint: 41062, 0	W3	-100	-100
opmodFreqWatt CurveData fw[3].y=-80	WritePoint: 41064, -80	W4	0	0

Table 6.14: Using DER program to write values into SunSpec registers W1 to W4.

To make sure the test result of the DER program are correct, the OutBack Shellprogram was used to double check the work. Field number 1178 represents register "Hz 1", by that

analogy, field number 1184 is register "Hz 4". Similarly, field number 1179 represents register "W 1" and field number 1185 represents register "W 4". Table 6.15 summarize the test result of writing SunSpec values for frequency-Watt curve using the Outback Shell program.

Register Address in AXS port	SunSpec Register offset in AXS port	Register Name	Value	Transfer Value	Error Message
41044	1165	FREQ_WATT_DID	134	N/A	N/A
41045	1166	FREQ_WATT_LEN	68	N/A	N/A
41046	1167	FREQ_WATT_ActCrv	0	N/A	N/A
41047	1168	FREQ_WATT_ModEna	0x0000 [Disabled]	N/A	N/A
41048	1169	FREQ_WATT_WinTms	Not implemented	N/A	N/A
41049	1170	FREQ_WATT_RvrtTms	0 seconds	N/A	N/A
41050	1171	FREQ_WATT_RmpTms	Not implemented	N/A	N/A
41051	1172	FREQ_WATT_NCrv	1	N/A	N/A
41052	1173	FREQ_WATT_NPt	4	N/A	N/A
41053	1174	FREQ_WATT_Hz_SF	-2	N/A	N/A
41054	1175	FREQ_WATT_W_SF	1	N/A	N/A
41055	1176	FREQ_WATT_RmpIncDec_SF	0	N/A	N/A
41056	1177	FREQ_WATT_ActPt	4	N/A	N/A
41057	1178	FREQ_WATT_Hz1	5.00 Hz	50	Write Success
41058	1179	FREQ_WATT_Hz1	8.00 Hz	80	Illegal Data Value
41058	1179	FREQ_WATT_W1	100 % WRef	80	Illegal Data Value
41059	1180	FREQ_WATT_Hz2	20.00 Hz	50	Illegal Data Value
41060	1181	FREQ_WATT_W2	0% WRef	0	Illegal Data Value
41061	1182	FREQ_WATT_Hz3	5 Hz	50	Write Success
41062	1183	FREQ_WATT_W3	-100 % WRef	0	Illegal Data Value
41063	1184	FREQ_WATT_Hz4	20.00 Hz	50	Illegal Data Value
41064	1185	FREQ_WATT_W4	0 % WRef	-80	Illegal Data Value

Table 6.15: Verify frequency-Watt points were transferred into SunSpec registers using OutBack Shell program.

6.5.2 Frequency-Watt function interoperability testing analysis

Based on the test results, the testing system discovers that only SunSpec register Hz 1 and Hz 3 allow the value transferred into. However, the allowable frequency value is too small, which cannot be used for setting a freq-Watt Curve for an inverter to operate. Therefore, the smart inverter GS8048A is not compliant with IEEE 2030.5 opModFreqWattattributes. In

conclusion, the smart inverter does not provide a functionally correct response to the IEEE 2030.5 opModFreqWatt attributes.

6.5.3 Frequency-Watt Sub-component testing preparation

Although the frequency-Watt control of the inverter cannot be verified by the user set points written in opModFreqWatt attributes, we still want to show that our test system sub-components works, specifically when the inverter is connected to the grid simulator. According to the GS8048A operator manual, the inverter supports the bi-directional frequency-Watt control, but the user cannot set points for the frequency-Watt curve like the Volt-VAr function as shown Table 6.16.

Item			Default	Minimum	Maximum
Frequency Watt	Start Freq	High	60.05 Hz	60.05 Hz	65.00 Hz
		Low	59.75 Hz	55.00 Hz	59.95 Hz
	Gradient	High	250% / Hz	5% / Hz	250% / Hz
		Low	133% / Hz	5% / Hz	250% / Hz
	Re-Start Freq	High	60.05 Hz	60.00 Hz	64.90 Hz
		Low	59.85 Hz	55.10 Hz	60.00 Hz
	Re-Start Period		1 min	0 min	30 mins

Table 6.16: Control parameters of the Freq-Watt function in GS 8048A smart inverter

As described in the Grid Support function in the operator manual, users can only set the two start points for the frequency-Watt function, which are the *start frequency high* point and *start frequency low* point. The gradient is the change rate of active power as frequency changes per Hz. A smaller value of the gradient will lead to a lower value of *start frequency low* and a higher value of *start frequency high*. The gradient value set for the frequency-Watt function is 5%/Hz. To enable the frequency-Watt function, the *start freq high* and *low* values should be in the range of *re-start freq high* and *low* values. The *re-start*

period specifies the time that the frequency-Watt function will be re-enabled once the *start freq high* and *low* values are set beyond the range of the *re-start freq high* and *low* values.

The frequency-Watt function testing in this section attempts test the function behavior as the frequency hits the higher band and lower band. Hence, the lowest frequency that can be set as tested with the MATE3s is 55 Hz and the highest frequency that can be set is 65 Hz.

6.5.4 GS8048A Frequency-Watt Function Testing with Grid Simulator

Since the GS8048A does not support bi-directional autonomously frequency-Watt control responding to both over-frequency and under-frequency, the following tests are focused on the frequency-Watt control responding to the over-frequency situations. In order to test the sensitivity of the frequency-Watt function to the frequency changes, the following tests used 2 seconds and 5 seconds for the frequency step changes. Moreover, the different frequency swept direction also applied to the frequency-Watt function.

6.5.4.1 Frequency-Watt testing with 61 Hz and 58 Hz

In this section, the frequency-Watt tests used 61 Hz as the *high start frequency*, which defines the point where the inverter needs to reduce exporting power reacting to the higher frequency. 58 Hz was chosen as the *low start frequency*, which defines the lowest frequency point where the inverter has to export active power. Other frequency points in the range of 55 Hz and 65 Hz can also been selected. 55 Hz is the minimum frequency that inverter can operate with frequency-Watt function and 65 Hz is the maximum frequency that inverter can operate with the frequency-Watt function.

**1. Frequency-Watt test sweep from low frequency to high frequency (58 Hz-61 Hz)
with 2 seconds time step**

This test explores the performance of the frequency-Watt control with 2 seconds time step. The frequency sweep direction is from minimum to maximum. In this test, the maximum export power was set as half of the maximum capacity of the inverter. The expected curve points for 58 Hz (f1) and 61 Hz (f2) are summarized in Table 6.17. The point 3 (f3, W3) is the frequency that the inverter needs to export minimum active power to the grid as frequency increases. This point applies to the rest of frequency-Watt testing as well.

Frequency	Hz	P	Expected Watt
f1	58	W1	1650
f2	61	W2	1650
f3	64	W3	441

Table 6.17: Frequency-Watt curve points with 58 Hz and 61 Hz sweep from the minimum to the maximum frequency.

Figure 6.24: Frequency-Watt testing (58 Hz - 61 Hz) sweep from low frequency to high frequency with 2 seconds time step and half power capacity.

As shown in Figure 6.24, the *low start frequency* point 58 Hz and *high start frequency* point 61 Hz were shifted to the left. The inverter stops exporting the maximum power at the *low start frequency*. The inverter reaches the minimum point to export active power at around 65 Hz.

2. Frequency-Watt test sweep from high frequency to low frequency (61 Hz-58 Hz) with 2 seconds time step

This test explores the performance of the frequency-Watt control with different frequency swept directions compared to the previous test. The frequency step change was set as 2 seconds. The frequency was swept from the maximum value to the minimum value. Moreover, this test also explores the effect brings to the frequency-Watt function when the maximum export power is set as the full capacity of the inverter. The expected curve points for 58 Hz (f1) and 61 Hz (f2) are summarized in the Table 6.18.

Frequency	Hz	P	Expected Watt
f1	58	W2	3600
f2	61	W3	3600
f3	64	W4	300

Table 6.18: Frequency-Watt curve points with 58 Hz and 61 Hz sweep from the maximum to the minimum frequency.

As shown in Figure 6.18, the *low start frequency* point 58 Hz and *high start frequency* point 61 Hz were shifted to the right. The inverter stops exporting the maximum power at the *low start frequency*. The inverter reaches the minimum point to export active power at 65 Hz.

Figure 6.25: Frequency-Watt testing (61 Hz - 58 Hz) sweep from high frequency to high frequency with 2 seconds time step and maximum power capacity.

3. Frequency-Watt test sweep from low frequency to high frequency (58 Hz-61 Hz) with 5 seconds time step

In order to test the accuracy of the frequency-Watt function respond to the different time steps of the frequency changes, the time step of this test is switched to 5 seconds. Within the test, the frequency sweeps from the minimum to the maximum. The voltage set points are summarized in the Table 6.18. The maximum export power was set as full capacity of the inverter.

As shown in Figure 6.26, the *low start frequency* and high start frequency points on the tested curve match with the expected *low start frequency*, 58 Hz, and *high start frequency*, 61 Hz. The inverter reaches the minimum point to export active power at 65 Hz.

Figure 6.26: Frequency-Watt testing (58 Hz - 61 Hz) sweep from low frequency to high frequency with 5 seconds time step and maximum power capacity.

4. Frequency-Watt test sweep from high frequency to low frequency (61 Hz-58 Hz) with 5 seconds time step

Similar to the previous test, this test explores how the frequency-Watt function behaves when the frequency sweeps from maximum to minimum with 5 seconds time step.

The voltage set points are summarized in the Table. 6.18.

Figure 6.27: Frequency-Watt testing (58 Hz - 61 Hz) sweep from low frequency to high frequency with 5 seconds time step and maximum power capacity.

As shown in Figure 6.27, the *low start frequency point*, 58 Hz, and *high start frequency point*, 61 Hz, were shifted to the right compared to the expected frequency-Watt curve. The inverter reaches the minimum point to export active power at 65 Hz.

6.5.4.2 Frequency-Watt testing with 61 Hz and 55 Hz

In order to test the performance of frequency-Watt control when the frequency is set as the minimum acceptable value, the following tests were conducted. Similar to the 58 Hz - 61 Hz tests, the following tests are also conducted with different time steps for voltages and voltage sweep directions.

1. Frequency-Watt test sweep from low frequency to high frequency (55 Hz-61 Hz) with 2 seconds time step

This test explores how well the frequency-Watt control performs when the frequency is set as the minimum acceptable value in the frequency-Watt function. The time step for frequency changes is 2 seconds in this test and the frequency sweep direction is from minimum to maximum. Within this test, the maximum export power was set as half of the maximum capacity of the inverter. The frequency set points of this test are summarized in the Table 6.19. The frequency point f1 is set as the *low start frequency* and point f2 is set as the *high start frequency*. Frequency point f3 is used for testing when the inverter exports the minimum power as the frequency higher than this value. As shown in Figure 6.28, the tested *high start frequency point* is about 62.5 Hz that was shifted to the right compared to the expected *high start frequency point*, 61 Hz.

Frequency	Hz	P	Expected Watt
f1	55	W1	1650
f2	61	W2	1650
f3	64	W3	441

Table 6.19: Frequency-Watt curve points with 58 Hz and 61 Hz sweep from the minimum to the maximum frequency.

Figure 6.28: Frequency-Watt testing (55 Hz - 61 Hz) sweep from low frequency to high frequency with 2 seconds time step and maximum power capacity.

The inverter exports the minimum active power at 64 Hz.

2. Frequency-Watt test sweep from high frequency to low frequency (61 Hz-55 Hz) with 2 seconds time step

Different from the previous test, the frequency sweep direction for this test was changed from maximum to minimum. The frequency step time in this test is still 2 seconds. Moreover, this test also explores the performance of the frequency-Watt control when maximum active power is provided. The frequency set points are summarized in the Table 6.7.

Frequency	Hz	P	Expected Watt
f1	55	W1	3300
f2	61	W2	3300
f3	64	W3	300

Table 6.20: Frequency-Watt testing (55 Hz - 61 Hz) sweep from low frequency to high frequency with 2 seconds time step and maximum power capacity.

Figure 6.29: Frequency-Watt testing (55 Hz - 61 Hz) sweep from low frequency to high frequency with 2 seconds time step and maximum power capacity.

As shown in Figure 6.28, the *high start frequency* was shifted to the right and the inverter exports the minimum power at around 64.5 Hz, responding well to the frequency increase. The maximum export active power matches with the expected 3300 W.

3. Frequency-Watt test sweep from low frequency to high frequency (55 Hz-61 Hz) with 5 seconds time step

This test explores the performance of the frequency-Watt control as the frequency-time step extended to 5 seconds, and the frequency points set close to the minimum acceptable value. The frequency sweep direction of this test is from minimum to maximum. The frequency set points are summarized in Table 6.20.

Figure 6.30: Frequency-Watt testing (55 Hz - 61 Hz) sweep from low frequency to high frequency with 5 seconds time step and maximum power capacity.

As shown in Figure 6.30, the *low start frequency* point on the tested curve matches with the user defined point on the expected curve. The *high start frequency* point was shifted to the right. The inverter exports the minimum power at around 64.5 Hz, responding to the frequency increase.

4. Frequency-Watt test sweep from high frequency to low frequency (61 Hz-55 Hz) with 5 seconds time step

This test explores the performance of the frequency-Watt control when the frequency-sweep direction is from maximum to the minimum. The frequency time step was set as 5 seconds. The voltage set points are summarized in Table 6.20.

Figure 6.31: Frequency-Watt testing (61 Hz - 55 Hz) sweep from high frequency to low frequency with 5 seconds time step and maximum power capacity.

As shown in Figure 6.31, the low frequency start point was shifted down and the *high start frequency* was shifted to the right. The inverter exports minimum power at 64 Hz, responding to the frequency increase.

6.5.4.3 Frequency-Watt testing with 65 Hz and 59.5 Hz

When the *high start frequency* on the frequency-Watt control curve is set close to the high frequency ride-through value, the inverter will not respond to the over-frequency disturbance because the frequency setting is too high for the grid frequency. In the US, the grid frequency is restricted to around $\pm 0.2\%$ of 60 Hz, so the stable grid frequency range is from 59.88 Hz to 60.12 Hz⁵. Such high frequency setting (65 Hz) is meaningless to the grid, but the tests conducted in this station explores the highest frequency value that can be put in the frequency-Watt function using the MATE3s and how well the inverter can follow the frequency-Watt curve. Similar to the test of *low start frequency*, 58 Hz, and *high start*

⁵Depending on the specification of the balancing authority

frequency, 61 Hz, the followings tests are applied with different frequency sweep times and directions.

1. Frequency-Watt test sweep from low frequency to high frequency (59.5 Hz-65 Hz) with 2 seconds time step

This test explores how well the frequency-Watt control was conducted when the frequency points were set as the maximum acceptable value with frequency-time step 2 seconds and sweep direction from minimum to maximum. The frequency set points of this test are summarized in Table 6.8. The maximum export power in this test is half of the maximum capacity of the inverter. Frequency point f2 is the *low start frequency*, 59.5 Hz, and the frequency point f3 is the *high start frequency*, 65 Hz. The frequency point f1 is used to explore how the frequency-Watt function works when the frequency is lower than the *low start frequency*. These three points apply to the rest of tests as well. The frequency set points are shown in Table 6.21.

Frequency	Hz	P	Expected Watt
f1	55	W1	1650
f2	59.5	W2	1650
f3	65	W3	1650

Table 6.21: Frequency-Watt testing (59.5 Hz - 65 Hz) sweep from low frequency to high frequency with 2 seconds time step and half power capacity.

Figure 6.32: Frequency-Watt testing (59.5 Hz - 65 Hz) sweep from low frequency to high frequency with 2s and half power capacity.

As shown in Figure 6.32, the *low start frequency* point, 59.5 Hz, is shifted to the right compared to the user-defined frequency. The inverter stops exporting maximum active power around 59.5 Hz. The maximum export active power is lower than the expected value because the inverter was under discharging during the frequency-Watt test.

2. Frequency-Watt test sweep from high frequency to low frequency (65 Hz-59.5 Hz) with 2 seconds time step

Different from the previous test, the frequency-sweep direction of this test was changed to sweep from maximum to minimum. The frequency step time is set as 2 seconds. Moreover, this test also explores the performance of the frequency-Watt control with maximum acceptable frequency when the maximum active power capacity is provided. The voltage set points are summarized in the Table 6.22.

Frequency	Hz	P	Expected Watt
f1	55	W1	3000
f2	59.5	W2	3000
f3	65	W3	3000

Table 6.22: Frequency-Watt testing (65 Hz - 59.5 Hz) sweep from high frequency to low frequency with 2 seconds time step and full power capacity.

Figure 6.33: Frequency-Watt testing (65 Hz - 59.5 Hz) sweep from high frequency to low frequency with 2 seconds time step and full power capacity.

Different than any other frequency-Watt testing, the inverter was trying to export the maximum power even through the frequency is lower than the *low start frequency* 59.5 Hz, but without success. As shown in the Figure 6.33, the inverter started decreasing maximum export power at frequency is blow 59 Hz.

3. Frequency-Watt test sweep from low frequency to high frequency (59.5 Hz-65 Hz) with 5 seconds time step

This test explores the performance of the frequency-Watt control as the frequency-time step extends to 5 seconds, and the frequency points were set close to the maximum acceptable values. The frequency sweep direction of this test is from minimum to maximum. The frequency set points are summarized in Table 6.22

Figure 6.34: Frequency-Watt testing (59.5 Hz - 65 Hz) sweep from low frequency to high frequency with 5 seconds time step and full power capacity.

As shown in Figure 6.34, the inverter starts decreasing the maximum power when the frequency is lower than 59.5 Hz, but it was trying to export the maximum power.

4. Frequency-Watt test sweep from high frequency to low frequency (65 Hz-59.5 Hz) with 5 seconds time step

This test explores the performance of the frequency-Watt control when the frequency-sweep direction was changed to sweep from maximum to minimum. The frequency time step was set as 5 seconds and the frequency set points are summarized in Table 6.22.

Figure 6.35: Frequency-Watt testing (65 Hz - 59.5 Hz) sweep from high frequency to high frequency with 5s time step and full power capacity.

Different than the previous two tests where the inverter was trying to export the maximum power, the inverter clearly stopped exporting the maximum power as the frequency dropped below 59.5 Hz. When the frequency is between 59.5 Hz and 65 Hz, the frequency-Watt control performs as expected, following the user-defined curve.

6.5.5 Frequency-Watt function Sub-component Testing Analysis

Based on the above testing result, the inverter testing system has the ability to test both the lower band and higher band of the frequency in the frequency-Watt function. The inverter has the ability to test the frequency-Watt function with different frequency sweep directions and is able to test the frequency-Watt function with different frequency time step changes even the GS 8048A smart inverter not always follow the user-defined curve very well.

7 Conclusion

The motivation of this research was to develop a testing system for testing the interoperability of a grid-interactive smart inverter. The test system consists of three parts: send the IEEE 2030.5 messages to a DER controller and transfer the control parameters to the inverter; verify if the inverter can successfully receive and use those control parameters; use the grid simulator to test the ability of an inverter to follow the user-defined Volt-VAr and Frequency-Watt curve.

The smart inverter cannot directly accept use IEEE 2030.5 messages to operate its functions, so a DER client was created in the test system to convert the IEEE 2030.5 message to the control parameters for the inverter to use. The DER client is a program written in C++ and running on a Raspberry Pi. The DER client is able to receive the user-defined IEEE 2030.5 messages and transfer the messages to the control parameters. This is demonstrated by executing the DER program on the Raspberry Pi. However, not all the IEEE 2030.5 attributes can be successfully transferred since some SunSpec registers in the AXS port of the GS8048A smart inverter have not been implemented. The DER client controls the inverter through the AXS port because the inverter is a register-controlled device and the AXS port is the collection of the SunSpec registers to control the inverter.

In order to verify if the inverter receives the control parameters or not, the Outback Shell program and Modbus Poll are used. These two methods read the status of the SunSpec

registers as long as the IP address of the AXS port can be figured. Based on the test result of using the Outback Shell program and Modbus Poll in the analysis section, some values defined in the IEEE 2030.5 were successfully transferred. The values that cannot be transferred are because not all the IEEE 2030.5 attributes to the inverter have a relevant SunSpec register to use. Some SunSpec registers have not been developed or implemented in the AXS port for the GS8048A smart inverter.

To show if the inverter has the ability to follow the user-defined control curve, the grid simulator is used. The grid simulator provides variable voltage and frequency changes for the inverter to enable and operate with Volt-VAr and frequency-Watt function. As many test results show in the analysis section, the GS8048A smart inverter sometimes cannot correctly follow the user-defined Volt-VAr and frequency-Watt curves. The test system developed for this thesis research is a success since the test system has the ability to test different functions of an inverter.

In all, the testing system designed for the grid-interactive smart inverter can perform tests for such inverters to meet the relevant IEEE 2030.5 functionality.

Bibliography

- [1] J. G. Kassakian, W. M. Hogan, R. Schmalensee, and H. D. Jacoby. The future of the electric grid, Boston, MA, USA: MIT Press 2011.
- [2] Goran Strbac. Demand side management: Benefits and challenges. *Energy Policy*, 36:4419–4426, November 2008. [Online].
- [3] Noriko Kawakami and Yukihiisa Iijima. Overview of battery energy storage systems for stabilization of renewable energy in Japan. In *2012 International Conference on Renewable Energy Research and Applications (ICRERA)*, pages 1–5, 2012.
- [4] Matthew T. Lawder, Bharatkumar Suthar, Paul W. C. Northrop, Sumitava De, C. Michael Hoff, Olivia Leitermann, Mariesa L. Crow, Shriram Santhanagopalan, and Venkat R. Subramanian. Battery energy storage system (BESS) and battery management system (BMS) for grid-scale applications. *Proceedings of the IEEE*, 102(6):1014–1030, 2014.
- [5] Aaron Larson. What is DERMS and how can it help utilities? *POWER Magazine*, July. 08 2020. [Online].

- [6] Office of Energy Efficiency and Renewable Energy. Using distributed energy resources: A how-to guide for federal facility managers. *Cogeneration and Competitive Power Journal*, 17:4(2), 2002. [Online].
- [7] U.S. Energy Information Administration. Battery storage in the United States: An update on market trends. Technical report, Washington, DC, USA, 2020. [Online].
- [8] Kelsey Misbrener. Smart inverters redefine relationship between DERs and the grid. *Solar Power World*, March. 12 2019. [Online].
- [9] Microgrid Knowledge Editors. How DERMS and smart inverters safely bring distributed resources to the grid. *Microgrid Knowledge*, Jun. 25 2018. [Online].
- [10] O.I. Adekola and A.K. Raji. Functionalities of smart inverter system for grid-connected applications. In *2015 International Conference on the Industrial and Commercial Use of Energy (ICUE)*, pages 340–344, 2015.
- [11] Gordon Lum. California use case for IEEE 2030.5 for distributed energy renewables. *IEEE newsletter*, Dec 2016 [Online].
- [12] Lloyd Cibulka, Tom Tansy, Bob Fox, Suzanne Martinez, Dr. Jan Kleissl, and Edmund G. Brown Jr. Smart inverter performance testing to UL 1741 SA and CA Rule 21 criteria. *RAND Corp.*, Santa Monica, CA, USA, RR-1776-NYCEDC, 2018 [Online].
- [13] SunSpec Orgnazation. *Common Smart Inverter Profile*, March, 2018.

- [14] California Public Utilities Commission. *SIWG Phase 3 DER Functions: Recommendations to the CPUC for Rule 21, Phase 3 Function Key Requirements, and Additional Discussion Issues*, March 31, 2017.
- [15] Stuart Mccafferty. Creating DER integration solution architectures using IEEE 2030.5 and the energy IoT common reference model. GridIntellect, LLC in the Digital Utility Group.
- [16] Frédéric Wauquiez. IEEE 2030.5 – connect to the wide world of distributed energy resources. General Electric Digital website, Aug. 5 2020. [Online].
- [17] James Obert, Patricia Cordeiro, Jay Johnson, Gordon Lum, Tom Tansy, Max Pala, and Ronald Ih. Recommendations for trust and encryption in DER interoperability standards, 02 2019.
- [18] Outback Power Company. Radian series inverter/charger GS8048 operator’s manual, Oct 2013. [Online].
- [19] Outback Power Technologies. *MATE3s Advanced System Display and Communications*. Arlington, WA, USA, 2019 [Online].
- [20] Outback Power Technologies. AXS port sunspec modbus interface owner’s manual, April 2016. [Online].
- [21] Inc Aquion Energy. Operations manual battery module model M100-LS082, 2016.

- [22] NH Research, Inc, Irvine, California. *NHR 9410 9420 Series User's Manual*, L edition, June 20, 2019.
- [23] Tektronix. *Power Analyzer PA4000 Datasheet*. Portland, OR, USA, February 2016.
- [24] Tektronix. *TPS2000B Digital Storage Oscilloscopes*. Portland, OR, USA, October 2018.
- [25] IEEE standards association. IEEE standard for smart energy profile application protocol. *IEEE Std 2030.5-2018 (Revision of IEEE Std 2030.5-2013)*, pages 1–361, 2018.
- [26] James Mater, Steve Kang, and Robby Simpson. IEC 61850 and IEEE 2030.5: A Comparison of 2 Key Standards for DER Integration: An Update. PacWorld, 2019. [Online].
- [27] Outback Power Technologies. *Mate3s Overview Guide*. Arlington, WA, USA, November 2019.
- [28] Dr. Meter Inc. PS305DM-DC bench power supply user manual. Dr. Meter website.
- [29] Tektronix. *PWRVIEW Online Help*. Tektronix, Inc, Beaverton, OR, USA, March 2016. [Online].
- [30] Andy Hoke, Austin Nelson, Jin Tan, Vahan Gevorgian, Chris Antonio, Ken Fong, Mohamed Elkhatib, Jay Johnson, Rasel Mahmud, Jason Neely, and Dean Arakawa. The

Frequency-Watt Function Simulation and Testing for the Hawaiian Electric Companies.

NREL government official website, 2017 [Online].

- [31] Karl Stein, Moe Tun, Marc Matsuura, and Richard Rocheleau. Characterization of a Fast Battery Energy Storage System for Primary Frequency Response. *Energies*, 11(12), 2018.